

DEMOCRATIC REPUBLIC OF TIMOR-LESTE
MINISTRY OF PUBLIC WORKS

PROJECT DOCUMENT FOR ENVIRONMENTAL LICENSING OF
WATER SUPPLY
LAUTEM MUNICIPAL CAPITAL

Rev.4 – Final

September 2021

DISCLAIMER

This Project Document has been prepared by ADP/ENGIDRO on behalf of and for exclusive use of the Government of the Democratic Republic of Timor-Leste, through the General Directorate for Water and Sanitation (now Be'e - TL) /Ministry of Public Works (MPW), and issued in accordance with the legal requirements in effect in Timor-Leste.

ADP/Engidro and its partner companies accept no liability or responsibility whatsoever for it in respect of any use of or reliance upon this report by any third party, or any versions of said document, in any language other than English.

DOCUMENT TECHNICAL DATA

Title:	PROJECT DOCUMENT FOR ENVIRONMENTAL LICENSING FOR WATER SUPPLY IN LAUTEM MUNICIPAL CAPITAL
OWNER:	Be'e Timor-Leste (BTL)
Location:	Lospalos, Lautem, Timor-Leste
Name of Project:	Consulting Services for Detailed Engineering Design of Timor-Leste Four Municipal Capitals Water Supply & Sanitation Project
Key Expert:	Vasco Lobato Leitão (Environmental Specialist)
National Expert:	Maria Helena de Jesus (Environmental Engineer)
Technical Support:	Nofiano Ruas (Environmental Technician)
Date:	10 September 2021
Version:	Rev.4 – Final

ACRONYMS AND ABBREVIATIONS

2DCWSP	- Second Districts Capital Water and Sanitation Project
4MCWSSP	- 4 Municipal Cities Water Supply & Sanitation Project
ADB	- Asian Development Bank
FSTP	- Faecal Sludge Treatment Plant
PDC	- Project Design Consultant
DED	- Detailed Engineering Design
BTL	- General Directorate for Water and Sanitation
BTL	- Be'e Timor-Leste
DNSA	- National Directorate for Water Services
SMASA	- Municipal Service for Water, Sanitation, and Environment
EARF	- Environmental Assessment and Review Framework
EHS	- Environment, Health and Safety
EIA	- Environmental Impact Assessment
EIS	- Environmental Impact Statement
EMP	- Environmental Management Plan
EMR	- Environmental Monitoring Report
ESS	- Environmental Safeguard Specialist
ESA	- Environmental Safeguard Assistant
FSTP	- Faecal Sludge Treatment Plant
GRM	- Grievance Redress Mechanism
IEE	- Initial Environmental Examination
IFC	- International Finance Corporation
Masl	- meters above sea level
MPW	- Ministry of Public Works
PA	- Protected Area
PD	- Project Document
PMU	- Project Management Unit
SEA	- Superior Environmental Authority
SEIS	- Simplified Environmental Impact Statement
SEMP	- Site-specific EMP
SPS	- Safeguard Policy Statement
TOR	- Terms of Reference
WDZ	- Water Distribution Zone
WTP	- Water Treatment Plant
WHO	- World Health Organization
WSS	- Water Supply And Sanitation

TABLE OF CONTENTS

INTRODUCTION	1
1. PROPONENT DETAILS	2
2. PROJECT LOCATION AND SCALE	2
2.1 GEOGRAPHICAL LOCATION	2
2.2 AREA COVERED, SCALE AND PROJECT COMPONENTS	3
2.3 MATERIAL SOURCE AND PROJECT COST	4
3. DISTRICT AND VILLAGES	12
4. PLANS AND TECHNICAL DESIGN OF THE PROJECT	12
4.1 PROJECT DESCRIPTION	12
4.1.1 <i>General Description</i>	12
4.1.2 <i>Water Supply System</i>	13
4.1.3 <i>Sanitation System</i>	19
4.2 PROPOSED WATER SUPPLY AND SANITATION SYSTEM	20
4.2.1 <i>Water Supply System</i>	20
4.2.2 <i>Sanitation System</i>	24
5. FEASIBILITY STUDY OF THE PROJECT	36
6. LAND AND WATER USE	37
6.1 LAND USE	37
6.2 WATER USE	38
7. ENVIRONMENTAL IMPACTS	40
7.1 BIOPHYSICAL IMPACTS	40
7.1.1 <i>Water Quality</i>	40
7.1.2 <i>Air quality and noise</i>	43
7.1.3 <i>Climate</i>	43
7.1.4 <i>Topography</i>	43
7.1.5 <i>Flora and Fauna</i>	44
7.1.6 <i>Socio-Cultural Impacts</i>	44
7.1.7 <i>Health and Economic Impacts</i>	44
7.1.8 <i>Socio-Cultural and Heritage Buildings</i>	45
8. PUBLIC CONSULTATION	47
9. CONSULTATION WITH OTHER AUTHORITIES	49
10. PROPOSED CLASSIFICATION OF THE PROJECT	49
11. EXECUTIVE SUMMARY	51
12. BIBLIOGRAPHY	52
APPENDIX 1. MAP OF LAUTEM MUNICIPALITY AND THE PROJECT	54
APPENDIX 2. ENVIRONMENTAL LICENSE ADB 0258-TIM PROJECT – MANATUTO DISTRICT	56
APPENDIX 3. ENVIRONMENTAL LICENSE ADB 0258-TIM PROJECT – RAEOA	60

APPENDIX 4. TRANSCRIPTS OF PUBLIC CONSULTATION (12 OCTOBER 2020)	64
APPENDIX 5. WATER QUALITY TEST REPORT (JICA & MASTERPLAN)	66
APPENDIX 6. D4 PRELIMINARY DESIGN REPORT	87
APPENDIX 7. ADB PROCESS INITIAL ENVIRONMENTAL EXAMINATION (IEE) – LOSPALOS	88
APPENDIX 8. “NO OBJECTION” LETTER FROM LAUTEM MUNICIPAL ADMINISTRATION	89
APPENDIX 9. PUMP TEST RESULTS	90

LIST OF TABLES

Table 1 - Boreholes GPS Locations	4
Table 2 - Water Supply - Summary of the Proposed Infrastructures	4
Table 3 - Preliminary Cost Estimate for 4MCWSSP Lautem Municipality.....	5
Table 4 - Land due Diligence	11
Table 5 Water Demands & Deficits with Existing and Future Sources	17
Table 6 - Water Sources Scenarios	20
Table 7 – Proposed Water Tanks Storage.....	22
Table 8 - Total Population versus Distribution Network Length versus Supply Zones – Lospalos City.....	23
Table 9 – Materials for Reutilizing.....	24
Table 10 - Total Septage Volume to be collected daily projections.....	28
Table 11 FSTP Possible Locations and description	35
Table 12 – Summary and Timetable of Feasibility Studies Conducted	36
Table 13 - Summary of Potential Environmental and Social Impacts of the Project.....	41
Table 14 - Identified Cultural, Historical & Touristic Sites in Lospalos.....	45
Table 15 - Estimated Environmental Classification for Lospalos Project Components.....	50

LIST OF FIGURES

Figure 1 – Proposed Water Distribution System for Lospalos (AdP-TL 2021)	6
Figure 2 - Location of the Lospalos WATSAN Project within Lautem Municipality.....	7
Figure 3 – Northwest Water Systems	9
Figure 4 - Papapa and Southern Water System.....	10
Figure 5 Lospalos Existing Water Sources	14
Figure 6 Example of Distribution areas and existing installation.....	15
Figure 7 - Water Resources Extraction versus Water Demand and Yearly Service Area Total Population	18
Figure 8 New Boreholes and pump testing.....	18
Figure 9 Lospalos Water Sources Scenario I.....	21
Figure 10 Lospalos Water Sources Scenario II (North System)	21

Figure 11 Lospalos Water Sources Scenario II (South System)	22
Figure 12 - Laying of Transmission and Distribution Lines along the Road. Typical Cross Sections	23
Figure 13 - Typical Double Trench	23
Figure 14 - Septic tank for up to 50 persons capacity	25
Figure 15 - Septic tank for up to 200 persons capacity.....	25
Figure 16 - Public Toilet layout.....	26
Figure 17 - Public Toilets Proposed Location Lospalos	27
Figure 18 - Aerial Image of Public Toilets Proposed Locations.....	27
Figure 19 FSTP Lospalos installation and segments.....	29
Figure 20 Photographs of Proposed FSTP Site and surroundings	30
Figure 21 Proposed FSTP Site (Parapata) location	33
Figure 22 - Parapata FSTP and Characteristic of the Area	34
Figure 23 Land Use in Project Area.....	39
Figure 24 Lospalos identified Cultural Sites	46
Figure 25 – Lospalos Public Consultation; participation of the Local Community and Other Stakeholders.	47
Figure 26 Suco Fuiloro Social Public Consultation	48
Figure 27 Suco Home Public Social Consultation.....	48

INTRODUCTION

The significant growing number of the population in all Municipalities is resulting in the increase of water demand and wastewater production in the private and domestic sectors. Issues such as continuous water scarcity, poor infrastructures, inadequate water and wastewater quality has led the Government of Timor-Leste to focus on the water and sanitation improvement, particularly in the district areas.

The Four Municipal Capitals Water Supply & Sanitation Project (4MWSSP) will support the Government of Timor-Leste in providing access to improved water supply and sanitation (WSS) in 4 municipalities (Baucau, Lautem, Viqueque and Same) by drawing on experiences and lessons learned from the ADB Second District Capitals Water Supply Project (46160-001) ADB TA-8064 TIM.

The project will build upon the current Government efforts in providing water supply and sanitation (WSS) services in Timor-Leste's urban areas, working towards the achievement of Sustainable Development Goal (SDG)-6 to ensure availability and sustainable management of water and sanitation for all by 2030, in line with the country's Strategic Development Plan 2011 – 2030 (G-RDTL, 2011), specifically the water and sanitation strategy of "...providing a safe piped 24-hour water supply to households in 12 District [now "municipality"] centres..., by 2030,..." across Timor-Leste. It will also finance climate-resilient and inclusive WSS infrastructure in project municipalities and strengthen institutional and community capacity, sustainable service delivery, and project development.

The 4MWSS Project intends to produce the following outputs:

- 1) Propose the rehabilitation and expansion of the urban water supply system for Baucau, Lospalos, Same and Viqueque municipal capitals.
- 2) Establish fully functioning water supply and sanitation infrastructure in pilot schools and public areas i.e. markets that is effectively operated, maintained, and managed to provide a minimum level of service for water supply and sanitation to all citizens.
- 3) Facilitate new or improved household sanitation in all households in the Municipal capitals of Baucau, Lospalos, Same and Viqueque.
- 4) Establishing septic tank sludge treatment and disposal facilities and associated sludge transport system in the municipal capitals.

The Ministry of Public Works (MPW) is responsible for planning, implementation, regulation, and monitoring of WSS, specifically the Be'e Timor-Leste (BTL), which, under the MPW, manages the Water and Sanitation facilities in the municipalities, these operated locally by the SMASA Lautem.

The MPW recognized its regulatory duty, as project proponent, as mandated in Decree Law No. 5/2011 - Environmental Licensing, to file a Project Document to the National Authority for Environmental Licensing (ANLA), as the start-up document for project screening and categorization under the environmental licensing process, for ALL 4 cities.

This Project Document's objective is to provide clear and relevant information on the proposed Water System Improvement Project for **Lospalos Municipal Capital only** (hereinafter called "Lospalos WATSAN Project") identified, located and described in Chapter 4.1, taking into account that its rehabilitation will be carried out under a future ADB loan to the Government of Timor-Leste. **The project will also include a Sanitation sub-component to cover the Proposed Public Toilets and the implementation of a Feecal Sludge Treatment Plant (FSTP) as destination of the collected septic sludge in the city.**

One of the Project Document's primary source of information is a previous study carried out in 2015, by the consultancy firm Aurecon (ADB, 2016), commissioned by the ADB (Asian Development Bank) to carry out the Technical Assistance (TA-8064) for the Second (2nd) District Capitals Water Supply Project (46160-001) and produce a demand responsive investment Masterplan to meet the water supply and sanitation needs of Timor-Leste's urban populations in Baucau, Lospalos, Viqueque and for Same, for the period to 2030, in line with national development plans and targets as outlined in the Timor-Leste Strategic Development Plan 2011 – 2030.

The ADB evaluated the environmental impact of the proposed rehabilitation through an Initial Environmental Examination (IEE) process under the ADB Safeguard Policy Statement (SPS) 2009 and concluded that the

rehabilitation and management of the proposed Water and Sanitation components within the Lospalos project area, would improve significantly the life of the Lospalos Municipal Capital dwellers, classifying the project as a Category B for environmental impact because the potential adverse environmental effects are site-specific, few (if any) were irreversible, and technical design and mitigation measures could be designed to address them.

Given the content of the information in the ADB commissioned IEE (ADB, 2015), this Project Document intends to propose a similar pathway and classification of the upcoming environmental study and provide updated information on the overall current legal and technical framework and secondary baseline data for the Lospalos components to, on the one hand, maintain the environmental thoroughness of the previous study and on the other hand verify if there is any change regarding the environmental impact conclusion and adapt and/or update the previous mitigation and management measures proposed to further improve the environmental sustainability of the future rehabilitated Water System in Lospalos Municipal Capital.

I. PROPONENT DETAILS

The Ministry of Public Works (MPW) is responsible for planning and oversight of the Water and Sanitation Sector and is the Proponent for the Lospalos WATSAN Project, supported by the Be'e Timor-Leste (BTL), responsible for the overall management, implementation and monitoring of the 4MWSSP project, while the SMASA Regional Office in Lospalos will manage day-to-day Lospalos WATSAN project implementation, construction and operation at the municipality level.

The project proponent and representative details/contacts for the Lospalos WATSAN Project are the following:

Proponent

Ministry of Public Works (MPW),
Mr. Salvador Eugenio Soares dos Reis Pires, Minister
MPW Corporate Services Building
Avenida 20 de Maio, Caicoli, Díli, Timor-Leste

Proponent Primary Contact

Be'e Timor-Leste (BTL)
Mr. Carlos dos Reis, President
BTL Compound
Avenida 20 de Maio, Caicoli, Díli, Timor-Leste
(Telephone: +670 78001012 / email: cdosreis@gmail.com)

Proponent Secondary Contact

Be'e Timor-Leste (BTL)
Mr. Almeida Boavida
Manager of Research, Project and GIS
BTL Compound, Avenida 20 de Maio, Caicoli, Díli,
Timor-Leste (Telephone: 78305968)

Proponent Tertiary Contact

SMASA Lautem Office
Mr. Jose Vila Nova, Director
Lautem, Lospalos Timor-Leste
(Telephone: 77326901)

The Ministry of Public Works (MPW), on behalf of the Government of the Democratic Republic of Timor-Leste, contracted the consortium Águas de Portugal Timor-Leste / Engidro to prepare the “*Detailed Engineering Design of Timor-Leste Four Municipal Capitals Water Supply & Sanitation Project of Baucau, Manufahi, Lautem and Viqueque*”, financed by the Infrastructure Fund of the Government of Democratic Republic of Timor-Leste. Vasco Leitão is the Environmental specialist responsible in preparing this Project Document on behalf of ADP-TL/Engidro.

The Consultant contact details for the Lautem WATSAN Project are as follows:

ADP-TL/Engidro Lead Consultant:
Mário Santos
Mobile: +670 778 47 15 15
Email: m.santos@adp.pt

Environmental Specialist:
Vasco Lobato Leitão
Mobile: +670 77 25 25 69
Email: vasco.al.leitao@oasis-sustainable.com

2. PROJECT LOCATION AND SCALE

2.1 Geographical Location

The 4 MCWSS Lospalos project is located in the urban area of Lospalos Municipal Capital Administrative post of Lospalos, Lautem Municipality, Lautem Administrative post in the northern border, Iliomar and Luro Administrative Posts in the western and southwest border, and the east bordering with Tutuala Administrative

post (See Appendix I. General Map of the Project Area). Geographical coordinates of the project site are in the SW latitude of 8°35'31.60"S and longitude of 126°55'42.00"E and NE latitude of 8°27'26.40"S and longitude of 127°3'48.14"E.

2.2 Area Covered, Scale and Project Components

The Project scope includes all the areas that will be required to implement the Abstraction, Treatment and Distribution of Water for Human Consumption, as well as provide designs and solutions for Sanitation for Buildings, Schools and Housing within a diameter area of 15 Km around the Municipal Capital, as clarified by the client in April 2020, taking the Lospalos Water Distribution Zones defined in the Second District Capitals Water Supply Project (ADB, 2016) as the guidelines for the project area and scope. The 15 Km diameter is also based on limiting the project not to exceed its sanitation activities farther than the designated scope, so that it will not negatively impact much further on the environmental and social components, in other words, there will be no increasing in terms of the magnitude of the impacts.

As we can see in Figure 2, the 15 Km range Lospalos WATSAN Project area encompasses the following:

- Suco Fuiloro: almost the entire suco area, as it lies almost totally within the 15Km and includes the entire proposed Water Supply Network, the existing Papapa and Puahopo Springs and most of the proposed borehole testing sites and the sanitation component;
- Suco Home: half of the suco area, the existing borehole (2Km away from Papapa spring) and some of the proposed borehole testing sites and 1 public toilet;
- Suco Leuro, Souro, Lore II, Muapitine, Bauro and Raça: all these sucos are included in or overlap a bit with the 15Km project limit but, to date, no project component or activity is planned to occur within them.

On the other hand, the Sanitation Component of Lospalos WATSAN Project area encompasses all households, buildings and schools within the 15Km diameter project area that are served by the proposed Faecal Sludge Treatment Plant (FSTP).

The team carried out site visits respectively on the 18th – 19th of February 2020 (inception phase) and 2nd – 4th of June 2020 aiming to evaluate the specific environmental conditions of Lospalos city. The Team identified that the 15 Km diameter project area overlaps several cultural patrimony sites that lie adjacent and parallel to the project components i.e. transmission and distribution mains, albeit the proponent intends to apply mitigation measures diligently so that the referred sites are not impacted. The team did a field observation and an interview with several entities from Lautem Cultural Centre in order to identify these sites. Other sites such as sensitive biodiversity areas were identified in Kokoho Marsh, upstream of Papapa lagoon, and in Heller Marsh, West of the FSTP proposed site. The team was informed by the local administration i.e. Chefes de Suco, that the communities note there is movement of some wildlife through both the above mentioned areas, however it was not possible to understand if there are established hunting areas within the project area.

The implementation of the project is associated according to the project cycle, which comprises of 4 phases, commencing from the design activity. The subsequent phases are the construction activities of infrastructures, following the operational and maintenances of the facilities, and the decommissioning. Taking into account that each component is considered in order to elaborate the environmental management plan comprehensively, the project components are all aggregated within the 15 km radius project scope as shown in Figure 2, to be rehabilitated and/or newly constructed as described below:

- a) Water Sources: the Lospalos water supply system for the community includes one spring and a lagoon, composed of:
 - i) Puahopo spring that will be abstracted into the water treatment plant;
 - ii) Papapa Lagoon, associated with Papapa spring that will contribute to the community's agriculture farms and the remaining flow will be released to the environment.

It's important to note that Puahopo spring and Papapa lagoon are located adjacent to each other, while the Papapa spring is in the South side of the lagoon (See Figure 3) and although tested for its productivity, is currently not used. To the Southeast of the Papapa lagoon is the weir for alternative

abstraction surface water. These 3 sources are probably connected to one another and are assumed to be in one aquifer system because of their location.

- b) Several new bore wells as additional sources to be included in the system and complement the existing springs. 7 boreholes in total are proposed in this project, 3 of them to be constructed as reserve for future demand requirements. Below is the list of names of the boreholes, both constructed and not yet constructed, including their GPS location.

Table 1 - Boreholes GPS Locations

Boreholes	GPS Coordinates
Borehole #2 - Home 1 (RN438)	8°30'9.32"S / 126°57'40.38"E
Borehole #3 - Home 2 (RN439)	8°30'14.66"S / 126°57'35.42"E
Borehole #8 - Home 3	8°30'12.48"S / 126°57'48.41"E
Borehole #7 - Home 4	8°30'19.04"S / 126°57'44.39"E
Borehole #6 - DNSA 2018	8°30'16.33"S / 126°58'18.00"E
Borehole #5 - Sawarica (RN441)	8°31'40.35"S / 126°59'28.73"E
Borehole #9	8°31'42.71"S / 126°59'27.90"E

- c) Water Distribution Zones: The main Puahopo spring supplies storage reservoirs and these subsequently supply 3 distribution zones with manual rotation in terms of supplying to the customers through gravity transmission and distribution pipelines.
- d) Sanitation Sector: 4 public toilets pilot tests in located within the 15 km project area and a new Faecal Sludge Treatment Plant (FSTP) to be implemented in Parapata, suco Fuiloro. This proposed site is in an open area within the Lospalos plains, 1,400 m East of Zone 3.2 and right next to the Municipal Capital solid waste dumpsite, as well as a large agricultural area 400m to the East and 200m to the South.

Proposed water supply infrastructures for Los Palos are compiled below.

Table 2 - Water Supply - Summary of the Proposed Infrastructures

Water Supply System	Los Palos	
Water Sources	Springs (un.)	1
	Boreholes (un.)	7
	Lagoon (un.)	1
	River Intake (un.)	0
Raw Transmission Mains (m)	4,958	
Water Treatment Plants (un.)	1	
Chlorination Buildings (un.)	2	
Water Tanks (un.)	3	
Water Tanks (total m ²)	4,250	
Transmission Mains (m)	8,470	
Distribution Network (m)	53,487	

The proposed water supply system is reflected in Figure 1 (see also Appendix 1 and 6), also citing the length of transmission mains that conveys both raw and treated water from water spring intakes and boreholes, along with water storage, distribution reticulations discriminated per sub-zones. The raw transmission mains are associated separately according to the proposed water sources (groundwater and springs) i.e., Puahopo spring and 7 boreholes located in different Sucos ("Villages"). Water that is extracted will be treated before entering the storages. The proposed water supply is described in Section 4.

2.3 Material Source and Project Cost

This project will need raw materials for the implementation of construction activities such as sands, rocks and other necessary aggregated materials sourced from existing legitimate suppliers and designated quarry to be extracted nearby the project area. Before proceeding on the material extraction in the selected quarry, it is important to make sure that the activity is licensed, which will be prepared according to the procedure required.

Although, trenching activity will preferably be chosen to do backfilling of the excavated soil, in order to minimize mobilization and reduce excessive extraction on the quarry. While the cement is imported and the production of the concrete is done at projection sites. The preliminary cost of the 4MCWSSP for Lautem Municipality is estimated around \$16,112,852 for proposed water supply and sanitation expenses, which is presented in the following table below:

Table 3 - Preliminary Cost Estimate for 4MCWSSP Lautem Municipality

Water Supply System	USD (\$)
Water sources and raw transmission mains	2,087,814
Water treatment plant	939,360
Water tanks and pumping stations	3,068,820
Transmission mains	1,456,632
Distribution network	7,493,306
Sanitation	USD (\$)
Faecal Sludge Treatment Plant	861,480
Construction of 4 public toilets per City	205,440

Figure I – Proposed Water Distribution System for Lospalos (AdP-TL 2021)




Figure 2 - Location of the Lospalos WATSAN Project within Lautem Municipality




Figure 3 – Northwest Water Systems





Figure 4 - Papapa and Southern Water System



2.4 Land Ownership

Table 4 - L results from the Social team survey regarding land ownership within the project components, namely public/government, private, and community land. This survey followed ADB Social Safeguards and procedures. Most of the land required for the project component has been identified as public land. Those plots registered as private land will follow the compensation process applicable in Timor-Leste, such as the customary land methodology or the legal procedure in the law.

Table 4 - Land due Diligence

Project Components	Physical site		Site ownership		Comments
	Area ('000 m ²)	Date Visited	Public	Private	
Intakes					
Northwest Borefield					
Bore 1	0.00125	07-12-20		√	Members of the community who were present during the visit reported that the AH are actual users and claimant of the land
Bore 2	0.00125	07-12-20		√	
Bore 3	0.00125	07-12-20		√	
Bore 4	0.00125	07-12-20		√	
South Bore field					
Bore 1	0.00125	07-12-20		√	Members of the community who were present during the visit reported that the AH are actual users and claimant of the land
Bore 2	0.00125	07-12-20		√	
Raw Water Transmission (Length x 0.6m-width)					
Northwest Bore 1		07-12-20	√		Transmission pipes will run along the road corridor
Northwest Bore 2		07-12-20	√		
Northwest Bore 3		07-12-20	√		
Northwest Bore 4		07-12-20	√		
Existing bore		07-12-20	√		
Northwest Bore 2/3		07-12-20	√		
Northwest Bore 3/4		07-12-20	√		
Northwest Bore 4/ Northwest Tank		07-12-20	√		
South Bore 1		07-12-20	√		
South Bore 2		07-12-20	√		
WTP	2.2365	08-12-20	√		The WTP is on an existing location which is public land based on public knowledge. Members of the community, confirms that the land has no claimant and active user.
Reservoirs (including pump stations)					
Northwest tank	0.9000	07-12-20		√	Members of the community who were present during the visit reported that the AH are actual users and claimant of the land.
Papapa West Tank	0.9000	08-12-20	√		There is an existing ground tank The location is public land based on public knowledge. Members of the community, reported that the land has no claimant or active users.
South Tank & Pump station	0.9000	08-12-20	√		The location is public land based on public knowledge. Members of the community, confirm that the land has no claimant or active users.
Treated Water Transmission Mains (Length x 0.6m-width)					
Northwest tank to bifurcation to Papapa West Tank	2.8122	07-12-20	√		Transmission pipes will run along the road corridor
Connection of Papapa West Tank	0.3540	07-12-20	√		
Bifurcation to Papapa West Tank - Future connection to supply Zone I.3	0.5730	07-12-20	√		
Connection to South Tank	2.3328	07-12-20	√		
Papapa WTP to Papapa West tank	0.2190	07-12-20	√		
Distribution network (Length x 0.6m-width)	35.7804	07-12-20	√		Distribution pipes will run along the road corridor
FSTP	10.9812	08-12-20	√		The location is a public land based on public knowledge. Members of the community, reported that the land has no claimants or active users.
Toilets					

Project Components	Physical site		Site ownership		Comments
	Area ('000 m2)	Date Visited	Public	Private	
Toilet 1	0.0840	07-12-20	√		Location is public land within the perimeter of the Lospalos Market (please refer to Plate 8)
Toilet 2	0.0840	07-12-20	√		Location is public land within the perimeter of the Cultural Center in Lospalos (please refer to Plate 9)
Toilet 3	0.0840	08-12-20	√		Location is public land in the future government site in Lospalos (please refer to Plate 10)
Toilet 4	0.0840	08-12-20	√		Location is public land within the perimeter of the health center in Suco Home (please refer to Plate 11)

3. DISTRICT AND VILLAGES

As previously mentioned, the 4 Municipal Capitals Water Supply and Sanitation Project (4MCWSSP) for Lautem Municipality will cover 2 sucos, namely **Suco Fuloro** (where 8 of the 11 aldeias will be covered by the system [Nacroman, 30 de Agosto, Lospala, Central, Bemoris, Ira-ara, Lereloho, Kuluhu]) and **Suco Home** (where 3 of the aldeias will be covered by the system [Tchenuloru, Reisoru, Larinatcha]). However, there are some sucos that are included in or overlap a bit with the 15 Km project limit, which are **Suco Leuro, Lore II, Muapitine, Souru, Bauro and Raça** but no project component or activity is planned to occur within them. **Therefore, no impacts will be expected in those mentioned aldeias and areas, as well as other areas outside Lospalos city.**

The total population according to the 2040 projection is 39,873 habitants. It is expected that the said numbers will get the benefit from clean water distribution and sanitary services. The remaining Aldeias from the said 2 Sucos are not included in this project because the DED water supply network cover was based on the approved supply areas from the 2015 Masterplan and also the extent of the urban areas due to significant increment of population numbers.

4. PLANS AND TECHNICAL DESIGN OF THE PROJECT

4.1 Project Description

4.1.1 General Description

The aims of this project, in general, are to evaluate, assess and provide Detailed Engineering Designs for the following:

- 1) Rehabilitation of the Potable Water Distribution Network to consumers within the defined Water Zones;
- 2) Evaluate Existing and new sources for possible supply of the Water Distribution System;
- 3) Evaluate the condition and scale of the Sanitation situation in the Project Area and design wastewater treatment infrastructure for 4 Public toilets within the project's 15km diameter area;
- 4) Evaluate and Design a stand-alone Faecal Sludge Treatment Plant (FSTP) to receive the collection and treatment of septic tank sludge effluent from all households, buildings and schools within the 15 Km project range.

It is expected that by the end of the project, safe and reliable water supply will be provided to the municipal town (sucos and aldeias), and all households will have improved hygienic toilets as well as toilets available in public places. The improved water supply and sanitation facilities in the pilot schools will provide children with safe and reliable water supply and toilets operated by competent operators in each pilot school, providing a template in other schools to improve water supply and toilets.

Finally, the wastewater produced by each household, in the form of septic tank sludge, will be safely transported and treated at the proposed FSTP.

It is important to note that the DED (Detailed Engineering Design) project assignment is consisted of several phases prior delivering the final draft to the client and implementing the project sequentially. These phases are as followed:

- Inception phase
The team had finalized the final draft of the Inception Report on February 2020. The said report was aimed on providing all necessary information of the existing components of the project during a preliminary site visit.
- Water Resources Investigation and Reporting
The underground water investigation for Same, Los Palos and Viqueque were carried out last October 2020 until January 2021. The status of this phase is in pending as this phase is still missing on the Baucau study at the field.
- Survey and Mapping
Pending conclusion of field work.
- Analysis Options
In this phase, the team provided the summary of several alternatives for the proposed projects that are to be analysed under the scope of the Preliminary Design report.
- Preliminary Design
During the Preliminary Design stage, the team also went through the Initial Environmental Examination (IEE) and Environmental Management Plan (EMP) process under the ADB Safeguard Policy Statement (SPS) 2009 for environmental screening and for the purpose of ADB loan process. Throughout this phase, the team also carried out a Public Consultation in each of the 4 cities.
- Final draft of DED
The inputs from the Public Consultations were collected and then used for improving and finalizing the design based on the preliminary design. The proponent will expect the final DED to be done during the upcoming Simplified Environmental Impact Statement (SEIS) process.

4.1.2 Water Supply System

A. Existing Water Sources

The Lospalos aquifer is supported by a layer of a very weathered limestone, that behaves as a porous aquifer. The current Public Water Supply source comprehends of 2 actual springs and a lagoon associated to them in one system:

1. Puahopo spring, abstracted into the pumping station;
2. Papapa spring, an emergent spring at the edge of a small lake that directly supplies the Municipal Capital;
3. Intake Lagoon related to Papapa spring, abstracted into the pumping station.
4. Two Boreholes next to Papapa WTP but are not functioning anymore;
5. Existing DNSA borehole in Home, dug up in 2018, reserved for future usage when demands increase;

According to DNSA previous water quality testing, the Papapa source has episodes of biological contamination, mostly from upstream husbandry activities and existing larger wild fauna i.e. freshwater crocodiles. In terms of productivity, the Project team have done investigations in October 2020, aiming to get definite numbers of the production yield. The total yield of the Papapa System (Papapa and Puahopo springs and Papapa Intake) can go up to approx. 131 L/s. The system is also comprised with another 2 existing boreholes (photos not available) not far from the springs, although they are inoperable due to a failure of the pumping system. Overall, water that is produced from all the existing sources can come up to a total of 140 L/s if both wells are in operation.

Water quality testing has been carried out by the Government laboratory and other projects since 2000 through to the 2015 Masterplan and up to January 2020 (Please see results in Appendix 5). Conclusions on these results are:

- For the period between 2000 and 2003, there is bacteriological contamination (total coliforms and Escherichia coli presence) in the distribution system and Papapa intake. There are some samples with high turbidity in the distribution network, but in the Papapa intake the values of turbidity are below the limits. The average of the total hardness in the Papapa intake is above the limit (around 280 mg/l CaCO₃, reaching values around 440 mg/l CaCO₃) considering TGL-04, but within the range considering the Decree-law n.31/2020. The values of Manganese are above the guide limit considering the Decree-law

n.31/2020, and under the guide limit of TGL-04 (however, there are few samples with manganese measurement);

- Master plan (2014) tests shows that there is bacteriological contamination (total coliforms and Escherichia coli presence) in the distribution system and in the Papapa intake and Puahopo intake. The total hardness is above the limit (around 240 mg/l CaCO₃) considering TGL-04, but within the range considering the new legislation (Decree-law No. 31/2020). The turbidity is at the limit in Papapa intake (5 NTU);
- Regarding the water quality tests performed in 2019 and 2020, results confirmed the bacteriological contamination (total coliforms and Escherichia coli presence). The turbidity in the Papapa intake was also very high. There are only 2 values, namely the value from March at 173 NTU and for May at 17,8 NT
- The water temperature is normally high reaching temperatures of 32°C in some samples;
- The other parameters tested are according to the limits from Timor-Leste and of the WHO.

Figure 5 Lospalos Existing Water Sources



B. Distribution System.

Most of the transmission and distribution pipes are galvanized steel pipelines of varying age from the period of Indonesian administration, old Portuguese pipes particularly in the old town area, and newer pipes installed by DNSA or by rural projects such as i.e. under the National Program for Suco Development (PNDS) project. According to the 2015 Masterplan, there are also numerous duplicate mains identified. The distribution system requires rationalization and simplification as well as decommissioning and removal of all existing, inoperational pipes.


The only operating reservoir is a concrete tower constructed in an elevated ground adjacent to the Papapa spring and the WTP. There is also an adjacent ground level reservoir but it is unclear why it has never been use.

The distribution zone in Lospalos comprises of 3 different zones with manual rotation in terms of supplying to the customers on an intermittent basis. The service levels are very poor with low coverage, intermittent supply and low pressure. According to the test results and field observations, contamination of the water in the distribution occurs due to low pressure during periods when the supply is not operational. Depending on a single reservoir

for distribution is considered ineffective as Lospalos is relatively flat and the town has grown substantially. The pumped system, pump maintenance issues and daytime operation exacerbate the poor service levels.

Most of the connections are unmetered with less sharing of piped water supply. The community mostly depends on sharing alternative sources including dug wells and tube wells. The 2015 Masterplan states that only 33% are registered and supplied to the houses in the urban area with low quantity and poor service quality.

Figure 6 Example of Distribution areas and existing installation



C. Gaps in the Water Supply

Water Balance: Demand vs supply.

The water supplied to consumers throughout the years was proven to be insufficient due to higher demand and the infrastructures for water abstraction and delivery not being upgraded for a very long-time, hindering optimal operation and distribution, as well as the limited number of natural water sources available.

The Preliminary Design followed a dimensioning process that reviewed 2 different scenarios, namely Scenario A in adherence to 2016 Masterplan (equivalent to current distribution capacity and customers). However, the project should be able to provide reliable water sources sufficient for the expected expansion requirements for Lospalos Municipal Capital. Therefore, a Scenario B was chosen as the project horizon, as it includes expansion areas and user numbers for the next 20 years, up to 2040.

The project identified 7 potential borehole source areas (5 in the North System, in Home Suco and 2 in the South System) and to date have carried out bore exploration for 3 of them, with success in retrieving water. A hydrogeological study was conducted in October 2020 (in equivalent conditions to the end of the Dry Season) to determine the available yield of proposed boreholes and existing springs. Table 5 presents the water demands versus water flow October investigation results. Please note that Boreholes #7, #8 and #9 are not executed yet but given the production restrictions in the Papapa WTA, are accounted for as indispensable in the 2040 plan.

These preliminary results show that the Papapa system would have more than enough water flow to supply the current and future demands for Lospalos Municipal Capital, estimated at one and half times the 2040 water demand to cover all the proposed households within the supply zones.

However, as per SMASA-Lautem, the water treatment plant at Papapa is planned for a limited production of 20 lps, due to restrictions of physical expansion of the current WTP because the papapa area is sacred and does not accommodate for more infrastructure. Puahopo spring can produce up to 56 l/s of water according to pump test result on October 2020 (See Appendix 9), but given the previous issue stated, hence water will only be extracted 20 l/s. These preliminary results must also take into account the downstream social and ecological needs flow for the sources, including agriculture and other activities identified during the IEE characterisation. For more details on the water productivity of the proposed water sources please refer to Table 5 below.

The Ecological flow considered for Papapa source provides for the variability of rain and flow between dry and wet season and has been determined, at a minimum, of 30% average monthly flow for Wet Season and 10% for Dry Season. Given the papapa system would only account for 20 lps for water distribution (15% of the whole system flow), in this case the environmental flow would be at 47% in 2020, well above the suggested flow threshold (30%). However, the environmental flow provided in 2030 and 2040 will be lowered exactly to 30% to anticipate the alteration on the water spring capacity, in case one day SMASA is authorized for the WTP production expansion or increasing demand for agriculture irrigation in the future (social flow).

Additionally, boreholes were drilled and tested in several prospection points from 30th September to 10th October 2020, at the end of the Dry season. 2 pilot wells were indicated and successfully drilled in Aldeia Chenoloru, Suco Home, and an additional 2 boreholes were drilled, one in Aldeia Savarika, and another in Aldeia Kuluhun, in Suco Fuloro. Of all these boreholes only three have been pressure tested and confirmed production at the yield required (15 to 20 lps), while the remaining await pump testing. The project intends to use the boreholes as top-up and backup sources, especially during the dry season when the papapa source has less flow due to seasonal water variability, which supports the system to avoid any water usage and/or quantity impacts.

The tests have determined a sustainable yield (production rate) for all three boreholes, which, together with the proposed papapa system available water for consumption, sums to an amount of water for supply that surpasses the requirement (demand) up to the horizon year 2040.

Additionally, the maximum extraction rate defined for each executed boreholes is below the tested sustainable groundwater availability, and acts as a precaution measure from aquifer over extraction. For instance, the sustainable yield for borehole No. 2 is 15 l/s at 24 hours but the system will extract a flow of 10 l/s for of up to 10 hours at a time, which represents approximately 30% less water extracted than the sustainable yield, for an equivalent 24 hour period. This extraction method is planned for all boreholes, up to year 2040 (see Table 5).

Table 5 Water Demands & Deficits with Existing and Future Sources

LOS PALOS		Existing Assessment				2020				2030				2040			
Demands for water supply network				Lps	hours	Volume (m ³ /day)		Lps	hours	Volume (m ³ /day)		Lps	hours	Volume (m ³ /day)			
Water Supply Demand (Total area)				42.3	24.0	3655		62.7	24.0	5416		88.4	24.0	7638			
Water Supply Demand (South area)				14.2	24.0	1227		18.42	24.0	1591		23.64	24.0	2042			
Existing Spring Sources		Flow Measurement		Flow to be extracted				Flow to be extracted				Flow to be extracted					
		Lps	%	Lps	%	hours	Volume (m ³ /day)	Lps	%	hours	Volume (m ³ /day)	Lps	%	hours	Volume (m ³ /day)		
Papapa System		131.9	100%	131.9	100%			131.9	100%			131.9	100%				
	Water supply	72.0	55%	20.0	15%	24.0	1728	20.0	33%	24.0	1728	20.0	33%	24.0	1728		
	Social Demand (w/Agriculture)	49.4	37%	49.4	37%			72.3	37%			72.3	37%				
	Remaining Flow	10.5	8%	62.5	47%			39.6	30%			39.6	30%				
Potential Sources (Boreholes North)		Tested Maximum Yield		Planned Extraction			Planned Extraction			Planned Extraction							
		Lps		Lps	hours	Volume (m ³ /day)	Lps	hours	Volume (m ³ /day)	Lps	hours	Volume (m ³ /day)					
Borehole #2 - Home 1 (RN438)		15		10	10	368	10	11.9	428	10	23.3	837					
Borehole #3 - Home 2 (RN439)		20		10	10	368	10	11.9	428	10	23.3	837					
Borehole #8 - Home 3							10	11.9	428	10	23.3	837					
Borehole #7 - Home 4							10	11.9	428	10	23.3	837					
Borehole #6 - DNSA 2018		9		9	10	332	9	11.9	385	9	16.0	518					
TOTAL						700			2097			3867					
Potential Sources (Boreholes South)		Tested Maximum Yield		Planned Extraction			Planned Extraction			Planned Extraction							
		Lps		Lps	hours	Volume (m ³ /day)	Lps	hours	Volume (m ³ /day)	Lps	hours	Volume (m ³ /day)					
Borehole #5 - Sawarica (RN441)		21		10	17	613	10	22.1	796	15	18.9	1021					
Borehole #9				10	17	613	10	22.1	796	15	18.9	1021					
TOTAL						1227			1591			2042					
Total Production		Tested Maximum Yield		Planned Extraction			Planned Extraction			Planned Extraction							
		Lps		Lps		%	Lps		%	Lps		%					
Total Bore Production (North) ⁽¹⁾		74		19		26%	49		66%	49		66%					
Total Bore Production (South) ⁽²⁾		63		20		32%	20		32%	30		48%					
Total Bore Production (North & South)		137		39		28%	69		50%	79		58%					
Total Spring Production		131.9		20.0		15%	20.0		15%	20.0		15%					
Total Production Capacity (Bores + Springs)		268.9		59.0		22%	89.0		33%	99.0		37%					

⁽¹⁾ Assuming lowest sustainable yield on nearby bores (15 lps)

⁽²⁾ Assuming lowest sustainable yield on nearby bores (21 lps)

Therefore, if the remaining boreholes are to be augmented in the system, there is a promising provision of water for the system, as shown in Figure 7 below, particularly during dry season when water is at its lowest productivity.

Figure 7 - Water Resources Extraction versus Water Demand and Yearly Service Area Total Population





Figure 8 New Boreholes and pump testing





4.1.3 Sanitation System

Based on 2016 Masterplan, the National 2030 target for household sanitation is 80% urban sanitation coverage, defined for 2015, as in the Government Resolution No. 8/2012 - Sanitation policy. However, major deficiencies of current toilets in school are mostly open defecation practice, lack of cleanliness, insufficient water supply, poor construction standards and inadequate lighting, schools are not “User friendly” where none of the toilets cater for the special infrastructural requirement of children, physically handicapped persons and menstruating girls, and nevertheless inadequacy of funds for operation and maintenance. No schools have been conducting regular water quality sampling and testing on regular basis and none of the school’s chlorination system is done.

In addition, all the houses that do not practice open defecation are contributing with septage, through their own toilets or shared toilets. According to the Masterplan, only 19% households in Lospalos practice open defecation.

Lastly it is presumed that all the leaching pits provided in the households are functioning as septic tanks for all practical purposes. Hence all these sanitation facilities are producing digested sludge which needs to be removed once in two years.

4.2 Proposed Water Supply and Sanitation System

4.2.1 Water Supply System

A. Water Sources

As mentioned in Sub-chapter 4.1, water sources in Lospalos comprise of 2 actual springs and an intake lagoon, as well as new bore holes. The detailed investigations for the existing springs and lagoons were carried out in October 2020 by the water resource team. Moreover, the team also has done the underground water investigations for proposed boreholes in 5 different sites in total, however, only three sites meet the requirements. Thus, the results showed that the current yield capacity in total (existing origin (springs & lagoons) and proposed boreholes) is 84 Lps which is shy of the 2040 water demand requirement for Lospalos.

As the future boreholes are expected to surpass the 88 lps as soon as they come online, the table below shows the only scenario possible for Lospalos to guarantee supply and maintain sustainability up to 2040:

Table 6 - Water Sources Scenarios

Lospalos	Scenario 2040	Proposed Water Sources	Papapa Intake, Boreholes #2, #3, #6, #7 and #8 (in Suco Home at west of the Municipal Capital) and Boreholes #5 and #9 (in Suco Fuiloro)

The existing springs will be analysed for their current productivity and the other concurrent water uses. Regarding new boreholes, the scope of the current project will consider the construction of the infrastructure needed to assure the estimate consumption for the next 10 years. The image of proposed boreholes construction layout and working procedure are presented in Appendix 6 – D4 Preliminary Design Report.

B. Water Storage, Treatment and Conveyance

As the water investigations are already commenced, there is information that allows a reasoned analysis regarding the availability of water at the sources. Based on the information about the springs and boreholes reliable yields, it is possible to establish the final systems frame, however, the analysis made was focussed in possible layout of the systems (different Scenario), as shown in table below.

In **Scenario I**, the water supply would be assured by two water sources:

1. The old Indonesia borehole to be rehabilitated and a set of new boreholes nearby;
2. The borehole that exists at the west of the Municipal Capital (Suco Home) which was also built during the Indonesian administration will be rehabilitated.

Previously it was planned that if the results of hydrogeological investigations determined that those boreholes yield is not sufficient to meet the water demand, then it should be foreseen to reinforce with a third water source by rehabilitation of the two existing boreholes of the Papapa WTP, and if necessary, another reinforcement by building a new borehole 900 m from that area. If a fourth water source will be necessary, three more locations at south of the Municipal Capital were identified as possible potential areas to conduct bore tests. However, based on the result of the water investigation shows that even the Indonesian Borehole which is located in Suco Home Aldeia Tchenuloru does not meet the requirement giving zero availability but the other 3 boreholes mentioned in Section A are possible to be foreseen to reinforce other existing sources.

Hypothetically, it will be necessary to build another water treatment facility in the two existing boreholes at the actual Papapa WTP, with softening (Calgon dosing) and disinfection treatment lines and the treated water will be stored in the Papapa West Tank. A fourth water source is necessary, which is located in Suco Fuiluro Aldeia Sawarica (in the South Municipal Capital) to be explored, given the distance from the location to the other

treatment facilities is quite far, hence, it is considered to build another water treatment facility with the same treatment lines near the South Tank which will store the treated water.

Figure 9 Lospalos Water Sources Scenario I



Therefore, a **Scenario II** was chosen, where the 2040 water supply would be assured by the following water sources:

1. Papapa lagoon and Puahopo spring;
2. Boreholes #2, #3, #6, #7 and #8 (in Suco Home at west of the Municipal Capital);
3. Boreholes #9 and #5 (in Suco Fuiloro);

In this scenario, Lospalos water system will be supplied by Puahopo spring, in addition of using surface water in the Papapa area. The water from Puahopo spring will be collected and treated in the WTP for water hardness correction (Calgon addition), sedimentation and filtration steps, and chlorination.

The existing boreholes at west of the Municipal Capital will be rehabilitated and the extracted water will be pumped to a WTP near the Northwest Tank at 427 meters above mean sea level. The treatment facility will include treatment lines with addition of Calgon to water hardness correction and chlorination. If necessary, the system water sources will be reinforced with more boreholes near Papapa area, as first priority, and near the South Tank area, as a second priority.

Figure 10 Lospalos Water Sources Scenario II (North System)





Table 7 lists the proposed water tanks storage calculated according to the water demands projection for 2040. See also Appendix 6 for the Water tanks design.

Table 7 – Proposed Water Tanks Storage

Municipal Capital	Tank	MDP + Unaccounted water (m ³ /d)			Storage Needed (m ³)		New Storage Proposed (m ³)	
		Scenario A		Scenario B	2020-2030	2030-2040	2020-2030	2030-2040(*)
		2020	2030	2040				
Lospalos (Scenario 1)	North West Tank	958	1 367	2 538	740	1 375	700	700
	Papapa West Tank	1 091	1 669	2 813	904	1 524	1 000	500
	South Tank - Tower Tank	1 136	1 443	1 948	782	1 055	150	-
	South Tank - Ground Tank						800	300
	Total	3 185	4 479	7 299	2 426	3 954	2 650	1 500
Lospalos (Scenario 2)	North West Tank	1 215	1 871	3 258	1 014	1 765	1 000	800
	Papapa West Tank	834	1 165	2 093	631	1 134	700	400
	South Tank - Tower Tank	1 136	1 443	1 948	782	1 055	150	-
	South Tank - Ground Tank						800	300
	Total	3 185	4 479	7 299	2 426	3 954	2 650	1 500

(**) Reserve area for future increase capacity (considering possibility of expansion area)

Figure 11 Lospalos Water Sources Scenario II (South System)



C. Rehabilitation of the Transmission and Distribution Mains

The type of construction for transmission lines and distribution networks has to follow the design criteria, starting from the material selection, type designs of trench, and the operational system.

Material Selection: The following criteria regarding material selection is proposed:

Transmission Lines (HPDE and Ductile Iron):

- Transmission lines with nominal pressure below 16 bar and nominal diameters below 315 mm – use of HPDE;
- Transmission lines with nominal diameters equal or above 300 mm - use of ductile iron;

- All transmission lines with nominal pressure equal or above 16 bar (regardless of the diameter) – use of ductile iron.

Distribution Network (HPDE):

- Distribution network & house service connection –Use of HDPE
- Laying of Transmission Mains and Distribution Network


During the Preliminary Design, the project proposed various diameters of pipeline between 60 mm and 250 mm for the distribution network with total length of distribution network 53,487 m and transmission mains 13,428 m. Table below reflects the total populations per total length of the distribution pipelines in each supply zones.

It is assumed that pipes will be buried underground, laid along and within the road Right of Way (RoW) or outside the RoW for the purpose of replacing/rehabilitating existing pipes. Inside the Municipal Capital area, transmission mains will be laid below the distribution network level, as shown in Figure 12. In order to allow the construction of the service connections on each side of the roads without interference with transmission mains and, also, to become more difficult to do illegal connections.

Table 8 - Total Population versus Distribution Network Length versus Supply Zones – Lospalos City


Tank	Zone	Population			Proposed Distribution Network km
		2020	2030	2040	
North West Tank	1	5358	8251	11935	14,4
Papapa West Tank	2	7336	11711	17279	22,3
South Tank	3	6403	8305	10659	16,8

Figure 12 - Laying of Transmission and Distribution Lines along the Road. Typical Cross Sections



Typical trench details are presented in the following figure:

Figure 13 - Typical Double Trench



Land that is excavated for trenching activity will all be reutilized in order to avoid extracting more materials from other resources and so that the activity will be more efficient in terms of its cost. Table below is the volume of materials to be reused once the pipes are replaced.

Table 9 – Materials for Reutilizing

	Unit	Same
Excavation	m ³	64.435
Gravel (Bedding, Embedment and Top Embedment)	m ³	11.152
Pipe	m ³	589
Backfill	m ³	52.694
Landfill	m ³	11.741

Transmission Mains Service

The distribution networks will be connected from water tanks. Even in situations where this option implies new network extension, the resulting benefits are significant since the operation of the systems will be facilitated and, therefore the transmission lines system will not be vulnerable to any ruptures in the distribution network.

Gravity Transmission Mains Operation

To ensure a balanced water supply to the water tanks, when a transmission main supplies more than one water tank, the connection to the tanks will be equipped with automatic control valves, which allows the flow control and will avoid the occurrence of random feeds depending on the value on piezometric head value in the pipe connection on each reservoir.

Distribution Network Pressure Zones

In each distribution zone, the pressure in the network can vary between a minimum of 10 m and a maximum of 60 m. When a water tank supplies a distribution network that has more than one pressure zone, the pressure zones will be set by Break Pressure Tanks (BPTs) or by Pressure Reducing Valves (PRVs). Advantages of BPTs vs PRVs:

- Less maintenance break pressure tanks have a higher turn down ratio than pressure reducing valves.
- Even if the break pressure tank fails, the downstream pipeline will never be exposed to excessive pressures.
- A break pressure tank has fewer components than a conventional pressure reducing installation.
- PRVs will leak and need maintenance at some stage. PRVs requires more skills.

Disadvantages:

- They are expensive and bulky.
- The level and flow control mechanisms are vulnerable to tampering and damages.
- Pressure is reduced all the way down to atmospheric pressure. This makes supplying areas immediately downstream at sufficient pressure difficult, which will imply the duplication of primary distribution mains since it will be necessary to install the BPT at a level that guarantees the minimum pressure value in the downstream distribution network.

4.2.2 Sanitation System

The proposed sanitation treatment sector is composed of 4 pilot test sites for public toilets (with septic tank and effluent soak pit system) and the construction of the Faecal Sludge Treatment Plant (FSTP) to receive the septage from these pilots, as well as all buildings and households located within 15 km of the Lautem Municipal capital. According to the Masterplan, it is inferred that National 2030 target for household sanitation is 100% access to hygienic toilets and improved hygiene behaviour as in consistent with the Government Resolution No. 8/2912 regarding to the Sanitation policy. The public toilets' pilot test locations will be chosen per the location and conditions of current sanitation infrastructure, users, as well as and specifically regarding schools, on the number of students, teachers and other school personnel, as well as the state of the toilet facilities

A. Public Toilets

The proposed specifications for the Public Toilets are based on the information below:

<p>1. <u>Male Toilets:</u></p> <ul style="list-style-type: none"> • Adult: 3 urinal stalls • Adult & Children: 3 latrines (each with 1.2 m²[approx.]); • Children: 1 small urinal 	<p>2. <u>Female Toilets:</u></p> <ul style="list-style-type: none"> • Adults & Children: 5 latrines (each with 1.2 m²[approx.]); • Facilities for menstruating girls.
<p>3. <u>Physically disabled Toilets:</u></p> <ul style="list-style-type: none"> • Adults & Children: A common latrine for physically disabled person shall be provided at the centre of men's and women's section. Area of latrine with a ramp etc. for a handicapped person=3.70 m² [approx.] 	

The treatment of the public toilet septage is being proposed in a two-step process, as described below:

1. Primary Treatment - Septic Tank: shall have minimum width of 750 mm, minimum depth of one metre below water level and a minimum liquid capacity of 1 000 litres. Inlet: The pipe shall be fixed inside the tank, with top limb rising above scum level and the bottom limb extending about 300 mm below the top water level. Outlet – It would be fixed like inlet but shall be 50 mm below the invert of the inlet pipe.
2. Secondary Treatment - Soak Pit or Dispersion trench or subsurface absorption system

These infrastructures will be carefully selected and designed according to the available areas, local conditions and receiving environment, based on the number of expected users and adapted to the specific local characteristics where the public toilets will be implemented.

Figure 14 - Septic tank for up to 50 persons capacity




Figure 15 - Septic tank for up to 200 persons capacity





Figure 16 - Public Toilet layout



The locations for future public toilets have been designated considering the magnitude of the benefits towards the community. Thus, the pilots are selected in places that have moderate to high mobility in which the beneficiaries are often found e.g. markets, terminals and other public spaces.

Figure 17 - Public Toilets Proposed Location Lospalos



Figure 18 - Aerial Image of Public Toilets Proposed Locations

Public Toilets	Remarks
#1	   <p>Rehabilitation of existing toilet facilities, Traditional Market, Suco Fuiloro, Aldeia Bee Moris</p>
#2	  <p>Lautem Cultural Centre, Suco Fuiloro, Aldeia Central</p>



B. Faecal Sludge Treatment.

The FSTP was designed considering the future users of the sanitation system up to 2040, namely public buildings, households and schools. The FSTP will be supplied with septage collected by vacuum trucks from domestic and non-domestic sources and the estimated daily volume collected in Lospalos can be viewed in Table 10.

Table 10 - Total Septage Volume to be collected daily projections

Lospalos	2020	2030	2040
No. of Households-[6.16 avg HH size] -DED	3,100	4,589	6,473
Septic tank coverage assumption	62%	74.7%	90%
No. of septic tanks	1,922	3,428	5,826
Total sludge produced (m ³ /year)	475	840	1,424
Total sludge produced (m ³ /d)	1.3	2.3	3.9

To define the FSTP ideal/possible location, the following requirements were taken into account:

- Proposed location of FSTP shall be available within 15 km distance
- Easy access
- The land should be relatively flat to facilitate the construction of lagoons without excessive earthworks
- The lagoons will be constructed using earthen embankments. Site is assumed to be on soil.

The proposed FSTP will be placed in Suco Parapata (See Figure 21), since it has all the requirements needed comparing to other alternatives provided and the surrounding area is a “brownfield project” adjacent to a pre-existing Municipal Capital Solid Waste Dumpsite. The proposed area has been acknowledged and approved by the local Municipal Administration as referred in Appendix 8. This also means that the area is assured for its availability and that the project proponent is permitted to use the land for future construction, without any hindrance from other parties or vice versa.

Figure 19 FSTP Lospalos installation and segments




Figure 20 Photographs of Proposed FSTP Site and surroundings

Proposed FSTP site (North View)



Surrounding of Proposed FSTP site (North East view)



Proposed FSTP site (East view) Farmland



Lospalos SW Dumpsite (South of proposed FSTP site)



Proposed FSTP Site (South View) Surroundings



Proposed FSTP site (South) Farmland



Figure 2I Proposed FSTP Site (Parapata) location




Figure 22 - Parapata FSTP and Characteristic of the Area




Table II FSTP Possible Locations and description

Municipality	FSTP	Coordinates	Actual Area Available (m2)	Distance from (m)		Site elevation above MSL (m)	Description	Comments
				Habitation	Water Body			
Lautem	1	Lat: -8.513230° Long: 127.024619°	8000	190	140	370	Location characteristics: <ul style="list-style-type: none"> - Flat area, declining is the dumpsite area - distance from the highway about 150 meters, - 190 meters from community settlements and - 140 meters from the river. - 1.5Km from the city - Next to existing Waste dumpsite 	Recommended
	2	Lat -8.483777° Long - 126.941617°	15000	420	3000	447	Location characteristics: <ul style="list-style-type: none"> - located on grassland, pristine i.e. Greenfield - flat area, - distance from the residential road about 1700 meters - 420 meters from community settlements - 3000 meters from the river. - High up from the watershed. 	Not recommended

5. FEASIBILITY STUDY OF THE PROJECT

This Project Document's primary source of information for this study were (but not limited to):

- ADB Master Plan for the Second (2nd) District Capitals Water Supply Project (46160-001) TA-8064 TIM in the four Districts Baucau, Lospalos, Viqueque and Same, carried out in 2016, by the consultancy firm Aurecon;
- Baucau, Lospalos, Viqueque and Same Initial Environment Examination (IEE) and Environmental Management Plan (EMP), carried out in 2016, under Grant no. 8064-TIM from the Asian Development Bank (ADB);
- Ongoing 4 MCWSS (The Four Municipal Capitals Water Supply & Sanitation Project) IEE for Lospalos Municipality.

A preliminary, non-in-depth feasibility study has been conducted regarding hydrogeological, topography and Water study (See Table 12). The aim of the study is to understand the Karst System in order to define water sources, water flow capacity, geospatialize the project area and to ensure the quality of the water is suitable for human consumption. Some of the technical studies are still in pending and the results are rudimentary particular on the water and geological sector.

Table 12 – Summary and Timetable of Feasibility Studies Conducted

Study	Date	Description Activities
1. Geological Study	TBC	Identify the local geology and geomorphology for Lospalos Municipal as well as its geotechnical implications for the works engineering design. Given that site investigation works haven't yet started, very little information is available, essentially concerning bibliographical data coming from diverse sources, namely Instituto do Petróleo e Geologia, Private investigation works and scientific papers.
2. Hydrogeological Study	- 30th September – 15th October 2020 (Pumping Tests to Boreholes) - 6th October 2020 (Pumping Tests to the springs) [See Appendix 9]	Five boreholes were built. Pumping tests were conducted by the research team to the existing springs and the boreholes sites, in order to estimate the hydraulic properties of aquifers, evaluate well performance and identify aquifer boundaries. The test activity includes a field experiment in which a well is pumped at a controlled rate and water-level response is measured in one or more surrounding observation wells and optionally in the pumped well (control well) itself.
3. Topography Survey	- 11 October 2020	From May to August 2020, the project area was surveyed through Classic topographical surveys to gather information on the topographical development of project sites with special emphasis on the proposed locations of water and sanitation infrastructure (reservoirs, water and wastewater treatment works, pumping stations, etc). Additionally, topographical surveys have been done along roads to allow the deployment of pipe profiles in future stages of the Detailed Engineering design development. Also, updated aerial imagery was acquired via drone survey to allow for the identification of the location of households and dwellings as possible future household connections.
4. Water quality Testing	- 30th October 2014 - 14th March 2019 - 23rd May 2019	- Water quality testing conducted by Aurecon under the 2015 IEE exercise (See Appendix 5); - Two recent water quality testing from the National Directorate for Sanitation and Water (now SMASA), to register any occurrence of contamination to water for human consumption. Types of considered parameters that were analysed are physical, chemical and Bacteriological test under the WHO Standards. - Water quality testing planned for all water sources.
5. Preliminary Design for the Detailed Engineering Design of Timor-Leste Four Municipal Capitals Water Supply & Sanitation Project – Lospalos Municipal Capital	March to present, 2020	Definition of final solutions will be detailed in the Detail Engineering Design Final Report. However, a preliminary study has been prepared by BTL in the form of the D4 preliminary design report, defining the locations, layouts and main characteristics of the proposed systems and infrastructures, including the water supply systems and the faecal sludge treatments plants, and review of the demands estimation and a preliminary cost estimate of all infrastructures including

Study	Date	Description Activities
6. Initial Environmental Examination (IEE) under ADB SPS 2009 (see appendix 7).	March to present, 2020	different scenarios and options (see appendix 6). The environmental assessment was conducted for the Lospalos Municipal Capital water supply and sanitation project, based on (i) the preliminary engineering design, and (ii) most likely environmentally sensitive components. The IEE report itself describes this process, where it (i) provides project information and environmental requirements; (ii) provides baseline physical, ecological, cultural and socioeconomic information surrounding the project's area; (iii) identifies and assesses potential environmental impacts from the project's implementation; (iv) includes recommendations for measures to avoid, mitigate, and compensate adverse impacts; (v) informs on stakeholder consultations and participation activities during project preparation; (vi) provides an environmental management plan; and (vii) presents a grievance redress mechanism for the project.
7. Social Survey	June 2021 to present	This study is consisted of two activities. Firstly, to calculate the number of consumers that are currently and will be served with water working system in this project by 2040. The team has been referencing from the 2015 Census and 2015 Masterplan for Project analysis. Secondly, a field survey was carried out to the affected community within the project area by registering and preparing lists of landlords and farmers that will be affected by this project. The social team is also encouraging women as part of Action Plan during the implementation plan, for them to take parts in the working field, as a women's group/association aiming to support I sustainable water usages.. The upcoming activity during pre-construction phase is to undergo a survey in the affected area on the third week of February 2021. This program is aimed on registering any reclamations from the community in regards to the affected commodity, up to the end of the construction phase. Grievance redress form will be provided by the team.

6. LAND AND WATER USE

6.1 Land Use

Given there are still no established Land Use Plans for the city of Lospalos, the current land use description is based on the technical team site visits to the Project Area and the definition of most of the Suco Fuloro as "Urban Area" (DGE, 2018). From these sources, it was possible to assess that, in general, Lautem Municipality consists of tropical rainforest in where in the Northern areas and around Lake Iralalero, extensive agriculturally suitable soils developed from weathering of calcareous rocks have developed in Lautem Municipality. These are characterised as dark, moderately deep, well-drained and reasonable fertility.

The predominant form of livelihood for households in the project area and Lospalos city (Lospalos Administrative Post) is a mix of urban services and agriculture practices coincident with regular flood areas (see Figure XX) while beyond the urban fringes it is assumed the predominant land use activities are near subsistence swidden agriculture for the production of primary staple crops such as i.e. maize, cassava, etc for farmer households, whilst a larger proportion of livestock activities i.e. buffalo, spread out towards the area from the outskirts of Lospalos town to the Iralalero plain and lake area.

Within the Municipality central area, especially along Lospalos on the plateau and lower ranges, these soils support mixed lowland forest, moist lowland forest, dry lowland forest and grassland and a wide range of agricultural activities from animal husbandry (cattle and buffalo) to cropping (corn, maize, rice and others), up to the urban boundaries of the Municipal Capital of Lospalos, in the Fuloro Suco. In the higher areas towards the Paitchau range the soils have formed on raised limestone, which limits agricultural use, as well as remaining under forest cover.

As a part of the project, it is found that the supply zone for 2 sucos within the 15 km diameter project limit for the Lautem Municipality WATSAN project (see Figure 2).

Suco Fuiloro borders the protected area (The Nino Conis Santana National Park) exactly at its western border, while Suco Maupitine, Bauro and Lore present a small overlap of their administrative border into the protected area limit. However, the project components are planned to be implemented within Sucos Fuiloro and Home, within the urbanised area of Lospalos and therefore, the project components are not expected to come within any proximity of the Protected Area (see Figure 23).

The proposed project also includes Faecal Sludge Treatment (FSTP) Plan which will use the specific land that has been identified (Parapata – Name of the location) and while in the field the team was informed locally that it has been local government land for decades. As previously mentioned in Sub-chapter 4.1.3 and reflected in Appendix 8, Lautem Municipality has presented a "No Objection" letter referring that the area will not be used in the future by the local government for any sort of development or agricultural activity, and therefore the Project Proponent has been given clearance to construct the FSTP in that location when the implementation phase comes into effect.

6.2 Water use

The majority of the Lautem population is mostly composed of farmers, consisting of 41% of the active population (15 to 64 years old) municipality population and water has been an important source for securing their activity so as to have a sustainable income. Farmers are heavily dependent on both irrigation and rainfall.


At present Lautem SMASA provides around 3,758.4 cubic meters of water per day to its population through an aggregate transmission and distribution network length of around 44 km. The water supply has not been able to meet the growing demand for water from the consumers because the water springs are not producing sufficient flow and the capacity of water storages is very small.

There are numerous groups and communities with existing pipelines but the water cannot be supplied due to the poor condition of the pipelines. The existing distribution pipelines are not quite integrated due to various old pipes built during the Indonesian occupancy combined with several NGO projects, leading to constant leakages. Issues of intermittent water supply and high incidence of illegal connections are part of the main issues why the water system is currently unable to serve the Lospalos population.

During multiple field studies for preliminary design through interviews and on-site observation of several designated local schools' sanitation facility, the project team concluded that most schools have similar concerns e.g. no clean water access, inoperable toilets and faucets, lack of hygiene and maintenance.

The 4 MCWSSP is expected to benefit a base year population of Lospalos Municipal Capital of 19,096 (2020) and design year population of 39,873 (2040) by providing a reliable and adequate supply of safe and potable water.

Figure 23 Land Use in Project Area



7. ENVIRONMENTAL IMPACTS

The 4 MCWSSP is expected to have numerous beneficial and negative impacts towards the environment and social aspects due to various project activities. The potential impacts and mitigation measures assessment for Lautem Municipality are predicted based on each of the project components, namely: 1) water sourcing; 2) treatment and storage; 3) distribution networks; and 4) sanitation sector (public toilets and FSTP), according to the project cycle (Design phase, Construction phase, Operational and Maintenance phase, and Decommissioning phase), as well as the assessment conducted in the 2015 Master plan and the recent IEE exercise.

Most of the potential environmental impacts will occur in the *Construction phase*, particularly during the civil works, but it is expected to have short term duration and mitigated. The majority of previously identified environmental impacts (ADB, 2015) have not been concluded as significant and the proposed construction management safeguards and operational regimes defined therein provide a sound basis to address the range of potential environmental impacts identified, actioned through the Project EMP and checked in the environmental monitoring program. It is essential to acknowledge the geological condition in Lospalos Municipal Capital i.e., flood prone area and some sensitive areas within the 15 km of the project zone.

The evaluation of potential impacts with its nature, time scale and significance are analysed and estimated in Table 13, including the estimation of the residual impacts after application of mitigation measures.

7.1 Biophysical impacts

Biophysical impacts are associated with water quality, air quality and noise, climate, topography, flora and fauna as mentioned below. The related impacts are not expected to occur outside the cross-border given that the impacts are localized in nature and temporary in extent.

7.1.1 Water Quality

Construction works for distribution pipe replacement, water storage rehabilitation and FSTP installation will likely generate silt run offs to nearby surface water receptors i.e. streams and drainage system, if temporary drainage systems are not applied. However, this activity won't have adverse impacts to the water ecosystems, as the duration is considered temporary.

During operation, the upstream spring areas i.e. Papapa system, have human activity mostly surrounded by agricultural activities, which can indirectly lead to bacteriological contamination in the springs downstream. Likewise, slash and burn activity is a low-cost mechanism used by the local community to fulfil their agriculture needs and happens very frequently before the wet season, which has an immense impact to the springs' water quality and available yield.

To preserve the sustainability of the proposed water collection and distribution system, the project can consider designing and implementing an Upstream Watershed Protection Programs, with restriction to water quality impacting activities i.e. animal husbandry, slash and burn, etc, or an Improvement Program for all existing and future dwelling sanitary infrastructure i.e. SMASA septic tank design template, to implement in the community surrounding the water source. Construction works of pipe replacement due to trenching, water storage remodelling and FSTP installation would likely generate silt run offs and therefore enter the nearby surface water i.e. river and drainage system that ends in the water body, if temporary drainage system is not applied. However, the said activity won't give adverse impacts to the water ecosystem and the duration is considered temporary in nature as long as the flow is not unceasing.

To preserve the sustainability of the proposed water collection and distribution system, the project can consider designing and implementing an Upstream Watershed Protection Programs, with restriction to water quality impacting activities i.e. animal husbandry, slash and burn, etc, or an Improvement Program for all existing and future dwelling sanitary infrastructure i.e. SMASA septic tank design template, to implement in the community surrounding the water source.

Table 13 - Summary of Potential Environmental and Social Impacts of the Project

Activities	Types of Components	Potential Impacts	Nature	Incidence	Time-Scale	Significance	Residual Impact (After Mitigation Measures)
Pre-Construction Phase							
Use water sources (springs and boreholes)	Water quantity	Insufficient debit due to environment and social flow (illegal connection, agriculture necessity, etc)	Negative	Direct	Medium-term	High	Moderate
	Socioeconomic	Water conflicts between communities	Negative	Direct	Short-term	High	Moderate
	Cultural	Social and ecological disruption due to project activities intruding the tara bandu and sacred area components e.g. hydrogeological study and water investigation i.e. bore well testing	Negative	Direct	Short-term	Moderate	Low
Protection of the water source for distribution purposes	Water quality & quantity	Inadequate protection of intake works or wells, leading to pollution of water supply & drying up of the SMASA boreholes & private wells due to over extraction	Negative	Direct	Medium-term	High	Low
Basecamp/place for storing project maintenance equipment	Land use & spoil management	Consume large space in the selected site where construction and operational activity will be carried out, spoil generation, cause damages to the equipment which will result in accidents towards the workforces and community, and also possibility on soil and water contamination if the referred equipment contains chemical and hazardous substances	Negative	Direct	Short-term	Moderate	Low
Site clearances and consultations with related entities	Land use, socio-economic & ecology	Social disruptions, vegetation loss, ecological imbalance, and inadequate management plan	Negative	Direct	Medium-term	Moderate	Moderate
Backfilling on the excavated land for pipe replacement	Soil materials, Safety, traffic and spoil management	Silt runoffs during wet season causing clogging on the drainage system, safety risk to the workers, dust and noise disruption, and traffic along the construction area	Negative	Direct	Short-term	Moderate	Low
New installation of disinfectant system in the proposed or selected storage	Occupational health & safety	Health hazard arising from inadequate design and/or handling of facilities for receiving, storing and handling of chlorine and other hazardous chemicals	Negative	Direct	Medium-term	High	Low
Remodelling / rehabilitation of existing water tanks	Water quantity	Poor infrastructure and insufficient capacity of water storages can lead to impendence of water delivery	Negative	Direct	Medium-term	High	Low
Baseline study on the technical, environmental and social components	Water supply and sanitation design, air and noise quality, socio-economic	Impediment to the project activities due to inadequate designs and magnitude of impacts that are unexpected and not anticipated	Negative	Direct	Short-term	High	Low
Location for proposed FSTP	Soil, odour, traffic management & land use	Inadequate designation of buffer zone around FSTP	Negative	Indirect	Medium-term	Moderate	Low

Activities	Types of Components	Potential Impacts	Nature	Incidence	Time-Scale	Significance	Residual Impact (After Mitigation Measures)
	Soil & land use	Land use change for temporary sites used for contractor's camp site	Negative	Direct	Medium-term	Moderate	Low
Wastewater disposal from FSTP	Wastewater, soil & water quality	Inadequate design causing increased runoff volume of untreated sullage and contamination to soil and water sources	Negative	Direct	Medium-term	High	Low
Construction Phase							
Activities related to Infrastructure Construction	Noise	Increase in noise level from construction works	Negative	Direct	Short-term	High	Moderate
	Air quality	Deterioration in air quality (dust)	Negative	Direct	Short-term	High	Moderate
Construction Activities – Macro Benefits	Socioeconomic	Job creation to local community and enhance workers' skills	Positive	Direct	Medium-term	High	Moderate
Construction Work Front: All Infrastructure	Socio-cultural	Impairment to the cultural heritage properties due to pipe replacement	Negative	Direct	Short-term	High	High
	Vehicular access and movement of construction vehicles	Traffic hindrance and amenity value to urban dwellers	Negative	Direct	Short-term	Low	Low
	Soil & land use	Vegetation loss	Negative	Direct	Medium-term	Moderate	Low
	Soil & land use	Silt runoffs can cause traffic accident & increasing volume of soil wastes (spoils, spare materials, etc) can lead to possible soil contamination, attract pests and serve as vectors for disease carrying insects, and negative visual impact	Negative	Direct	Short-term	Moderate	Low
	Occupational health & safety	Accidents and even mortality for worst scenario towards the workforces and community	Negative	Direct	Short-term	High	Moderate
Operational & Maintenance Phase							
Protection of the water source quality	Water quality	Expansion of housing in the upstream with inadequate sanitation facility leading to water deterioration in the sources	Negative	Indirect	Long-term	High	Low
Operation of FSTP	Wastewater	Inadequate management of the treated sludge from the FSTP causing odour and excessive plot space consumption	Negative	Direct	Short-term	Moderate	Low
Drinking water supply system	Water quantity	Achieve consumer water demands for consumption	Positive	Direct	Long-term	High	High
Mishandling of chlorine	Water quality	Water quality deterioration due to inadequate chlorination and irregular water quality testing	Negative	Direct	Short-term	High	Low
	Occupational health & safety	Health hazards due to chlorine exposure	Negative	Direct	Short-term	High	Low
Sound Operation of FSTP and Clean Water Distribution System	Public Health	Improvement of community's health and reduce mortality due to clean water and sanitation access	Positive	Direct	Long-term	High	High

7.1.2 Air quality and noise

While the current air quality in the project area is difficult to ascertain given the unavailability of historical data for previous environment related projects i.e. Category A and B in the project area, the site visits have demonstrated that, under normal urban conditions, the air and noise quality is that of a semi-urban, medium-to-low density city and thus the nature and characteristics of the project leads the proponent to estimate that the impacts from these components are textbook construction activity, to be focussed upon mainly during the construction phase, regarding the implementation of applicable mitigation measures.

The construction activities will likely produce negative impacts towards the environment and the local community but these are considered temporary, such as air pollution that causes disturbance to the nearby dwellings and commercial buildings, construction waste (solid and liquid), traffic, flood due to lack of outlet system and slope instability. Earthwork construction, stockpiling of natural aggregates, transport loading and unloading or heavy vehicles mobilizing, tend to generate dust and its dispersion, which can affect the respiratory system and eye visioning. These types of activities can also have a potential impact on noise emission, which will be significant in areas of noise-sensitive institutions or buildings such as health care and educational facilities. The health and safety risk of the workers and local communities, declining of the water quality, soil erosion, etc. are also considered as main impacts. Besides Health & Safety & Environment (HSE) measures in the construction Right of Way and/or area, such as proper traffic or road signage and warning signs or disseminating HSE information to the community, other measures such as limiting noisy works to daytime hours and reducing the speed limit in the work site will minimize the risk of occurrence of these impacts.

7.1.3 Climate

It is not foreseen that, due to its nature, the project components will contribute to Climate change. However, on the contrary, the project may suffer from climate change related impacts and will require adaptation.

Climate Change Towards Water Supply System

Annual values of rainfall are quite dispersive in the project area. This fact combined to the poor resilience of the aquifer increases uncertainty regarding the water availability for the whole project horizon and will require realistic monitoring to foresee any problems faced by the project in this regard. The impact may be stronger in the sources located in high transmissive geological formations with low storage capacity, i.e. systems with poor resilience and thus impact on the water availability in the surface and ground sources.

The topography of Lospalos is quite flat with infrequent flooding occurrence and landslide risk free. However, the future infrastructures are designed with climate change resilient materials and methods, in such a way to prevent any climate-related damages. Water level monitoring regarding water flow will be carried out, as well as review of water quantities to correlate with seasonal meteorological variations and estimate source productivity. Given that the project area is predominantly drought prone, there will be a requirement to look into a more temperature resistant piping infrastructure and fill-in materials i.e. pipe trenching, in order to guarantee the quality integrity of the distributed water quality. Implanting pipelines under the ground will not influence the effectiveness of chlorine concentration and will preserve the quality of the pipes from climate change risk (floods, landslides, timber or other men-made infrastructures collapsing due to strong wind induced).

Climate Change Towards Sanitation

Another example of this would be the planning of the operation of the faecal sludge treatment facility which will take the weather into account when estimating the reasonable maximum capacity with regards to the number of cycles per year for emptying the sludge/liquid separation bed. The emptying should then be completed by the end of the two seasons; the cold period (typical July to October) and the hotter period.

FSTP design is calculated to the consideration of rainwater volume from infrequent rainfall events since excessive rainwater volume would cause overflow of the runoff and allow untreated wastewater entering the ground.

7.1.4 Topography

The topography of the project site is quite flat and landslide risk free and restricted to the urban area so location and routing is not considered to be a substantial problem.

Regarding the FSTP (faecal Sludge Treatment Plant), the best potential location for the Los Palos FSTP (faecal Sludge Treatment Plant) (Parapata site, on the side of the existing Solid Waste Dumpsite), is deprived of hazardous conditions in the immediate surrounding area and is outside the flood plain risk area.

The access road from the public road to the treatment plant site should be paved, without steep gradients. It should preferably have sufficient width to allow two tankers to pass. Where this is not possible, frequent passing places should be provided.

7.1.5 Flora and Fauna

During the implementation for the rehabilitation project, attention must be given to protect and minimize negative impacts on environmental sensitive areas and ecosystems, or the natural environment. Overall, the project area is in urban area and the trenches and trenchless works will not have direct impacts since the work will be done within the ground adjacent to the road (ROW) or confined to the planned area of construction. Nevertheless, the project only has 1 location that is deemed sensitive and should other areas be encountered during the construction activities, the contractors must ensure to establish a Sensitive Areas Management Plan to make sure no impacts occur in this regard, namely vegetation and trees removal are avoided and no fauna is destroyed.

However, if some of the construction works must forcefully remove roadside trees under the supervision of the NDPA and SMASA, the contractor will be required to compensate with trees replanting and re-vegetation. It is also important to limit noisy activities within these areas, in order to stabilize the fauna's mobility, and restrict permanent campsite location, clearing, parking, and movement of heavy vehicles and equipment stockpiling.

7.1.6 Socio-Cultural Impacts

It is important to understand that almost all springs, new and currently in use i.e. Papapa/Paupopo Spring and Stream area, are and have always been involved in and have a spiritual importance to the community, under cultural/animistic protection.

Therefore, it is important to involve the lia na'in i.e. cultural leader, and communities to lead in the preparation of cultural ceremony preparation i.e. "opening" and Tara Bandu for authorization to i.e. yearly ceremonies at Papapa/Paupopo springs or while conducting investigations for existing and proposed water sources, their use, continuance of use and/or cultural/natural protection of the source water resource, to avoid conflicts and distribution interruptions.

7.1.7 Health and Economic Impacts

The water supply system repair and improvement in the Municipality of Lautem will alleviate the district's populace from their present economic condition where people will be opened to economic activities with an influx of investors. The whole district is expected to get 24/7 access to clean and potable water; therefore, health condition, sanitation and hygiene practices of the people will improve. Given the condition that the Lospalos National Hospital will be supplied with clean water, it will also benefit on reducing the number of mortalities in the medium to long term.

This project will directly generate positive employment opportunities (either skilled or non-skilled work) for the local people. Their earnings will consequently affect the local economy given the employment process will prioritize local people, reducing the need for in-migration.

On the other hand, the local economy will suffer major positive impacts from the network improvement works such as increase in business for shops and other economic activities. For Lospalos, although the network itself is located along the roadways, the people and commercial activities will unlikely be disturbed as the work will be carried out on individual short lengths of the network, thus the period of construction in each section area will not last long.

Nevertheless, there can be economic impacts if roads have to be closed for short periods and customers are unable to gain access to shops, or if trenches are constructed near the sides of roads, and customers are impeded to access the shops, resulting in loss of income which is expected to be short-lived.

7.1.8 Socio-Cultural and Heritage Buildings

Lautem society follows a variation albeit still in line with the general indications of those practiced in Timor-Leste, where the sacred or *Lulik* plays a central role in their contemporary social relationships and community, especially in what regards agricultural management and conservation of resources and *lulik* areas appear in more disperse but nevertheless important symbols such as trees or water sources.

During the site visit, the team identified and received information from the Chief of Cultural Center of Lautem related to historical and other cultural sites, which lie nearby the distribution pipelines. These traditional regulations and customs in Timor-Leste also contribute to conserving the natural resources such as forests and crops, a communal protection system known as *Tara bandu*.

There are several types of symbolic actions used for this practice. In agriculture, objects may be hung near or a piece of rattan tied around the trunk of specific trees or next to a garden to indicate custodianship of the resource. It is also widely believed that people who steal the goods subject to *Tara bandu* may suffer from an accident, misfortune or illness, while the *Tara Bandu* itself also provides for mediation of land disputes.


Table 14 - Identified Cultural, Historical & Touristic Sites in Lospalos

No.	Name of Site	Type	Coordinates
1.	Uma Adat Kiik Monument	Socio-cultural, heritage	8°31'17.43" S / 126°59'42.18" E
2.	SD2 School	Heritage	8°31'21.66" S / 126°59'41.41" E
3.	Edifice of Ministry of Education	Heritage	8°31'28.75" S / 126°59'40.77" E
4.	Sao Paulo Church	Socio-cultural	8°31'20.21" S / 126°59'47.19" E
5.	National Hospital	Heritage	8°31'20.62" S / 126°59'50.42" E
6.	Evangelic Church	Socio-cultural	8°31'20.97" S / 126°59'31.63" E
7.	Centro Cultural & Uma Adat	Heritage	8°31'18.82" S / 126°59'55.83" E
8.	EDTL edifice	Heritage	8°31'27.61" S / 126°59'42.54" E
9.	Cemetery	Socio-cultural	8°30'55.64" S / 126°59'15.48" E
10.	SD1 School	Heritage	8°31'21.07" S / 126°59'43.08" E
11.	Mosque	Socio-cultural	8°31'25.04" S / 126°59'42.96" E
12.	Emanuel Church & Clinic	Socio-cultural	8°31'28.78" S / 126°59'50.76" E
13.	Lospalos Community Radio	Heritage	8°31'27.76" S / 126°59'40.83" E
14.	Small Monument	Heritage	8°31'21.32" S / 126°59'34.36" E
15.	Cemetery 2	Socio-cultural	8°31'46.18" S / 126°59'54.09" E
16.	UNTL	Heritage	8°31'59.11" S / 126°59'51.60" E
17.	Police PNTL Headquarter Lospalos-	Heritage	8°31'30.84" S / 126°59'45.63" E
18.	Uma Adat Monument	Heritage	8°31'21.45" S / 126°59'45.78" E

Socio-cultural and heritage building above mentioned are adjacent to the distribution pipeline (see Figure 24) in which contractor should be aware of during the construction phase so that it will not damage or interfere to the heritage building as according to decree law no. 33/2017 which states that immovable assets should have a protection zone of 50 metres radius and take into account the established mitigation measures.

It is also important to involve the *Lia na'in* and communities for cultural ceremony preparation and *Tara Bandu* protection of the water sources, to strengthen acceptance and avoid ill-feelings towards the project.

Figure 24 Lospalos identified Cultural Sites



8. PUBLIC CONSULTATION

The IEE 2020 process undertook Public Consultation for Lospalos in Lautem Municipal Cultural Centre on the 19th of November 2020 and was participated by local government agencies and authorities (Chief of Suco and Village), and representative members of the communities within the project area, where the issues of significant social concern, its predicted environmental impacts and proposed mitigation measures were presented, in order to collect all useful and relevant inputs from them, for the project construction phase.

The stakeholders gave their concern, suggestion and recommendation for the project implementation, focussing mainly on issues such as Coverage area of the project, Design of the public Toilets, Water distribution system that does not cover or serve all villages, Misuse by consumers (and direct impact on water availability in the distribution system and Cultural sites and new constructions within project area.

In general, during the consultation, no issues of significant social concern or objections about the proposed project were raised and stakeholders were positive about the proposed project and expecting for this project to be implemented as soon as possible, since they are facing crucial issues on water for daily consumption and don't want to repeat uncertain schedule for water delivery into the households in the future.



Figure 25 – Lospalos Public Consultation; participation of the Local Community and Other Stakeholders.

In addition, 2 other Public Consultations, carried out under the social component in Suco Fuiloro and Suco Home (7th December 2020). All PCs registered a significant attendance especially with a strong female participation. After the non-technical presentation of the project, the floor was given to the attendees to discuss water supply and sanitation issues related to the project. Suco community deliberated on the location and the layout of the future Public Toilets. A layout with gender segregation was generally accepted by the community.

The community acknowledges the lack of proper water and sanitation system. Specifically for the water component it is a time consuming activity to transport water from the source to the household. To become potable, water is then boiled before being used which entails in an additional cost for fuel (mainly wood).

The community is supportive of a paid water distribution system and the use of Public Toilets. The creation of a water users association that would support SMASA teams is also generally accepted. The community welcomes

the opportunity to be part of the project either in the construction phase or in the Operation and Maintenance stage, reinforcing the number of SMASA employees.

These Public consultations further confirmed the expectations and worries in the previous Public Consultation and reassured the team that there is very little risk of any water conflicts or impacts felt by the community during implementation and operation of the future system.

Figure 26 Suco Fuloro Social Public Consultation



Figure 27 Suco Home Public Social Consultation



9. CONSULTATION WITH OTHER AUTHORITIES

Since the beginning of the 4 MCWSS project, the team has contacted various entities and stakeholders through meetings to inform and gain understanding of the issues faced in Lospalos in terms of land acquisition, water source and its distribution and cultural heritage sites.

Some of the various consultation meeting are highlighted below for their importance in terms of the project implementation process and to clarify on the communication process with Relevant Stakeholders.

- 2020 June 2nd – 4th – Meeting with Lautem Local Institutions

Culture Representative for Lautem: A brief meeting with Lautem's entity was conducted by the consultant environmental team during the site visit. The first meeting was conducted with Head of Centro Cultural of Lautem with the main objective of informing about the project aim and locations and also gathering information regarding the cultural and sacred sites of Lospalos Municipal Capital. The sites mentioned were Uma Lulik, historical monuments, caves, any kinds of sacred trees, or any other sites which are forbidden by the Lia Nai'n to the community to have access to, taking in consideration applicable mitigation measures as Lautem municipality has many sensitive areas such as protected biodiversity, sacred or cultural areas.

Lautem Department of Environment: The consultant team also conducted a meeting with the Department of the Environment of Lautem. The objective of the meeting was to inform and explain about the WATSAN project in Lospalos and also gather references from previous studies by government or any local or international organizations on biodiversity of Lospalos. However, there was no information that the Department of the Environment of Lautem could provide, as the Department has not conducted any study or research about the environment yet.

SMASA Director: The team also had a brief meeting with the Director of SMASA regarding the environmental component of the project and the summary of the site characterisation carried out during the IEE survey. The prospection point, transmission line and water distribution, and cultural sites were also discussed during the meeting.

- 2020 July 06th – Meeting with Director General of DGAS (Direção Geral Agua e Saneamento)

This meeting was conducted between the representatives of the consultant team and Director General of DGAS. The main purposes of the meeting was to discuss issues regarding:

- i. Illegal water connections;
- ii. Laying water pipeline and
- iii. Coverage area of Water Supply & Sanitation subprojects.

- 2020 September 22nd – Meeting with the Secretariat of State for Arts and Culture

A meeting was conducted between the representative of Secretary of State for Arts and Culture and environmental consultants, which was represented by the National Environmental Technician. The meeting took place in Secretary of State for Arts and Culture Office in Pantai Kelapa. The objective of the meeting was to request cultural heritage sites data in all 4 Municipals in adherence to a request letter sent from the General Directorate of Water and Sanitation Service (BTL) with a reference number 172/C50605/Gab.DGAS/MOP/VII/2020. This is aiming to identify whether or not the sites are located adjacent to the project components and how they will impact on the related sites.

10. PROPOSED CLASSIFICATION OF THE PROJECT

The project's main objective is to guarantee that the overall balance of environmental and social impacts results in positive outcome, taking into special consideration the mitigation commitments in the Environmental Management Plan, the compliance with the RDTL environmental assessment process and especially given the project's special relationship with the institution's technical assistance support.

Based on the extension of proposed water extraction and the nature of the proposed rehabilitation works for Papapa Spring and the Borehole System, and because it is a rehabilitation of the water network i.e. a brownfield

project, with pre-existing pipelines and zones that have undergone previous impacts during the first installation (thus leading to the new intervention being less significant and of temporary duration, with very small portions of the project components requiring new infrastructure i.e. greenfield project areas), the project was classified as Category B under the ADB SPS 2009 (ADB, 2016) in the 2015 Masterplan, for the Lospalos area.

This year (2021) Environmental assessment has been conducted for the Lospalos water supply and sanitation Project based on (i) Preliminary engineering design, and (ii) most likely environmentally sensitive components, applying ADB's rapid environmental assessment (REA) checklist and the field review in June 2020 to help guide the probable classification. This exercise showed that the Lospalos Water supply and sanitation project is not likely to have significant adverse environmental impacts that are irreversible, diverse, or unprecedented, or that potential impacts are unlikely to affect areas larger than the sites or facilities subject to physical works. These impacts are site-specific, few if any of them are irreversible, and in most cases mitigation measures can be designed with uncomplicated measures commonly used at construction sites and known to civil works contractors.

This classification is consistent with the estimated classification process the proponent has carried out under Decree-Law no. 5/2011, particularly Annex I – Category A (EIA) or Annex II – Category B (IEE) thresholds, to follow the Timorese requirements regarding Environmental Licensing.

Table 15 - Estimated Environmental Classification for Lospalos Project Components

Proposed Components	Proposed Capacity	Estimated Classification	Included in XII. Location Factors?
Sanitation			
Public Bathrooms Septic Systems	N/A	N/A	No
Feacal Septage Treatment Plant	5,592 HH	B	No
Water Distribution			
Rehabilitation (Mains and Distribution)	66,915m	B ⁽¹⁾	No
Water Sources (Existing and/or New)			
Papapa System	20 L/sec / 630 720 m ³ /year	B ⁽¹⁾	No
Borehole #3,7,8	15 L/sec (each borehole) / 1,296 m ³ /day	B ⁽¹⁾	No
Borehole #2,5,9	20 L/sec (each) / 1,728 m ³ /day	B ⁽¹⁾	No
Borehole #6 (DNSA)	9 L/sec (777 m ³ /day)	B ⁽¹⁾	No

⁽¹⁾ As in previous ANLA attributed Category B Licenses to similar-scaled water source volumes and length of distribution network such as BTL projects in Pante Macassar and Manatuto (see Appendix 2 and 3).

This assumption is further justified based on the ANLA previously attributed Category B Environmental License for the Government Projects for Rehabilitation of Water Distribution Infrastructure in the District Capital Water Supply Project for Manatuto and Pante Macassar 2014 (see Appendix 2 and 3).

Given this project has all the favourable conditions to be classified as a Category B project, as it is concurrent with both ADB SPS 2009 requirements and the Timorese legislation, **the proponent hereby requests the Environmental Regulator to consider a Category B for this project**, in accordance with the Regulator's choice of classification prerogative outlined in item 2 b) of article 4 of Decree-Law no. 05/2011, since the Decree Law and its Ministerial Diplomas provide flexibility of project Category choice to the Environmental Regulator, when duly justified, especially when the relative scale and gravity of the project's impacts and conditions are similar to the above-mentioned Category B.

II. EXECUTIVE SUMMARY

The DED for the four Municipal Capitals Water Supply & Sanitation Project (4MWSSP) is based on the previous Master plan Design to support the Government of Timor-Leste in providing access to improved water supply and sanitation (WSS) in 4 municipalities (Baucau, Lospalos, Viqueque and Same) financed by the Infrastructure Fund of the Government of Democratic Republic of Timor-Leste with all enumerated infrastructure components, a total of USD\$ 70,404,273 estimated project cost.

The primary objective of this Project Document' s is to provide clear and relevant information on the proposed Water and Sanitation System Improvement Project for **Lautem Municipal Capital only**, taking into account that its rehabilitation will be carried out under a future ADB loan to the Government of Timor-Leste.

The preliminary cost of the 4MCWSSP for Lautem Municipality is estimated around \$16,112,852 for proposed water supply and sanitation expenses. It will include all the areas that will be required to implement the Abstraction, Treatment and Distribution of Water for Human Consumption, as well as provide designs and solutions for Sanitation for Buildings, Schools and Housing within a diameter area of 15 Km around the Municipal Capital.

The 4 MCWSSP is expected to have numerous beneficial and negative impacts towards the environment and social aspects due to various project activities. The project also will provide improvements and opportunities in several ways regarding employment generation, skill enhancement, improved Health and Hygiene as well as Women empowerment. Furthermore, it will directly generate employment opportunities either skilled or non-skilled work for the local people. This type of employment opportunities will increase the skill of the workforce in terms of technical proficiency. By the end of the project, safe and reliable water supply will be provided to the municipal town (sucos and aldeias), and all households will have improved hygienic toilets as well as toilets available in public places. The improved water supply and sanitation facilities in the pilot schools will provide children with safe and reliable water supply and toilets operated by competent operators in each pilot school, providing a template in other schools to improve water supply and toilets.

To improve the efficiency, transparency and public involvement, the ADB (IEE) conducted the Public Consultation for Lautem Municipality in the Municipal Cultural Centre on the 19th of November 2020 and was participated by local government agencies and authorities (Chief of Suco and Village), and representative members of the communities within the project area and was participated by local government agencies and authorities (Chief of Suco and Village), and representative members of the communities within the project area, as well as 2 additional Public Consultation under the Social component (on the 7th December 2020). All the PCs confirmed the acknowledgement of the Project as being fundamental to the improvement of their livelihoods and reassured the team that there is generalised acceptance of the project and very little risk of any water conflicts or impacts felt by the community during the implementation and operation of the future system.

The estimation of classification for the project was done in accordance with the project component scale, as well as the scope referenced in the Second District Capitals Water Supply Project. While all projects funded by ADB and IFC must comply with their Safeguards to ensure that projects are environmentally sound, designed to operate in compliance with applicable regulatory requirements, and are not likely to cause significant environmental, health, or safety hazards, in Timor-Leste, environmental screening and categorization follows suit but is also dependant on project component and scale comparison with Decree-Law no. 5/2011 – Environmental Licensing, particularly Annex I – Category A (EIA) or Annex II – Category B (IEE) thresholds.

As based on DL no. 05/2011 – Environmental licensing, outlined in item 2 b) of article 4, it can be concluded that, overall, the project was not likely to have significant adverse environmental impacts and in most cases mitigation measures can be designed to for them, and therefore the project is proposed to be a Category B project.

12. BIBLIOGRAPHY

ADB. (2020). *ADB IEE (Initial Environmental Examination)*. SAME: ADB.

ADB. (2009). *ADB Safeguard Policy Statement*.

ADB. (2016). *Second District Capitals Water Supply Project: TA-8064 TIM - Final Report*. AURECON. Dili: Asian Development Bank (ADB).

EPANZ. (2007). *Iralalaru Hydropower Project - EIA*. Norwegian Water Resources and Energy Directorate (NVE). Dili: NVE.

DGE. (2018). *Urban Classification for Lautem Municipality - GIS data*. Lospalos, Lautem, Timor-Leste: Ministério das Finanças.

GovTL. (2011). *Decree-Law no.05/2011 -Environmental Licensing*. Government of Timor-Leste.

GovTL. (2017). *Ministerial Diploma no.46*. GovTL.

GovTL. (2017). *Regulation on the Detailed Requirements for the Screening, Scoping and Terms of Reference, of the Environmental Impact Statement and Management Plans for Environmental Evolution*. Government of Timor-Leste.

G-RDTL. (2011). *Timor-Leste Strategic Development Plan 2011 - 2030*. Fifth Government of Timor-Leste, Office of the Prime Minister. Dili: Government of Timor-Leste.


JICA. (2013). *Land Cover, Land Use and Forest Status in Timor-Leste in 2010 - The Forest Preservation Programme in RDTL*. Nippon Koei Co., Ltd. Dili: JICA.

JICA. (2017). *Results of the Evaluation and Prioritization of Watersheds in the Country*. Japan International Cooperation Agency (JICA). Tokyo: JICA.

Seeds of Life. (2014). *Manufahi District Thematic Layers Slope*.

APPENDIXES

Appendix I. Map of Lautem Municipality and the Project



Consultant :



Águas de Portugal - Timor Leste
Unipessoal Lda.



OASIS Sustainable Projects

Client :



Ministry of Public Works
General Directorate for Water and Sanitation

Project Designation :
PROJECT LOCATION

SCALE	DATE
1:40 000	February 2021

- FSTP
- Water Tank
- Borehole
- Spring
- FSTP
- Transmission Main
- Distribution Pipes
- MasterPlan
- Rivers
- 15km Zone
- Protected Areas
- Administrative Boundaries
- Suco Boundary

Appendix 2. Environmental License ADB 0258-TIM Project – Manatuto District



REPÚBLICA DEMOCRÁTICA DE TIMOR-LESTE
National Directorate for Environment, State Secretariat for Environment,
Ministry for Commerce, Industry and Environment

ENVIRONMENTAL LICENSE
Issued under Decree Law on Environmental Licensing No. 05/2011

In accordance with decision dated on 07th August 2014 by the *State Secretary for Environment* Mr. Numinando Soares Martins "Buras" Approved the Simplified Environmental Impact Statement. Hence, pursuant to the Chapter VI of Decree Law on *Environmental Licensing 05/2011* (Decree Law 05/2011), and Issued Environmental License for the activity referred to the Schedule below which subject to the conditions contained in the Annex.

Schedule

Proponent of Project:	National Directorate of Water Supply Services
Date Submitted Application:	20 th of March 2014
Application Number:	20/ AIA-DNMA /XI/ 2013
Environmental License Number:	06 / C:B-5 / SSE-MCIE / VIII / 2014
Activity Scale:	Distance 15.09 km(Transmission pipe 15090m and distribution pipe 68741m; maximum depth 1m)
District and Sub-district:	Manatuto
Category of Project:	Category B
Project:	Upgrading and Rehabilitation of Existing Water supply
Date of Notification:	07 th of August 2014

Notes

1. This Environmental License is non-transferrable in accordance with Articles 22 (4) of Decree Law 05/2011.
2. Proposed changes to the project affecting environmental impacts or the project area/size, or relocation, are subject to technical review and approval in accordance with Chapter VIII of Decree Law 05/2011.
3. Appeal rights are governed by *Decree Law 32/2008 on Administrative Procedure*.
4. The Proponent is solely responsible for ensuring all other necessary renewal license, permit, authorisations or recommendations are obtained from relevant government authorities.

5. The Proponent is responsible for ensuring that all subcontractors or others carrying out works associated with this Environmental License comply with the SEIS, EMP and terms of this Environmental License.
6. All future communications, documents and reports prepared by or on behalf of the Proponent in relation to the Project and submitted to the National Directorate for Environment ('DNMA') shall be in both Tetum and English, and in both electronic and hard copy.

Annex - Conditions of Environmental License

The conditions contained in this Annex are to protect the environment and to mitigate the environmental impacts of the Project.

General Conditions

1. Project in accordance with initial environmental examination documents, and future environmental licenses

- 1.1 The District Capital Water Supply Project must be conducted in accordance with the Final Report of Simplified Environmental Impact Statement (SEIS) prepared by Project Implementation Unit Consultant dated 20th of March 2014 and the incorporated Environmental Management Plan (EMP), except as modified or amended by this Environmental License.
- 1.2 The Expansion, Rehabilitation and operation and maintenance of Manatuto Water Supply Systems must be conducted in accordance with Asia Development Bank Safety Environmental Principle.
- 1.3 The Nature, Size, Location and Importance of the Project, described on page 12 – 15 (5.1-5.2) of the SEIS, strictly states the Project Site Boundary for all development and construction activities related to The District Capital Water Supply Project.
- 1.4 To successfully implement the EMP the SEIS has given adequate instructions for the Project Implementation Unit (PIU) to monitor and report environmental compliance all through the project implementation period.
- 1.5 As planned in the SEIS this Water Supply Project is given the Environmental License granted for two (2) years starting from the Date of the Notification mentioned in *Licensing*
- 1.6 Any proposed changes, alterations or additions to the Project that the Proponent wishes to undertake that are not consistent with the SEIS and EMP and this Environmental License will require an additional Environmental License or amendment of this Environmental License, in accordance with relevant provisions of *Decree Law 05/2011*.
- 1.7 DNMA may review and alter any conditions in this Environmental License, including by requiring alterations to the Environmental Management Plan, to respond to any proposed changes to any component of the Project through any application made by the Proponent to DNMA relating to the Project, if DNMA deems it necessary to do so to protect the environment.

Additional requirements and modifications

2. Construction phase

- 2.1 When the activity starts, community near the area of the project must be included to offer them jobs in which could help minimize the social impacts.
- 2.2 The proponent must coordinate with other institution that related to this activity before implementing the project.
- 2.3 For air quality related to dust, inspection should be done to ensure that residents living along the construction route are not affected. Hence spreading water will help minimize dust emission close to the residential areas;
- 2.4 The proponent must assure that water bodies nearby are safe from siltation and contamination that includes fuel and lubricants used in the rehabilitation of the water supply project;
- 2.5 The proponent must enforce the disposal of surplus material at environmentally safe disposal/ fill sites and that spoil stockpiles are managed properly;
- 2.6 Soils from the excavation must not be disposed of near the water bodies, paddy field, Farmland and community's residential area along the road rehabilitation route;
- 2.7 Sites where rocks and sands are excavated should be 20 meters away from the river bank;
- 2.8 Avoiding excavation of soil and stone in the sensitive environmental areas (protected area/ Forest, potential landslides field, high elevation hills, etc);
- 2.9 When the project is complete, excavated areas must be rehabilitated, materials dumping, Facilities for staff and logistic installed must be demolished and managed it properly;
- 2.10 Actively monitor the water bodies that are close to the construction site during the Rehabilitation process;
- 2.11 The community from the residential areas, horticulture, paddy fields, And other types of farmlands and agricultural plantation whom are affected must be Given compensation in a fair and just manner;
- 2.12 Avoiding in necessary eviction. If any target household need to be remove, please Negotiate in fair manner and applying *prior consent principle*
- 2.13 During the rehabilitation activity, noise from the excavator must be controlled, need to Install appropriate warning signal for safety traffic, for the safety of worker and road Users;
- 2.14 Trucks carrying construction materials (sand, stones, cement etc) must be covered by Tarpaulin to prevent materials from falling off of the trucks;
- 2.15 Alternative roads must be built to ensure that public transportations are not delayed during the rehabilitation;

- 2.16 Rehabilitate eroded areas that caused by the construction activity;
- 2.17 During daytime construction site should be sprayed with water every three hours each day along the Rehabilitation project route;
- 2.18 Prepare disposal site for solid and liquid waste from the construction activity, excavator and trucks; except dangerous waste (oil ,lubricant and so on)
- 2.19 Worker and staff compound close by community village must be develop in coordination with local leaders and the residence. Worker and staff need to respect local people, ritual, symbols of believe and cultures;
- 2.20 Need to apply local content principle for the involvement of local people in working Opportunity and possible local material procurement;
- 2.21 Identified appropriate location for material (sand, stone, wood, water and other material) collection;
- 2.22 Due to the instability of soil, high elevation of the areas and impact of climate change (more rain or less rain could cause erosion), there is need to have bio engineering expert in providing knowledge and techniques to community for re-vegetation and reforestation;
- 2.23 The Proponent must ensure that the waste is disposed of at disposal area;
- 2.24 After the project is finally done, the company is responsible to clean up all the waste and piles from the construction activity along the project route.

National Directorate of environment will be supervision and oriented company refer to the Environment License and Environment Management Plan.

Dili, 07th of August 2014

Approved by:



Numinando Soares Martins "BURAS"
Secretary of State for Environment

Appendix 3. Environmental License ADB 0258-TIM Project – RAEOA



REPÚBLICA DEMOCRÁTICA DE TIMOR-LESTE
National Directorate for Environment, State Secretariat for Environment,
Ministry for Commerce, Industry and Environment

ENVIRONMENTAL LICENSE Issued under Decree Law on Environmental Licensing No. 05/2011

In accordance with decision dated on 07th August 2014 by the **State Secretary for Environment** Mr. Numinando Soares Martins “Buras” Approved the Simplified Environmental Impact Statement. Hence, pursuant to the Chapter VI of Decree Law on *Environmental Licensing 05/2011* (Decree Law 05/2011), and Issued Environmental License for the activity referred to the Schedule below which subject to the conditions contained in the Annex.

Schedule

Proponent of Project:	National Directorate of Water Supply Services
Date Submitted Application:	20th of March 2014
Application Number:	20/ AIA-DNMA /XI/ 2013
Environmental License Number:	06 / C:B-5 / SSE-MCIE / VIII / 2014
Activity Scale:	Distance 6.7 km(Transmission pipe 6768m and distribution pipe 39615m; maximum depth 1m)
District and Sub-district:	Pante Macasar, Oecusse
Category of Project:	Category B
Project:	Upgrading and Rehabilitation of Existing Water supply
Date of Notification:	07th of August 2014

Notes

1. This Environmental License is non-transferrable in accordance with Articles 22 (4) of Decree Law 05/2011.
2. Proposed changes to the project affecting environmental impacts or the project area/size, or relocation, are subject to technical review and approval in accordance with Chapter VIII of Decree Law 05/2011.
3. Appeal rights are governed by *Decree Law 32/2008 on Administrative Procedure*.
4. The Proponent is solely responsible for ensuring all other necessary renewal license, permit, authorisations or recommendations are obtained from relevant government authorities.
5. The Proponent is responsible for ensuring that all subcontractors or others carrying out works associated with this Environmental License comply with the SEIS, EMP and terms of this Environmental License.

- 6 All future communications, documents and reports prepared by or on behalf of the Proponent in relation to the Project and submitted to the National Directorate for Environment ('DNMA') shall be in both Tetum and English, and in both electronic and hard copy.

Annex - Conditions of Environmental License

The conditions contained in this Annex are to protect the environment and to mitigate the environmental impacts of the Project.

General Conditions

1. *Project in accordance with initial environmental examination documents, and future environmental licenses*
 - 1.1. The District Capital Water Supply Project must be conducted in accordance with the Final Report of Simplified Environmental Impact Statement (SEIS) prepared by Project Implementation Unit Consultant dated 20th of March 2014 and the incorporated Environmental Management Plan (EMP), except as modified or amended by this Environmental License.
 - 1.2. The Expansion, Rehabilitation and operation and maintenance of Manatuto Water Supply Systems must be conducted in accordance with Asia Development Bank Safety Environmental Principle.
 - 1.3. The Nature, Size, Location and Importance of the Project, described on page 13 – 19 (5.1-5.2) of the SEIS, strictly states the Project Site Boundary for all development and construction activities related to The District Capital Water Supply Project.
 - 1.4. To successfully implement the EMP the SEIS has given adequate instructions for the Project Implementation Unit (PIU) to monitor and report environmental compliance all through the project implementation period.
 - 1.5. As planned in the SEIS this Water Supply Project is given the Environmental License granted for two (2) years starting from the Date of the Notification mentioned in *Licensing*.
 - 1.6. Any proposed changes, alterations or additions to the Project that the Proponent wishes to undertake that are not consistent with the SEIS and EMP and this Environmental License will require an additional Environmental License or amendment of this Environmental License, in accordance with relevant provisions of *Decree Law 05/2011*.
 - 1.7. DNMA may review and alter any conditions in this Environmental License, including by requiring alterations to the Environmental Management Plan, to respond to any proposed changes to any component of the Project through any application made by the Proponent to DNMA relating to the Project, if DNMA deems it necessary to do so to protect the environment.

Additional requirements and modifications

2. Construction phase


- 2.1 When the activity starts, community near the area of the project must be included to offer them jobs in which could help minimize the social impacts;
- 2.2 For air quality related to dust, inspection should be done to ensure that residents living along the construction route are not affected. Hence spreading water will help minimize dust emission close to the residential areas;
- 2.3 The proponent must coordinate with other institution that related to this activity before implementing the project;
- 2.4 The proponent must assure that water bodies nearby are safe from siltation and contamination that includes fuel and lubricants used in the rehabilitation of the water supply project;
- 2.5 The proponent must enforce the disposal of surplus material at environmentally safe disposal/ fill sites and that spoil stockpiles are managed properly;
- 2.6 Soils from the excavation must not be disposed of near the water bodies, paddy field, Farmland and community's residential area along the road rehabilitation route;
- 2.7 Sites where rocks and sands are excavated should be 20 meters away from the river bank;
- 2.8 Avoiding excavation of soil and stone in the sensitive environmental areas (protected area/ Forest, potential landslides field, high elevation hills, etc);
- 2.9 When the project is complete, excavated areas must be rehabilitated, materials dumping, Facilities for staff and logistic installed must be demolished and managed it properly;
- 2.10 Actively monitor the water bodies that are close to the construction site during the Rehabilitation process;
- 2.11 The community from the residential areas, horticulture, paddy fields, And other types of farmlands and agricultural plantation whom are affected must be Given compensation in a fair and just manner;
- 2.12 Avoiding in necessary eviction. If any target household need to be remove, please Negotiate in fair manner and applying *prior consent principle*
- 2.13 During the rehabilitation activity, noise from the excavator must be controlled, need to Install appropriate warning signal for safety traffic, for the safety of worker and road Users;
- 2.14 Trucks carrying construction materials (sand, stones, cement etc) must be covered by Tarpaulin to prevent materials from falling off of the trucks;
- 2.15 Alternative roads must be built to ensure that public transportations are not delayed during the rehabilitation;

- 2.16 Rehabilitate eroded areas that caused by the construction activity;
- 2.17 During daytime construction site should be sprayed with water every three hours each day along the Rehabilitation project route;
- 2.18 Prepare disposal site for solid and liquid waste from the construction activity, excavator and trucks; except dangerous waste (oil ,lubricant and so on)
- 2.19 Worker and staff compound close by community village must be develop in coordination with local leaders and the residence. Worker and staff need to respect local people, ritual, symbols of believe and cultures;
- 2.20 Need to apply local content principle for the involvement of local people in working Opportunity and possible local material procurement;
- 2.21 Identified appropriate location for material (sand, stone, wood, water and other material) collection;
- 2.22 The Proponent must ensure that the waste is disposed of at disposal area;
- 2.23 Due to the instability of soil, high elevation of the areas and impact of climate change (more rain or less rain could cause erosion), there is need to have bio engineering expert in providing knowledge and techniques to community for re-vegetation and reforestation;
- 2.24 After the project is finally done, the company is responsible to clean up all the waste and piles from the construction activity along the project route.

National Directorate of environment will be supervision and oriented company refer to the Environment License and Environment Management Plan.

Dili, 07th of August 2014

Approved by:



Numinando Soares Martins "BURAS"
Secretary of State for Environment



Appendix 4. Transcripts of Public Consultation (12 October 2020)

4MCWSP Public Consultation

Lospalos (5 October 2020)

1. Questions, Recommendation, Complaints, Responses and Discussion (Q&A session)

1.1 Elio da Silva – Lapuru Aldeia Chief (Suco Fuluro)

➤ Questions & Suggestion: Master Plan

Mr. Elio stated that the presentation is really beneficial to the local community because it can help them to understand the project benefit. From Master Plan it is clearly seen that the WATSAN project only cover some aldeias, why it is happen?

He is also suggest that we should not change the design inside the master plan, as it has been gone through several verifications.

1.2 Helio da Silva – Titilario Aldeia Chief (Suco Fuluro)

➤ Questions and Concern: Master Plan & Coordination

He appreciates the presentation and said it really helpful. He is questioned the master plan as it doesn't include some aldeias. Why some aldeias does not include in Master Plan?

He is also concern about time management and coordination for the next meeting

1.3 Delfin de Jesus – Planning Director of Lautem Municipality

➤ Concerns, Recommendation and Comments – Water demands, Cultural Site, Public Toilets

Appreciated the presentation and the project plan that have been presented by the project proponent, one of the main concerns from the community according to our opinion in regards water demands and we have been talk about that with some engineers. He also said that the soil test related to two constructions are already finalized, thus there are water demands that comes from those constructions as well. On the other hand he also stated that there will have 5 project constructions in Lautem Municipality. Therefore the project proponents also need to consider it regarding technical issues.

He also concerns about the design as Lautem Municipality already planned to rehabilitate Uma Lulik – Sacred House and construct 3 public gardens with outdoor water fountain included. On the other hand one of the main concerns from him in regards the design of Public Toilets. As mentioned in presentation it does not include the design for people with disabilities. He said that it can raise concern from the NGO and also from community. Therefore he recommended to consider also the designs.

He recommends that public toilets should also installed in some specific location as it presents higher demands of toilet.

1.4 Luis do Santos – Home Suco Chief

➤ Questions, concerns & Recommendation – Cost estimation & Public Toilets

As local leader he appreciated and supports the Watsan project to continue and implement in near time. In regards about the contract of the project, does the project has a cost estimation? How about the development of the project, is it for short, medium or long term?

He recommends to the project proponents to define the cost estimation for Home Suco with its expenditure mechanism and publish it to the local leader and also community to know about it. He also said that if possible, project owner can consider to install toilets for Suco's Building as at the moment they don't have any toilet yet.

1.5 Elio Pereira – Aldeia Chief, Suco Home

➤ Question & Recommendation – Project Impacts & Public Toilets

Mr. Pereira asks about the impact to the existing boreholes when the construction begins. If it has an impact what should we do? He also stated about water tank dimension, Can you explained more about water tank dimension for Home Suco? He also recommends to construct public toilet in their Suco.

1.6 João Piedade – National Director for Basic Sanitation

➤ Comments – Coverage Area & Master Plan

Mr. Jose stated that the situation in 2015 is not the same in 2020, therefore there are a lot of community that ask and questioning to enlarge the coverage area of the project. He also add that, there are some areas that considered as an urban area, however the project is not cover till that area. For example Titilari, the project is not cover that place. He hoped that the project owner can take into consideration some of the requirements that comes from the community.

At the same time Mr. Jose also introduced Ms. Joanina from AdP to the community in general as she is always work in close cooperation with Local Authority and Community.

He also considered comment that comes from planning Director of Lautem Municipality (sub-section 1.3) about the construction of public gardens with outdoor water fountain included and said that when we have resources than we can do that, however he asks to the local authority and community to support the implementation of the project.

He outlined that the objective of the public consultation is to collect all the concerns, recommendation, constructive ideas from all the stakeholders, local authorities and community so that the project proponents can take it into consideration before the construction begin.

Regarding concerns from sub-section 1.4 about the short, medium and long term, he argue that it has already finished when published the final report of Master Plan. At the moment we already begin Detail engineering design to find out the source of the potential springs in order to add the water volume and its flow.

Appreciated local authorities and communities because they can work together in order to develop their mother land. He recommends to informed AdP Consultant representation Mr. Jose Serafin (Former DNSA staff) if they have or get some issues related to the project.

➤ Consultant's Clarification to Respond sub-section 1.5:

Aguas de Portugal - Mario Santos : As it has been explained during the presentation regarding sustainability of the water boreholes, we have an equipment that help us to do the test in order to guarantee water sustainability in Home Suco's and others suco's as well. That equipment's also will allow us to understand wether new boreholes that we planned to do will affect the springs or not.

➤ Consultant's Clarification to Respond sub-section 1.5:

Aguas de Portugal - Julio : Regarding water tank, it will consist of concrete wall in which will installed in four different areas with one tower respectively. In Suco Home will install one concrete tank with capacity for 700 cubic meters. These tanks also will provide with treatment facilities and security guards.

He also outlined the restricted area for the participants. He said that when all the water tanks and tower are already installed than those areas will prohibited to community in general and also animals to approach in order to avoid any possible damage to the installation site. The installation area for water tanks will cover approximately 4892 square meters.

Appendix 5. Water Quality Test Report (JICA & Masterplan)

District: Lautem

Town: Los Palos

Tested by: Alvaro Godinho, technician, WSS laboratory and T.ISHIHARA, JICA Study Team

No.	Sampling Point	Date		pH	Temp.	Cond.	TDS	Salinity	Turbid.	Alkali.	Hdns.	Ca-Hdns	NH ₃ -N	NO ₃ -N	NO ₂ -N	Fe	Fluoride	Mn	SO ₄ ²⁻	R.Cl ₂	T.Coli	G.Bac
		sample	test		(°C)	(µS/cm)	(mg/L)	(‰)	(NTU)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	CFU
Timor Loro sa'e Guidelines				6.5-8.5	NS	NS	1000	NS	5.0	NS	200	NS	1.5	10	1	0.3	1.5	0.5	250	5	0	0
LP-1	Papapa, intake	23/mar/00	24/mar/00	7.1	26.1	518	251	0.2	1.7	258	264	NT	0.1	0.6	0.012	ND	0.10	0.1	NT	NT	±	+
LP-2	KOR BATT, Spring	No Sample		NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT
LP-3	Kauto, Old pump house	23/mar/00	24/mar/00	6.8	26.0	523	253	0.3	1.4	NT	NT	NT	ND	NT	NT	NT	0.16	NT	NT	NT	+	+++
LP-4	Perekiki	No Sample		NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT
LP-5	Kartini-1	No Sample		NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT
LP-6	Sawarika	No Sample		NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT
LP-7	Motarlori	23/mar/00	24/mar/00	7.0	26.5	522	253	0.2	1.0	NT	NT	NT	ND	NT	NT	NT	0.17	NT	1	NT	+++	+++
LP-8	Natura, shallow well	No Sample		NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT
LP-9	Central 2	23/mar/00	24/mar/00	7.1	26.8	534	259	0.3	1.0	NT	NT	273	ND	NT	NT	NT	0.21	NT	2	NT	++	++
LP-10	Central 3	23/mar/00	24/mar/00	7.0	27.5	537	260	0.3	1.5	290	297	NT	ND	0.9	0.010	ND	0.25	0.1	NT	NT	NT	NT

Legend:

ND: not detectable NT: not tested NS: not set CFU: colony formed unit -: 0-3 ±: 3-10 +: 10-20 ++: 20-30 +++: more than 30

District: Lautem
Town: Los Palos

Tested by: Alvaro Godinho, technician, WSS laboratory

No.	Sampling Point	Date		pH	Temp. (°C)	R.Cl ₂ (mg/L)	Cond. (µ S/cm)	TDS (mg/L)	Salinity (‰)	Turbidity (NTU)	NH ₃ -N (mg/L)	Fluoride (mg/L)	Alkalinity (mg/L)	Hardness (mg/L)	NO ₃ -N (mg/L)	NO ₂ -N (mg/L)	Fe (mg/L)	Mn (mg/L)	T.Coli CFU	G. Bacteria CFU
		sample	test																	
WHO Guideline Value				6.5-8.5	NS	0.5	NS	1000	NS	5	NS	1.5	NS	200	10	1	0.3	0.5	0	0
1	Papapa, intake	08/mai/00	09/mai/00	7.1	26.0	NT	532	258	0.3	2.12	0.4	0.12	289.0	NT	0.80	0.007	0.02	0.0	±	+
2	Central 2	08/mai/00	09/mai/00	7.1	NT	NT	526	255	0.3	12.3	0.30	0.2	286.0	NT	0.60	0.003	0.02	0.3	++	++
3	Central 3	08/mai/00	09/mai/00	7.0	26.0	NT	518	251	0.2	10.9	0.3	0.10	NT	NT	0.50	0.003	0.00	0.3		
4	Motarlori	08/mai/00	09/mai/00	7.0	26.0	NT	516	250	0.2	1.48	0.5	0.12	288.0	NT	0.40	0.002	0.02	0.1	+++	+++
5	Kauto, Old pump house	08/mai/00	09/mai/00	6.8	26.0	NT	517	250	0.2	2.03	0.2	0.19	NT	NT	0.40	0.002	0.02	NT	+	+++

Legend:

ND: not detectable NT: not tested NS: not set CFU: colony formed unit -: 0-3 ±: 3-10 +: 10-20 ++: 20-30 +++: more than 30

Suggestions

Boil water before drinking

District: Lautem
Town: Los Palos

Sample by Eurico Da Costa, WSS Lospalos, Tested by Alvaro Godinho, Mario soares WSS Laboratory

No.	Sampling Point	Date		pH	Temp.	Cond.	TDS	Salinity	Turbid.	Alkali.	Hdns.	NH ₃ -N	NO ₃ -N	NO ₂ -N	Fe	Fluoride	Mn	SO ₄ ²⁻	T.Coli	E.Coli
		sample	test		(°C)	(µS/cm)	(mg/L)	(‰)	(NTU)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	CFU
Timor Loro sa'e Guidelines				6.5-8.5	NS	NS	1000	NS	5.0	NS	200	1.5	10	1	0.3	1.5	0.5	250	0	0
LP-1	Papapa, intake	30/0ut/00	01/nov/00	7.5	28.7	539	261	0.3	1.4	280	268	ND	0.9	0.011	ND	0.12	ND	1.0	170	0
LP-2	KOR BATT, Spring	30/0ut/00	01/nov/00	7.4	26.8	546	264	0.3	0.4	281	222	1.0	1.3	0.006	ND	0.15	ND	ND	10	0
LP-3	Kauto, Old pump house	30/0ut/00	01/nov/00	7.4	30.0	544	264	0.3	1.6	NT	NT	ND	NT	0.009	NT	0.11	NT	NT	225	0
LP-4	Perekiki	30/0ut/00	01/nov/00	7.5	27.0	545	264	0.3	3.5	280	282	ND	0.9	0.005	ND	ND	0.3	1.0	100	0
LP-5	Kartini-1	30/0ut/00	01/nov/00	7.4	27.6	547	265	0.3	4.4	NT	NT	0.6	NT	ND	NT	0.07	NT	NT	145	0
LP-6	Sawarika	30/0ut/00	01/nov/00	7.3	30.3	554	269	0.3	1.5	281	285	1.1	1.0	0.003	ND	0.18	ND	ND	130	0
LP-7	Motarlari	30/0ut/00	01/nov/00	7.4	27.8	545	264	0.3	2.3	NT	NT	ND	0.8	0.004	ND	ND	ND	1.0	115	5
LP-8	Natura, shallow well	30/0ut/00	01/nov/00	7.6	25.7	440	212	0.2	1.6	NT	219	1.4	0.4	0.007	ND	ND	ND	ND	TNC	130
LP-9	Central 2	31/0ut/00	01/nov/00	7.5	25.9	541	262	0.3	6.5	280	283	ND	0.9	0.009	0.03	0.08	ND	2.0	85	35
LP-10	Central 3	31/0ut/00	01/nov/00	7.5	26.6	541	262	0.3	4.3	NT	NT	0.3	NT	0.008	NT	0.12	NT	NT	220	5

Legend:

ND: not detectable NT: not tested NS: not set CFU: colony formed unit; TNC: too numerous to count

Suggestions

Boiling Water Before Drinking

District Lautem

Town: Lospalos

Sampled by Eurico Da Costa, DWSS Lospalos, Tested by : Alvaro Godinho, Mario Soares WSS Laboratory.

No.	Sampling Point	Date		pH	Temp. (°C)	Cond. (µS/cm)	TDS (mg/L)	Salinity (‰)	Turbid. (NTU)	T. Coli CFU	E. Coli CFU
		sample	test								
Timor Loro sa'e Guidelines				6.5-8.5	NS	NS	1000	NS	5.0	0	0
LP-1	Papapa, intake	22/jan/01	23/jan/01	8.2	22.0	511	247	0.2	3.4	TNC	58
LP-2	KOR BATT, Spring	22/jan/01	23/jan/01	8.2	25.2	534	259	0.3	0.5	10	4
LP-3	Kauto, Old pump house	22/jan/01	23/jan/01	8.2	27.7	409	198	0.2	7.0	300	58
LP-4	Perekiki	22/jan/01	23/jan/01	8.2	27.4	423	204	0.2	9.1	TNC	66
LP-5	Kartini-1	22/jan/01	23/jan/01	8.2	27.7	464	224	0.2	15.5	225	40
LP-6	Saw arika	22/jan/01	23/jan/01	8.2	27.7	468	226	0.2	4.5	TNC	2
LP-7	Motarlari	22/jan/01	23/jan/01	8.2	27.5	443	214	0.0	5.2	550	2
LP-8	Natura, Shalow Well	22/jan/01	23/jan/01	8.2	27.2	457	221	0.2	3.3	TNC	8
LP-9	Central 2	22/jan/01	23/jan/01	8.2	26.7	393	189	0.2	3.5	TNC	18

Legend:

ND: not detectable

NT: not tested

NS: not set

CFU: colony formed unit;

TNC: Too Numerous To Count.

Suggestions

Boiling Water Before Drinking

District : Lautem
Town : Lospalos

Sample by Eurico Da Costa ,WSS Lospalos tested by Alvaro Godinho, Mario Soares WSS Laboratory

No.	Sampling Point	Date		pH	Temp.	Cond.	TDS	Salinity	Turbid.	T.Coli	E.Coli
		sample	test		(°C)	(µS/cm)	(mg/L)	(‰)	(NTU)	CFU	CFU
Timor Loro sa'e Guidelines				6.5-8.5	NS	NS	1000	NS	5.0	0	0
LP-1	Papapa, intake	14/mar/01	15/mar/01	8.3	20.6	526	255	0.3	3.0	TNC	6
LP-2	KOR BATT, Spring	14/mar/01	15/mar/01	8.5	6.7	169	81	0.1	3.8	TNC	0
LP-3	Kauto, Old pump house	14/mar/01	15/mar/01	8.2	20.7	564	276	0.3	3.7	5	0
LP-4	Perekiki	14/mar/01	15/mar/01	8.3	20.3	512	248	0.2	5.7	280	2
LP-5	Kartini-1	14/mar/01	15/mar/01	8.2	20.2	402	194	0.2	4.7	60	0
LP-6	Sawarika	14/mar/01	15/mar/01	8.2	21.2	518	251	0.2	4.5	60	0
LP-7	Motarlori	14/mar/01	15/mar/01	8.3	20.4	517	250	0.2	2.2	225	0
LP-8	Natura, Shalow Well	14/mar/01	15/mar/01	8.1	18.2	450	217	0.2	0.9	345	0
LP-9	Central 2	14/mar/01	15/mar/01	8.2	21.3	519	252	0.2	1.0	195	4
LP-10	Central 3	14/mar/01	15/mar/01	8.2	21.9	482	233	0.2	1.9	190	0

Legend:

ND: not detectable

NT: not tested

NS: not set

CFU: colony formed unit,

TNC: Too Numerous To Count

Suggestions

Boiling Water Before Drinking

District : Lautem
Town : Lospalos

Sampling Date : 18-April-2001

Sampled by : Eurico da Costa DWSS Lospalos

Testing Date : 19-April-2001

Tested by : Alvaro Godinho .Mario Soares WSS Laboratory

Received by : X. Wang

No	Sampling Point	Time		pH	Temp.	Cond.	TDS	Salinity	Turbid.	Ca.Hardness	Hardness	T.Coliform	E.Coli
		sample	test		(°C)								
East Timor Guidelines		Hours And Minutes		6.5-8.5	NS	NS	1000	NS	5.0	NS	200	0	0
LP-1	Papapa, intake		09:30	8.3	21.7	512	248	0.2	2.7	230	275	60	70
LP-2	KOR BATT, Spring		09:32	8.2	7.5	303	146	0.1	7.1	NT	NT	50	18
LP-3	Kauto, Old pump house		09:35	8.3	22.0	512	248	0.2	3.3	NT	NT	0	0
LP-4	Perekiki		09:47	8.0	16.1	394	190	0.2	3.7	NT	NT	TNC	TNC
LP-5	Kartini-1		09:48	NT	NT	NT	NT	NT	NT	NT	NT	TNC	TNC
LP-6	Sawarika		09:49	8.3	23.7	315	248	0.2	8.4	NT	NT	73	0
LP-7	Motarlori		10:02	8.3	22.1	512	248	0.2	2.3	NT	NT	100	6
LP-8	Natura, Shallow Well		10:04	8.0	11.2	835	40	ND	76.5	NT	NT	80	6
LP-9	Central 2		10:14	7.8	11.2	79	37	ND	27.8	NT	NT	123	82
LP-10	Central 3		15:15	8.2	18.9	497	240	0.2	15.8	NT	NT	140	0

Legend:

ND: not detectable

NT: not tested

NS: not set

CFU: colony formed unit; TNC: Too Numerous To Count

Suggestions

Boiling Water Before Drinking

District : Lautem
Town : Lospalos

Sampling Date :22-May-2001

Sampled by : Eurico da Costa DWSS Lospalos

Testing Date :25-May-2001

Tested by : Mario Soares WSS Laboratory

Received by : Alvaro Godinho

No	Sampling Point	Time		pH	Temp. (°C)	Cond. (µS/cm)	TDS (mg/L)	Salinity (‰)	Turbid. (NTU)	Ca.Hardness (mg/l)	Hardness (mg/l)	T.Coliform CFU	E.Coli CFU
		sample	test										
East Timor Guidelines		Hours And Minutes		6.5-8.5	NS	NS	1000	NS	5.0	NS	200	0	0
LP-1	Papapa, intake		11:17	8.3	16.7	334	161	0.2	0.8	NT	176	-	++
LP-2	KOR BATT, Spring		11:19	8.2	15.0	340	163	0.2	0.6	NT	NT	±	+
LP-3	Kauto, Old pump house		11:22	8.3	15.1	334	161	0.2	0.7	NT	NT	-	+++
LP-4	Perekiki		11:24	8.2	15.1	338	163	0.2	0.6	NT	NT	-	±
LP-5	Kartini-1		11:26	8.3	14.4	320	154	0.2	0.9	NT	NT	-	+++
LP-6	Sawarika		11:31	8.4	14.3	317	153	0.2	3.5	NT	NT	-	±
LP-7	Motarlori		11:32	8.4	14.2	293	141	0.1	1.1	NT	NT	-	+
LP-8	Natura, Shalow Well		11:37	8.2	14.7	340	164	0.2	0.7	NT	NT	-	+++
LP-9	Central 2		11:39	8.1	24.6	339	163	0.2	1.1	NT	NT	-	+++
LP-10	Central 3		11:45	8.2	24.8	299	144	0.1	1.0	NT	NT	-	+

Legend:

ND: not detectable

NT: not tested

NS: not set

CFU: colony formed unit; TNC: Too Numerous To Count

For Paper Slip

(-) : 0 - 3

(±) : 3 - 10

(+) : 10 - 20

(++) : 20 - 30

(+++) : more than 30

Suggestions

Boiling Water Before Drinking

District : Lautem
Town : Lospalos

Sampling Date :19/ June/2001

Sampled by : Eurico da Costa DWSS Lospalos

Testing Date :19 /june/2001

Tested by : Miguel Quintao & Mario Soares WSS Laboratory

Received by : Miguel Quintao

No	Sampling Point	Time		pH	Temp. (°C)	Cond. (µS/cm)	TDS (mg/L)	Salinity (‰)	Turbid. (NTU)	Alkalinity (mg/l)	Hardness (mg/l)	T.Coliform CFU	E.Coli CFU
		sample	test										
East Timor Guidelines		Hours And Minutes		6.5-8.5	NS	NS	1000	NS	5.0	NS	200	0	0
LP-1	Papapa, intake		11:41	8.3	27.1	525	254	0.3	2.0	NT	1604	++	+++
LP-2	KOR BATT, Spring		11:44	8.2	27.0	528	256	0.3	1.8	NT	NT	++	+++
LP-3	Kauto, Old pump house		11:46	8.2	26.8	529	256	0.3	1.8	NT	NT	++	+++
LP-4	Perekiki		11:48	8.2	26.6	527	255	0.3	1.8	NT	NT	+++	+++
LP-5	Kartini-1		11:51	8.2	26.4	529	256	0.3	1.8	NT	NT	++	+++
LP-6	Sawarika		11:54	8.2	26.3	526	255	0.3	1.7	NT	NT	++	+++
LP-7	Motarlori		11:56	8.2	26.2	528	256	0.3	1.4	NT	NT	+++	+++
LP-8	Natura, Shalow Well		11:58	8.3	25.9	524	254	0.3	1.7	NT	1514	++	+++
LP-9	Central 2		11:59	8.3	25.5	526	255	0.3	1.8	NT	NT	++	+++
LP-10	Central 3		12:01	8.3	25.5	525	254	0.3	1.8	NT	NT	+++	+++

Legend:

ND: not detectable

NT: not tested

NS: not set

CFU: colony formed unit;

TNC: Too Numerous To Count

Weather Report :

Sunny / Cloudy / Rain

Suggestions

Boiling Water Before Drinking

District : Lautem
Town : Lospalos

Sampling Date :16-07-2001

Sampled by : Eurico da Costa,DWSS Lospalos

Testing Date :17-07-2001

Tested by : Mario Soares WSS Laboratory

Received by : Mario Soares

No	Sampling Point	Time		pH	Temp. (°C)	Cond. (µS/cm)	TDS (mg/L)	Salinity (‰)	Turbid. (NTU)	Alkalinity (mg/l)	Hardness (mg/l)	T.Coliform CFU	E.Coli CFU
		sample	test										
East Timor Guidelines		Hours And Minutes		6.5-8.5	NS	NS	1000	NS	5.0	NS	200	0	0
LP-1	Papapa, intake	15:05	15:17	8.1	26.5	530	257	0.3	2.9	NT	NT	15	4
LP-2	KOR BATT, Spring	15:09	15:19	8.1	26.5	511	247	0.2	2.7	NT	NT	95	0
LP-3	Kauto, Old pump house	15:18	15:23	8.1	26.1	515	249	0.2	2.7	NT	NT	NT	NT
LP-4	Perekiki	18:45	15:26	8.1	25.9	503	244	0.2	3.5	NT	NT	NT	NT
LP-5	Kartini-1	18:55	15:30	8.2	26.0	507	245	0.2	3.2	NT	NT	NT	NT
LP-6	Sawarika	10:55	15:35	8.0	26.0	549	266	0.3	1.5	NT	NT	NT	NT
LP-7	Motarlori	15:30	15:37	8.1	25.9	513	249	0.2	1.4	NT	NT	NT	NT
LP-8	Natura, Shalow Well	10:40	15:42	8.1	25.1	448	216	0.2	0.7	NT	NT	NT	NT
LP-9	Central 2	09:04	15:46	8.1	26.1	514	249	0.2	1.5	NT	NT	NT	NT
LP-10	Central 3	16:30	15:47	8.1	26.1	513	248	0.2	2.3	NT	NT	NT	NT

Legend:

ND: not detectable

NT: not tested

NS: not set

CFU: colony formed unit

TNC: Too Numerous To Count.

Weather Report :

Sunny

Cloudy

Rain

Suggestions

Boiling Water Before Drinking

District : Lautem
Town : Lospalos

Sampling Date :15 - 08 - 2001

Sampled by : Eurico Da Costa DWSS Lospalos

Testing Date :17 - 08 - 2001

Tested by : Miguel Quintao WSS Laboratory

Received by :Miguel Quintao

No	Sampling Point	Time		pH	Temp.	Cond.	TDS	Salinity	Turbid.	Alkalinity	Hardness	T.Coliform	E.Coli
		sample	test		(°C)	(µS/cm)	(mg/L)	(‰)	(NTU)	(mg/l)	(mg/l)	CFU	CFU
East Timor Guidelines		Hours And Minutes		6.5-8.5	NS	NS	1000	NS	5.0	NS	200	0	0
LP-1	Papapa, intake	14:03	14:57	8.3	28.0	527	255	0.3	0.8	234	208	TNC	10
LP-2	KOR BATT, Spring	14:08	14:59	8.2	27.2	525	254	0.3	0.8	232	258	TNC	45
LP-3	Kaub, Old pump house	14:27	15:02	8.2	26.8	524	254	0.3	0.8	NT	NT	TNC	45
LP-4	Perekiki	18:31	15:04	8.1	26.8	525	254	0.3	0.9	NT	NT	TNC	25
LP-5	Kartini-1	18:36	15:07	8.2	26.6	525	284	0.3	0.8	NT	NT	TNC	5
LP-6	Sawarika	09:10	15:10	8.2	26.5	566	274	0.3	0.9	NT	NT	TNC	20
LP-7	Motarlori	08:10	15:12	8.2	26.5	526	255	0.3	0.8	NT	NT	TNC	10
LP-8	Natura, Shalow Well	08:16	15:15	8.1	26.3	523	253	0.3	1.0	NT	NT	TNC	5
LP-9	Central 2	11:13	15:17	8.1	26.7	552	267	0.3	0.8	NT	NT	TNC	5
LP-10	Central 3	08:56	15:19	8.2	26.4	524	254	0.3	0.9	NT	NT	TNC	45

Legend:

ND: not detectable

NT: not tested

NS: not set

CFU: colony formed unit

TNC: Too Numerous To Count

Weather Report :

Sunny

Cloudy

Rain

Suggestions

Boiling Water Before Drinking

District : Lautem
Town : Lospalos

Sampling Date : 15/ 10/ 2001

Testing Date : 17/10/2001

Received by : Miguel Quintao

Sample by :Eurico da Costa DWSS Lautem

Testing by : Miguel Quintao WSS Lab

No	Sampling Point	Time		pH	Temp.	Cond.	TDS	Salinity	Turbid.	Hard	Alkal	T.Coli	E.Coli
		sample	test		(°C)	(µS/cm)	(mg/L)	(‰)	(NTU)	(mg/l)	(mg/l)	CFU	CFU
East Timor Guidelines		Hours And Minutes		6.5-8.5	NS	NS	1000	NS	5.0	200	NS	0	0
LP-1	Papapa, intake	14:30	15:18	8.1	25.1	393	190	0.2	1.2	266	1964	TNC	2
LP-2	KOR BATT, Spring	14:35	15:19	8.1	24.5	457	221	0.2	1.7	NT	NT	TNC	112
LP-3	Kauto, Old pump house	14:45	15:20	8.0	24.5	437	211	0.2	1.0	NT	NT	TNC	2
LP-4	Perekiki	18:35	16:58	8.0	24.6	429	207	0.2	1.2	NT	NT	56	0
LP-5	Kartini-1	18:40	16:00	8.0	24.9	427	206	0.2	1.2	NT	NT	26	0
LP-6	Sawarika	09:30	16:01	8.0	25.2	416	201	0.2	0.9	NT	NT	16	0
LP-7	Motarlori	08:03	16:10	8.0	25.4	423	204	0.2	0.8	NT	NT	42	0
LP-8	Natura, Shalow Well	15:30	16:11	7.9	25.6	431	208	0.2	1.0	260	2182	52	0
LP-9	Central 2	10:21	16:12	8.0	25.9	427	206	0.2	1.0	NT	NT	120	0
LP-10	Central 3	10:25	16:20	8.2	26.8	494	239	0.2	1.1	NT	NT	72	0

Legend:

ND: not detectable

NT: not tested

NS: not set

CFU: colony formed unit;

TNC: Too Numerous To Count

Weather Report :

Sunny

Cloudy

Rain

Suggestions

Boiling Water Before Drinking

District : Lautem
Town : Lospalos

Sampling Date : 12 / December / 2001
 Testing Date : 13 / December / 2001
 Received by : Mario Soares

Sample by : Eurico da Costa DWSS Lospalos
 Testing by : Miguel Quintao and Mario Soares WSS Laboratory

No	Sampling Point	Time		pH	Temp. (°C)	Cond. (µS/cm)	TDS (mg/L)	Salinity (‰)	Turbid. (NTU)	Hard (mg/l)	Alkal (mg/l)	NH ₃ -N (mg/L)	NO ₃ -N (mg/L)	NO ₂ -N (mg/L)	Fe (mg/L)	Fluoride (mg/L)	Mn (mg/L)	SO ₄ ²⁻ (mg/L)	T.Coli CFU	E.Coli CFU
		sample	test																	
East Timor Guidelines		Hours And Minutes		6.5-8.5	NS	NS	1000	NS	5.0	200	NS	1.5	10	1	0.3	1.5	0.5	250	0	0
LP-1	Papapa, intake	15:00	14:43	7.9	27.0	508	246	0.2	1.1	440	305	0.9	0.5	0.016	0.03	0.8	NT	2	TNC	490
LP-2	KOR BATT, Spring	15:05	14:44	8.0	27.0	411	199	0.2	15.1	330	250	0.6	0.3	0.013	0.25	0.16	NT	6	TNC	542
LP-3	Kaub, Old pump house	15:20	14:45	8.0	27.0	412	199	0.2	14.3	NT	NT	NT	NT	NT	NT	NT	NT	NT	182	2
LP-4	Perekiki	15:25	14:55	7.9	27.0	398	192	0.2	19.2	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	466
LP-5	Kartini-1	15:30	14:56	8.0	27.0	397	192	0.2	16.9	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	484
LP-6	Sawarika	16:00	14:57	8.0	27.0	380	183	0.2	17.6	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	476
LP-7	Motarlori	15:31	15:05	8.0	27.0	398	192	0.2	16.6	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	488
LP-8	Natura, Shalow Well	14:40	15:06	8.1	27.0	398	192	0.2	18.6	195	240	0.9	0.4	0.027	0.29	0.15	NT	NT	TNC	426
LP-9	Central 2	14:45	15:07	8.0	27.0	399	193	0.2	18.9	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	510
LP-10	Central 3	14:00	15:16	8.0	27.0	399	192	0.2	17.2	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	TNC

Legend:

ND: not detectable NT: not tested NS: not set FU: colony formed urNC: Too Numerous To Count
 Weather Report : Sunny Cloudy Rain

Inspected by :

Suggestions

1. Bacteriological Is Problem
2. Boiling Water Before Drinking

Mario Soares Laboratory Manager

District : Lautem
Town : Lospalos

Sampling Date : 15/February /2002

Sample by : Eurico da Costa DWSS Lautem

Testing Date : 18/ February /2002

Testing by : Miguel Quintao WSS Laboratory

Received by : Miguel Quintao

No	Sampling Point	Time		pH	Temp.	Cond.	TDS	Salinity	Turbid.	Hard	Alkal	NH ₃ -N	NO ₃ -N	NO ₂ -N	Fe	Fluoride	Mn	SO ₄ ²⁻	T.Coli	E.Coli
		sample	test		(°C)	(µS/cm)	(mg/L)	(‰)	(NTU)	(mg/l)	(mg/l)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	CFU
East Timor Guidelines		Hours And Minutes		6.5-8.5	NS	NS	1000	NS	5.0	200	NS	1.5	10	1	0.3	1.5	0.5	250	0	0
LP-1	Papapa, intake	14:30	11:05	8.2	25.1	563	224	0.2	1.5	430	300	0.9	0.3	0.006	0.01	0.1	NT	ND	TNC	174
LP-2	KOR BATT, Spring	14:32	11:06	7.9	25.2	485	234	0.2	1.1	245	280	0.3	0.5	0.016	ND	ND	NT	1	94	0
LP-3	Kautb, Old pump house	14:25	11:07	8.1	21.1	487	236	0.2	1.5	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	82
LP-4	Perekiki	18:30	11:16	8.2	19.4	485	234	0.2	1.4	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	166
LP-5	Kartini-1	18:36	11:17	8.0	21.8	488	236	0.2	1.2	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	164
LP-6	Sawarika	10:25	11:19	8.1	22.3	491	238	0.2	1.1	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	138
LP-7	Motarlori	08:15	11:30	8.2	21.3	487	236	0.2	1.1	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	178
LP-8	Natura, Shalow Well	16:30	11:31	8.2	25.6	443	214	0.2	0.6	210	315	0.4	0.6	0.005	0.02	ND	NT	ND	TNC	68
LP-9	Central 2	11:00	11:32	8.0	22.6	489	237	0.2	1.1	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	98
LP-10	Central 3	11:20	11:42	8.2	22.6	475	230	0.2	1.2	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	0

Legend:

ND: not detectable

NT: not tested

NS: not set

:U: colony formed u C: Too Numerous To Cou

Weather Report :

Sunny

Cloudy Rain

Inspected by :

Suggestions

1. Bacteriological Is Problem
2. Boiling Water Before Drinking

Mario Soares Laboratory Manager

District : Lautem
Town : Lospalos

Sampling Date : 15/February /2002

Sample by : Eurico da Costa DWSS Lautem

Testing Date : 18/ February /2002

Testing by : Miguel Quintao WSS Laboratory

Received by : Miguel Quintao

No	Sampling Point	Time		pH	Temp.	Cond.	TDS	Salinity	Turbid.	Hard	Alkal	NH ₃ -N	NO ₃ -N	NO ₂ -N	Fe	Fluoride	Mn	SO ₄ ²⁻	T.Coli	E.Coli
		sample	test		(°C)	(µS/cm)	(mg/L)	(‰)	(NTU)	(mg/l)	(mg/l)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	CFU
East Timor Guidelines		Hours And Minutes		6.5-8.5	NS	NS	1000	NS	5.0	200	NS	1.5	10	1	0.3	1.5	0.5	250	0	0
LP-1	Papapa, intake	14:30	11:05	8.2	25.1	563	224	0.2	1.5	430	300	0.9	0.3	0.006	0.01	0.1	NT	ND	TNC	174
LP-2	KOR BATT, Spring	14:32	11:06	7.9	25.2	485	234	0.2	1.1	245	280	0.3	0.5	0.016	ND	ND	NT	1	94	0
LP-3	Kautb, Old pump house	14:25	11:07	8.1	21.1	487	236	0.2	1.5	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	82
LP-4	Perekiki	18:30	11:16	8.2	19.4	485	234	0.2	1.4	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	166
LP-5	Kartini-1	18:36	11:17	8.0	21.8	488	236	0.2	1.2	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	164
LP-6	Sawarika	10:25	11:19	8.1	22.3	491	238	0.2	1.1	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	138
LP-7	Motarlori	08:15	11:30	8.2	21.3	487	236	0.2	1.1	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	178
LP-8	Natura, Shalow Well	16:30	11:31	8.2	25.6	443	214	0.2	0.6	210	315	0.4	0.6	0.005	0.02	ND	NT	ND	TNC	68
LP-9	Central 2	11:00	11:32	8.0	22.6	489	237	0.2	1.1	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	98
LP-10	Central 3	11:20	11:42	8.2	22.6	475	230	0.2	1.2	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	0

Legend:

ND: not detectable NT: not tested NS: not set U: colony formed u C: Too Numerous To Cou

Weather Report : Sunny Cloudy Rain

Inspected by :

Suggestions

1. Bacteriological Is Problem
2. Boiling Water Before Drinking

Mario Soares Laboratory Manager

District : Lautem
Town : Lospalos

Sampling Date : 20 - 04 - 2002
 Testing Date : 22 - 04 - 2002
 Received by : Mario Soares

Sample by : Eurico Da Costa DWSS Lautem
 Testing by : Miguel Quintao WSS Laboratory

No	Sampling Point	Time		pH	Temp.	Cond.	TDS	Salinity	Turbid.	Hard	Alkal	NH ₃ -N	NO ₃ -N	NO ₂ -N	Fe	Fluoride	Mn	SO ₄ ²⁻	T.Coli	E.Coli
		sample	test		(°C)	(µS/cm)	(mg/L)	(‰)	(NTU)	(mg/l)	(mg/l)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	CFU
East Timor Guidelines		Hours And Minutes		6.5-8.5	NS	NS	1000	NS	5.0	200	NS	1.5	10	1	0.3	1.5	0.5	250	0	0
LP-1	Papapa, intake	16:10	16:03	8.4	28.9	324	156	0.2	1.2	NT	NT	NT	NT	NT	NT	NT	NT	NT	220	0
LP-2	KOR BATT, Spring	16:15	16:04	7.9	28.2	386	186	0.2	0.8	300	176	NT	NT	NT	NT	NT	NT	NT	765	0
LP-3	Kautb, Old pump house	16:30	16:05	7.9	28.3	397	191	0.2	0.9	NT	NT	NT	NT	NT	NT	NT	NT	NT	830	2
LP-4	Perekiki	19:30	16:11	7.9	28.0	265	127	0.1	0.9	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	0
LP-5	Kartini-1	19:39	16:12	7.8	28.3	378	187	0.2	0.8	NT	NT	NT	NT	NT	NT	NT	NT	NT	1245	14
LP-6	Sawarika	16:45	16:13	7.8	28.1	388	187	0.2	1.0	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	4
LP-7	Motarlori	18:20	16:16	7.8	28.0	398	192	0.2	0.8	210	225	NT	NT	NT	NT	NT	NT	NT	TNC	8
LP-8	Natura, Shalow Well	15:30	16:17	7.7	26.8	292	140	0.1	5.7	NT	NT	NT	NT	NT	NT	NT	NT	NT	1060	4
LP-9	Central 2	10:10	16:18	7.7	27.5	388	187	0.2	2.0	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	4
LP-10	Central 3	10:25	16:25	7.6	27.8	362	175	0.2	2.1	NT	NT	NT	NT	NT	NT	NT	NT	NT	186	0

Legend:

ND: not detectable NT: not tested NS: not set FU: colony formed urTNC: Too Numerous To Count
 Weather Report : Sunny Cloudy Rain

Inspected by :

Suggestions

1. Bacteriological Is Problem
2. Boiling Water Before Drinking

Mario Soares Laboratory Manager

District : Lautem
Town : Lospalos

Sampling Date : 01/07/2002
 Testing Date : 02/07/2002
 Received by : Mario Soares

Sample by : Eurico da Costa DWSS Lospalos
 Testing by : Mario Soares and Miguel Quintao WSS Laboratory

No	Sampling Point	Time		pH	Temp. °C	Cond. (µS/cm)	TDS (mg/L)	Salinity (‰)	Turbid. (NTU)	Hard (mg/l)	Alkal (mg/l)	NH ₃ -N (mg/L)	NO ₃ -N (mg/L)	NO ₂ -N (mg/L)	Fe (mg/L)	Fluoride (mg/L)	Mn (mg/L)	SO ₄ ²⁻ (mg/L)	T.Coli CFU	E.Coli CFU
		sample	test																	
East Timor		Hours And		6.5-8.5	NS	NS	1000	NS	5.0	200	NS	1.5	10	1	0.3	1.5	0.5	250	0	0
LP-1	Papapa, intake	18:15	09:32	8.5	24.8	460	222	0.2	0.9	165	180	NT	NT	NT	NT	NT	NT	NT	TNC	68
LP-2	KOR BATT, Spring	18:17	09:33	8.5	24.4	490	237	0.2	0.6	295	280	NT	NT	NT	NT	NT	NT	NT	18	0
LP-3	Kauto, Old pump house	18:00	09:40	8.3	24.1		238	0.2	0.7	NT	NT	NT	NT	NT	NT	NT	NT	NT	10	2
LP-4	Perekiki	18:23	09:41	8.1	24.1	492	224	0.2	0.6	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	12
LP-5	Kartini-1	18:23	09:46	8.2	24.1	498	241	0.2	0.6	NT	NT	NT	NT	NT	NT	NT	NT	NT	30	2
LP-6	Sawarika	18:50	09:47	8.2	24.1	507	245	0.2	0.5	NT	NT	NT	NT	NT	NT	NT	NT	NT	56	0
LP-7	Motarlori	18:45	09:55	8.4	24.1	495	239	0.2	0.5	270	275	NT	NT	NT	NT	NT	NT	NT	9	3
LP-8	Natura, Shalow Well	18:30	09:56	8.2	24.1	394	190	0.2	0.8	NT	NT	NT	NT	NT	NT	NT	NT	NT	28	22
LP-9	Central 2	18:40	10:05	8.3	24.1	496	240	0.2	0.7	NT	NT	NT	NT	NT	NT	NT	NT	NT	15	16
LP-10	Central 3	18:21	10:06	8.2	23.9	496	240	0.2	0.5	NT	NT	NT	NT	NT	NT	NT	NT	NT	20	12

Legend:

ND: not detectable NT: not tested NS: not set CFU: colony formed unit TNC: Too Numerous To Count

Weather Report : Sunny Cloudy Rain

Inspected by :

Suggestions

1. Bacteriological Is Problem
2. Boiling Water Before Drinking

Mario Soares Laboratory Manager

District : Lautem
Town : Lospalos

Sampling Date : 15 - 03 - 2003

Sample by : Eurico da costa Dwss Lospalos

Testing Date : 16 - 03 - 2003

Testing by : Miguel Quintao Wss Laboratory

Received by : Miguel Quintao

No	Sampling Point	Time		pH	Temp.	Cond.	TDS	Salinity	Turbid.	Hard	Alkal	NH ₃ -N	NO ₃ -N	NO ₂ -N	Fe	Fluoride	Mn	SO ₄ ²⁻	T.Coli	E.Coli
		sample	test		(°C)	(µS/cm)	(mg/L)	(‰)	(NTU)	(mg/l)	(mg/l)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	CFU
East Timor		Hours	And	6.5-8.5	NS	NS	1000	NS	5.0	200	NS	1.5	10	1	0.3	1.5	0.5	250	0	0
LP-1	Papapa, intake	09:10	10:36	8.6	29.3	292	140	0.1	0.5	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	4
LP-2	KOR BATT, Spring	09:15	10:37	8.5	29.3	257	123	0.1	0.4	250	120	NT	NT	NT	NT	NT	NT	NT	TNC	30
LP-3	Kaub, Old pump house	09:00	10:44	8.2	29.1	285	131	0.1	0.2	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	14
LP-4	Perekiki	10:19	10:45	8.5	29.0	249	121	0.1	0.1	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	48
LP-5	Kartini-1	10:25	10:46	8.4	29.1	290	139	0.1	0.2	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	54
LP-6	Sawarika	11:15	10:55	8.5	29.0	275	132	0.1	0.5	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	60
LP-7	Motarlori	10:40	10:54	8.5	29.0	270	131	0.1	0.1	150	165	NT	NT	NT	NT	NT	NT	NT	TNC	54
LP-8	Natura, Shalow Well	11:14	10:55	8.5	29.3	290	141	0.1	0.5	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	34
LP-9	Central 2	12:00	10:57	8.5	29.3	250	121	0.1	0.3	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	28
LP-10	Central 3	12:15	10:58	8.6	29.1	270	135	0.1	0.5	NT	NT	NT	NT	NT	NT	NT	NT	NT	150	2

Legend:

ND: not detectable NT: not tested NS: not set CFU: colony forming units TNC: Too Numerous To Count

Weather Report : Sunny Cloudy Rain

Inspected by :

Suggestions

1. Bacteriological Is Problem
2. Boiling Water Before Drinking

Mario Soares Laboratory Manager

District : Lautem
Town : Lospalos

Sampling Date : 15 - 03 - 2003

Sample by : Eurico da costa Dwss Lospalos

Testing Date : 16 - 03 - 2003

Testing by : Miguel Quintao Wss Laboratory

Received by : Miguel Quintao

No	Sampling Point	Time		pH	Temp.	Cond.	TDS	Salinity	Turbid.	Hard	Alkal	NH ₃ -N	NO ₃ -N	NO ₂ -N	Fe	Fluoride	Mn	SO ₄ ²⁻	T.Coli	E.Coli
		sample	test		(°C)	(µS/cm)	(mg/L)	(‰)	(NTU)	(mg/l)	(mg/l)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	CFU
East Timor		Hours	And	6.5-8.5	NS	NS	1000	NS	5.0	200	NS	1.5	10	1	0.3	1.5	0.5	250	0	0
LP-1	Papapa, intake	09:10	10:36	8.6	29.3	292	140	0.1	0.5	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	4
LP-2	KOR BATT, Spring	09:15	10:37	8.5	29.3	257	123	0.1	0.4	250	120	NT	NT	NT	NT	NT	NT	NT	TNC	30
LP-3	Kaub, Old pump house	09:00	10:44	8.2	29.1	285	131	0.1	0.2	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	14
LP-4	Perekiki	10:19	10:45	8.5	29.0	249	121	0.1	0.1	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	48
LP-5	Kartini-1	10:25	10:46	8.4	29.1	290	139	0.1	0.2	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	54
LP-6	Sawarika	11:15	10:55	8.5	29.0	275	132	0.1	0.5	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	60
LP-7	Motarlari	10:40	10:54	8.5	29.0	270	131	0.1	0.1	150	165	NT	NT	NT	NT	NT	NT	NT	TNC	54
LP-8	Natura, Shalow Well	11:14	10:55	8.5	29.3	290	141	0.1	0.5	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	34
LP-9	Central 2	12:00	10:57	8.5	29.3	250	121	0.1	0.3	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	28
LP-10	Central 3	12:15	10:58	8.6	29.1	270	135	0.1	0.5	NT	NT	NT	NT	NT	NT	NT	NT	NT	150	2

Legend:

ND: not detectable NT: not tested NS: not set CFU: colony formed TNC: Too Numerous To Count

Weather Report : Sunny Cloudy Rain

Inspected by :

Suggestions

1. Bacteriological Is Problem
2. Boiling Water Before Drinking

Mario Soares Laboratory Manager

District : Lautem
Town : Lospalos

Sampling Date : 01/; 14/03/2019

Sample by : Eurico da Costa DWSS Lospalos

Testing Date : 02; 15/03/2019

Testing by : Mai; Sidonio X. de Jesus

& Estela

Received by : M: Mario Soares

No	Sampling Point	test	pH	Temp.	Cond.	TDS	Salinity	Turbid.	Hard	Alkal	NH ₃ -N	NO ₃ -N	NO ₂ -N	Fe	Fluoride	Mn	SO ₄ ²⁻	T.Coli	E.Coli
				(°C)	(µS/cm)	(mg/L)	(‰)	(NTU)	(mg/l)	(mg/l)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	CFU
East Timor Guidelines		Hours And Minutes	6.5-8.5	NS	NS	1000	NS	5.0	200	NS	1.5	10	1	0.3	1.5	0.5	250	0	0
LP-1	Papapa, intake	09;05	8.2	24.4	220	110.6	0.1	173.0	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	TNC
LP-2	Puahopu intake, Spring	07;00	7.9	24.1	559	283	0.3	0.9	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	28
LP-3	Kaub, Old pump house	09;03	8.2	24.2	198.2	99.9	0.1	176.0	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	TNC
LP-4	Uma Seguransa Papapa	09;10	7.9	24.2	558	282	0.3	0.9	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	36
LP-5	Eks Edifiso SMASA Kuluhun	08;38	7.8	24.2	506	256	0.2	2.4	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	TNC
LP-6	Edifiso SMASA Lautem	10;32	7.6	24.5	550	277	0.3	0.9	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	TNC
LP-7	Central 3/Manuel da Costa	08;51	7.9	24.0	528	268	0.3	2.4	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	TNC

Legend:

ND: not detectable NT: not tested NS: not set FU: colony formed urTNC: Too Numerous To Count

Weather Report :

Sunny Cloudy Rain

Inspected by :

Suggestions

1. Bacteriological Is Problem
2. Boiling Water Before Drinking

Mario Soares Laboratory Manager

District : Lautem
Town : Lospalos

Sampling Date : 23/05/2019

Testing Date : 24/05/2019

Sampled by : SMASA LAUTEM

Tested by : Estela Saldanha

No	Sampling Point	Time		pH	Temp. (°C)	Cond. (µS/cm)	TDS (mg/L)	Sal (‰)	Turb. (NTU)	Ca.Hard. (mg/l)	T.Hard (mg/l)	Alk. (mg/L)	NH ₃ -N (mg/L)	NO ₃ -N (mg/L)	NO ₂ -N (mg/L)	Fe (mg/L)	Flu (mg/L)	Mn (mg/L)	SO ₄ ²⁻ (mg/L)	T.Coli CFU	E.Coli CFU
		Sample	Test																		
East Timor Guidelines		Hours And Minutes		6.5-8.5	NS	NS	1000	NS	5.0	NS	200	NS	1.5	10	1	0.3	1.5	0.5	250	0	0
LP-1	Puohopou Intake Sp	15:08	NT	8.2	19.9	512	287.0	0.3	0.8	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	TNC
LP-2	Papapa Intake	15:12	NT	8.1	19.6	466	260.0	0.3	16.8	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	TNC
LP-3	Uma Seguransa Papapa	15:25	NT	8.2	20.3	528	291.0	0.3	2.5	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	4	TNC
LP-4	Ex. Edifisio SAS	09:40	NT	8.2	20.5	501	275.0	0.3	0.8	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	12	TNC
LP-5	Sr. Vitor	09:50	NT	8.4	21.1	511	276.0	0.3	0.9	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	28	TNC
LP-6	Clinica Imanuel A	16:08	NT	8.5	21.5	526	282.0	0.3	0.9	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	5	TNC
LP-7	Clinica Imanuel B	16:12	NT	8.5	21.5	458	240.0	0.2	5.0	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT
LP-8	Sr.Gil da Costa	16:20	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	TNC
LP-9	Eurico da Costa	16:25	NT	8.5	23.2	525	278.0	0.3	0.7	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	TNC
LP-10	Edifisio SAS	16:27	NT	8.5	23.3	578	295	0.3	1.1	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	TNC	TNC

Legend:

ND: not detectable; **NT:** not tested; **NS:** not set; **CFU:** colony formed unit; **TNC:** Too numerous to count; **FAC:** free available chlorine

Weather Report : Sunny Cloudy Rain

Inspected by :

Suggestions

1. Turbidity a'as
2. Persiza hadia sistema distribuissau tamba iha contaminassau !
3. Nono be'e molok atu hemu !

Chief of DNSA Laboratory

Source - District Capitals Water Supply and Sanitation Master Plan - Baucau, Lospalos, Same and Viqueque

Appendix C

Water quality test results

Cycle 1 tests May 2014

References and parameters	Units	Town	LOS PALOS	LOS PALOS	LOS PALOS	LOS PALOS	LOS PALOS	LOS PALOS	LOS PALOS	LOS PALOS	LOS PALOS	
			Date	9-May-14	9-May-14	9-May-14	9-May-14	9-May-14	9-May-14	9-May-14	13/jun/14	13/jun/14
			Location	PAPAPA INTAKE	HOTEL ROBERTO CARLOS	RSS WELL	DISTRICT ADM. OFFICE	BEHIND CHURCH	NATURA/ SAS OFFICE	EX. KODIM LAMA	PUAHOPO	PAPAPA INTAKE
WHO/TL Guideline	Sample Reference 4210	Sample Reference 4211	Sample Reference 4212	Sample Reference 4213	Sample Reference 4214	Sample Reference 4215	Sample Reference 4216	Sample Reference 4330	Sample Reference 4331			
Physical tests												
pH	-	6.5 - 8.5	7.7	7.6	7.5	7.7	7.7	7.7	7.7	7.5	7.8	NT
E. Conductivity	µs/cm	NS	566	626	520	616	590	610	610	601	608	NT
TSS	mg/L	NS	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	NT
TDS	mg/L	1000	283	313	260	308	295	305	305	301	304	NT
Salinity	%	NS	0.3	0.3	0.2	0.3	0.3	0.3	0.3	0.3	0.3	NT
Temperature	oC	NS	28.4	28.0	27.1	28.6	28.1	32.0	32.0	28.2	20.4	NT
Turbidity	NTU	5	5.0	0.1	0.4	0.2	5.1	0.4	0.4	0.5	0.7	NT
Chemical tests												
NH3-N	mg/L	1.5	0.5	0.3	0.4	0.4	0.4	0.4	0.5	0.5	NT	NT
NO3-N	mg/L	10 (as NO3-N)	0.3	ND	0.1	0.1	0.1	0.2	0.1	0.1	NT	NT
NO2-N	mg/L	1 (as NO2-N)	0.007	0.004	0.005	0.003	0.005	0.005	0.005	0.006	NT	NT
Iron (Fe)	mg/L	0.3	0.04	0.03	0.03	0.1	0.03	0.1	0.1	ND	NT	NT
Manganese (Mn)	mg/L	0.5	ND	ND	ND	ND	ND	ND	ND	ND	NT	NT
Fluoride	mg/L	1.5	0.10	0.15	0.06	0.1	0.2	0.2	0.2	0.1	NT	NT
Free chlorine	mg/L	0.5	ND	ND	ND	ND	ND	ND	ND	ND	NT	NT
Ca hardness	mg/L	NS	235	210	200	225	230	175	175	240	NT	NT
Arsenic	mg/L	0.01	ND	ND	ND	ND	ND	ND	ND	ND	NT	NT
T. Hardness	mg/L	200	240	225	230	245	245	245	245	240	NT	NT
Total alkalinity	mg/L	NS	225	215	220	240	240	240	240	230	NT	NT
Sulphate (SO4 2-)	mg/L	250	2	8	2	5	1	5	5	2	NT	NT
Bacteriological test												
Total coliform	CFU/100 mL	0	TNC	0	TNC	0	TNC	6	6	2	TNC	TNC
E. Coli	CFU/100 mL	0	TNC	0	TNC	1	TNC	6	6	8	2	2

Legend:

ND: not detectable; NT: not tested; NS: not set; CFU: colony formed unit; TNC: Too numerous to count; FAC: free available chlorine

Non compliant

Serious non compliance/health risk



Appendix 6. D4 Preliminary Design Report

(Stand-alone document)

Appendix 7. ADB Process Initial Environmental Examination (IEE) – Lospalos

(Stand-alone document)

Appendix 8. "No Objection" Letter from Lautem Municipal Administration



ADMINISTRAÇÃO
MUNICIPAL DE
LAUTEM



Administrador do Município de
LAUTEM

OFÍCIO

REF : 139 /AM. LAUTÉM/V/2021

Data : 03 Maio 2021
Hato'o : Presidente Conselho Administrativo Bee Timor Leste, E.P
Eng Carlos Peloi dos Reis

Assunto : *Nota konfirmasaun.*

Caro Sr. Presidente BTL, E.P.

Bazeia ba karta husi DGAS ho nu. Ref.: 267/680605/GAB- DGAS /2020 datada 23 de Setembro 2020 ne'ebe BTL, E.P re – encaminha ho nu.ref.:104/Gab.P.BTL.,E.P/IV/2021 iha dia 16 Abril 2021 relaciona ho fatin selesinado ba tratamento bee foer (FSTP) iha kapital Municipiu Lautem ne'ebe husu Administrasaun nia opiniaun kona ba fatin refere.

Nune'e liu husi karta ida ne'e, Administrasaun Munisipiu Lautem hakarak konfirma katak fatin refere hanesan fatin ne'ebe prepara nanis ona ba Soe lixu solidu durante ne'e. Tamba ne'e Administrador Munisipiu Lautem hakarak konfirma katak Administrasaun Munisipiu LAIHA OBJESAUN ba fatin selesinado atu estabese Sistema tratamento bee fo'er (FSTP).

Obrigado barak ba ita nia atensaun.

Melhores Cumprimentos,


Domingos Savio M.Si
O Administrador do Município de Lautem

Cc:

1. Diretor Servisu Munisipál Registos, Notariado e Cadastrais Município Lautem.
2. **Diretor Servisu Munisipál Agua Saneamento e Ambiente**
3. Diretor Servisu Municipal Planeamento Dezenvolvimento Integrado Município Lautem
4. Ponto Vokal Servisu Municipal Meio Ambiente de Lautem
5. Arkivo

Appendix 9. Pump Test Results

Los Palos_ETA_Papapa Lake

CLIENTE: AdP Timor-Leste
 PROJECTO: Surface Water Monitoring
 DISTRITO: Los Palos
 NASCENTE: ETA-Papapa Lake
 DATE: 7-out-20








TABELA DE REGISTO DE MEDIÇÃO DE CAUDAL EM NASCENTES

MEDIÇÃO Nº	IDENTIFICAÇÃO DA NASCENTE	DATA DA MEDIÇÃO	HORA DE INÍCIO DOS TESTES	HORA DE FIM DOS TESTES	EQUIPAMENTO UTILIZADO	Nº TESTE	LARGURA DO TANQUE (M)	COMPRIMENTO DO TANQUE (M)	ALTURE DE ENCHIMENTO DE ÁGUA (M)	QUANTIDADE DE ÁGUA (M3)	TEMPO DE ENCHIMENTO DO TANQUE (SEGUNDOS)	CAUDAL MEDIDO (L/S)
1	ETA-Papapa Lake	7-out-20	10:03:00	11:11:00	Tanque de betão existente com 5,0 m2 de área	1	2,00	2,50	0,395	1,975	90,00	21,94
						2	2,00	2,50	0,470	2,350	110,00	21,36
						3	2,00	2,50	0,475	2,375	116,00	20,47
						4	2,00	2,50	0,463	2,315	113,00	20,49
						5	2,00	2,50	0,472	2,360	117,00	20,17
2	ETA-Papapa Lake	7-out-20	17:01:00	17:22:00	Tanque de betão existente com 5,0 m2 de área	1	2,00	2,50	0,381	1,905	91,00	20,93
						2	2,00	2,50	0,397	1,985	97,00	20,46
						3	2,00	2,50	0,405	2,025	97,00	20,88






REGISTO FOTOGRÁFICO

Medição da área do tanque	Instalação da régua para controlo de nível de água	Controlo de válvula de seccionamento	Enchimento do tanque
			






Los Palos_ETA_Puahopo Spring

CLIENTE: AdP Timor-Leste PROJECTO: Surface Water Monitoring DISTRITO: Los Palos NASCENTE: ETA-Puahopo Spring DATE: 7-out-20												
												
TABELA DE REGISTO DE MEDIÇÃO DE CAUDAL EM NASCENTES												
MEDIÇÃO Nº	IDENTIFICAÇÃO DA NASCENTE	DATA DA MEDIÇÃO	HORA DE INÍCIO DOS TESTES	HORA DE FIM DOS TESTES	EQUIPAMENTO UTILIZADO	Nº TESTE	LARGURA DO TANQUE (M)	COMPRIMENTO DO TANQUE (M)	ALTURE DE ENCHIMENTO DE ÁGUA (M)	QUANTIDADE DE ÁGUA (M3)	TEMPO DE ENCHIMENTO DO TANQUE (SEGUNDOS)	CAUDAL MEDIDO (L/S)
1	ETA-Puahopo Spring	7-out-20	11:24:00	12:08:00	Tanque de betão existente com 5,0 m2 de área	1	2,00	2,50	0,624	3,120	61,00	51,15
						2	2,00	2,50	0,565	2,825	53,00	53,30
						3	2,00	2,50	0,504	2,520	50,00	50,40
						4	2,00	2,50	0,607	3,035	56,00	54,20
						5	2,00	2,50	0,500	2,500	47,00	53,19
2	ETA-Puahopo Spring	7-out-20	17:32:00	17:49:00	Tanque de betão existente com 5,0 m2 de área	1	2,00	2,50	0,444	2,220	41,00	54,15
						2	2,00	2,50	0,451	2,255	40,00	56,38
						3	2,00	2,50	0,482	2,410	43,00	56,05
REGISTO FOTOGRÁFICO												
Medição da área do tanque			Instalação da régua para controlo de nível de água			Controlo de válvula de seccionamento			Enchimento do tanque			
												

Los Palos_ Papapa Spring (B1+B2)

CLIENTE: AdP Timor-Leste PROJECTO: Surface Water Monitoring DISTRITO: Los Palos NASCENTE: Papapa spring (B1+B2) DATE: 6-out-20									
TABELA DE REGISTO DE MEDIÇÃO DE CAUDAL EM NASCENTES									
MEDIÇÃO Nº	IDENTIFICAÇÃO DA NASCENTE	DATA DA MEDIÇÃO	HORA DE INÍCIO DOS TESTE	HORA DE FIM DOS TESTES	EQUIPAMENTO UTILIZADO	Nº TESTE	TEMPO DE ENCHIMENTO DO TANQUE (SEGUNDOS)	TANQUE UTILIZADO (L)	CAUDAL MEDIDO (L/S)
1	Papapa spring (B1+B2)	6-out-20	07:57:00	15:14:00	Motobomba nº1 (4 Polegadas)	1	15,85	250,00	15,77
						2	15,65	250,00	15,97
						3	15,96	250,00	15,66
						4	17,25	250,00	14,49
						5	17,43	250,00	14,34
						6	17,26	250,00	14,48
						7	16,01	250,00	15,62
						8	15,49	250,00	16,14
						9	15,50	250,00	16,13
2	Papapa spring (B1+B2)	6-out-20	07:57:00	15:14:00	Motobomba nº2 (4 Polegadas)	1	16,3	250,00	15,34
						2	16,69	250,00	14,98
						3	16,82	250,00	14,86
						4	15,32	250,00	16,32
						5	17,37	250,00	14,39
						6	15,64	250,00	15,98
						7	16,05	250,00	15,58
						8	15,95	250,00	15,67
						9	15,44	250,00	16,19
REGISTO FOTOGRÁFICO									
Preparação do local de medição			Instalação de moto bombas			Estabilização do nível de água		Registo do teste de medição	
									

Los Palos_ Papapa Spring (B3)

CLIENTE: AdP Timor-Leste PROJECTO: Surface Water Monitoring DISTRITO: Los Palos NASCENTE: Papapa spring (B3) DATE: 6-out-20									
TABELA DE REGISTO DE MEDIÇÃO DE CAUDAL EM NASCENTES									
MEDIÇÃO Nº	IDENTIFICAÇÃO DA NASCENTE	DATA DA MEDIÇÃO	HORA DE INÍCIO DOS TESTES	HORA DE FIM DOS TESTES	EQUIPAMENTO UTILIZADO	Nº TESTE	TEMPO DE ENCHIMENTO DO TANQUE (SEGUNDOS)	TANQUE UTILIZADO (L)	CAUDAL MEDIDO (L/S)
1	Papapa spring (B3)	6-out-20	15:15:00	18:13:00	Motobomba (4 Polegadas)	1	12,40	250,00	20,16
						2	13,06	250,00	19,14
						3	13,95	250,00	17,92
						4	14,34	250,00	17,43
						5	14,05	250,00	17,79
						6	13,33	250,00	18,76
						7	13,00	250,00	19,23
						8	13,77	250,00	18,16
						9	13,94	250,00	17,94
REGISTO FOTOGRÁFICO									
Preparação do local de medição		Instalação de moto bombas			Estabilização do nível de água		Registo do teste de medição		
									

Los Palos_ Papapa Spring (C2)

CLIENTE: AdP Timor-Leste
 PROJECTO: Surface Water Monitoring
 DISTRITO: Los Palos
 NASCENTE: Papapa spring (C2)
 DATE: 6-out-20



TABELA DE REGISTO DE MEDIÇÃO DE CAUDAL EM NASCENTES

MEDIÇÃO Nº	IDENTIFICAÇÃO DA NASCENTE	DATA DA MEDIÇÃO	HORA DE INÍCIO DOS TESTES	HORA DE FIM DOS TESTES	EQUIPAMENTO UTILIZADO	Nº TESTE	TEMPO DE ENCHIMENTO DO TANQUE (SEGUNDOS)	TANQUE UTILIZADO (L)	CAUDAL MEDIDO (L/S)
1	Papapa spring (C2)	6-out-20	18:21:00	19:05:00	Motobomba com válvula (4 Polegadas)	1	26,97	250,00	9,27
						2	25,72	250,00	9,72
						3	31,06	250,00	8,05
						4	17,63	250,00	14,18
						5	26,34	250,00	9,49
						6	20,48	250,00	12,21

REGISTO FOTOGRÁFICO

Preparação do local de medição	Instalação de moto bombas e válvula	Estabilização do nível de água	Registo do teste de medição
			

RN438 - Home II



H2O Trade Centre
15 Henning Road
Coolalinga
NT 0835
Phone: (08) 8983 2611
Fax: (08) 8983 2711

PUMP TEST SUMMARY

PAGE 1 OF 14
JOB#: 1497

CLIENT: AOP
 REGISTERED # (RN): 438
 LOCATION: HOME LOSPALOS GPS: 08°30'9.290" S
 WELL NAME: HOME II 126°57'4.389" E
 RECORDERS NAME: NATALINO MENDES
 DATES OF TEST: 4-10-20 TO: 4-10-20

BORE CONSTRUCTION DATA		
TOTAL DEPTH: <u>43</u>	MTRS	DATE DRILLED: <u>3-10-20</u>
TOTAL DEPTH CASSED: <u>42.5</u>	MTRS	SWL WHEN DRILLED: <u>8</u> MTR
CASING SIZE: <u>150</u>	(MM) ID	REG B ATTACHED: <u>(YES)</u> NO
SCREENS/ SLOTS: <u>FROM 41.24 TO 21.2-15.6</u>	MTRS	SCREEN/SLOTS APERTURE: <u>2</u> mm
WARNING: MINIMUM INTERNAL BORE DIAMETER IS <u>150</u> mm		

TEST EQUIPMENT USED	
PUMP TYPE: <u>SUBMERSIBLE PUMP</u>	PUMP TEST TRAILER USED: <u>Y</u> <input checked="" type="checkbox"/> <u>(N)</u>
BRAND/MODEL: <u>GRUNDFOS</u>	GENERATOR SIZE: <u>50</u> <u>(KVA)</u>
MOTOR KW: <u>11 KW</u>	POLY SIZE & Length:
PUMP OUTLET SIZE: <u>3"</u>	COLUMN SIZE: <u>3"</u>
DISCHARGE PIPE SIZE: <u>3"</u>	COLUMN LENGTHS AND NUMBER USED: <u>4.2 x 5 + 1 + 2MTR PUMP & MOTOR</u>
ORIFICE SIZE: <u>-</u>	TOP OF PUMP TO INLET: <u>23</u>
OTHER DEVICES USED: <u>FLOW METER</u>	ACTUAL PUMP INLET DEPTH: <u>22.5</u>
REMARKS:	MTRS <u>(TO) GL</u>

DRAW DOWN MEASURED FROM <u>(TO) GL / OTHER:</u>	
STEPPED TEST	CONSTANT RATE TEST <u>(N/A)</u>
DATE OF TEST: <u>4-10-20</u>	DATES OF TEST: TO:
SWL AT START: <u>8.30</u>	SWL AT START:
STEP ONE: <u>7</u> LPS <u>60</u> MINS	DISCHARGE RATE: LPS
STEP TWO: <u>9</u> LPS <u>60</u> MINS	PUMPING DURATION: MINS
STEP THREE: <u>11</u> LPS <u>60</u> MINS	MAX DRAWDOWN: MTRS
STEP FOUR: <u>15</u> LPS <u>60</u> MINS	RECOVERY MEASURED TO: MTRS
STEP FIVE: <u>-</u> LPS <u>-</u> MINS	AT MINS AFTER SHUTDOWN.
RECOVERY MEASURED TO: MTRS	
FROM SWL AT MINS AFTER SHUTDOWN	
REMARKS:	

OBSERVATION WELLS <u>(N/A)</u>							
NAME OF OBSERVATION WELLS:							
REGISTERED NUMBERS (RN):							
DISTANCE FROM PUMP WELL:							
DIRECTION FROM PUMP WELL:							
STATIC WATER LEVEL (GL OR TOC):							
SPS:							
SWL AT END OF TEST:							
REMARKS:							



H2O Trade Centre
 15 Fenning Road
 Coolalinga
 NT 0835
 Phone:
 (08) 8983 2611
 Fax:
 (08) 8983 2711

PUMP TEST SUMMARY - COMPOSITE OF BORE

PAGE 2 OF 14

JOB#: 1497

CLIENT: ADP

REGISTERED # (RN): 438

LOCATION: HOME, LOSPALOS


08°30m 9.2906m South
 GPS: 126°57mid 4.389m East

WELL NAME: HOME II


RECORDERS NAME: NATALIND MENDES

DATES OF TEST: 4-10-20

TO: 4-10-20



OTHER BORE DETAILS:



H2O Trade Centre
15 Henning Road
Coolalinga
NT 0835
Phone: (05)89832611
Fax: (08)89832711

STEPPED RATE PUMPING TEST

PAGE 3 OF 13

JOB#: 1497

CLIENT: ADP
 DATE: 4-10-20
 REGISTERED NUMBER (RN): 438
 LOCATION: HOME LOSPALOS GPS:
 WELL NAME: HOME II
 PUMP SETTING (INLET DEPTH): 23 TOC/GL
 STATIC WATER LEVEL: 8:30 TOC/GL
 DISCHARGE RATE: 7, 9, 14, 15 LPS
 OTHER DETAILS:

STEP 1					STEP 2				
NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS	NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS
	830	830				930	9.78	1.43	
	831	9.29	0.99			931	9.80	1.50	
	832	9.45	1.15			932	9.99	1.58	
	833	9.51	1.21			933	9.95	1.65	
	834	9.55	1.25			934	10.11	1.81	
	835	9.58	1.28			935	10.18	1.88	
	836	9.59	1.29			936	10.14	1.84	
	837	9.61	1.31			937	10.18	1.83	
	838	9.61	1.31			938	10.14	1.89	
	839	9.63	1.33			939	10.16	1.86	
	840	9.64	1.34			940	10.17	1.87	
	842	9.65	1.35			942	10.19	1.91	
	844	9.66	1.36			944	10.20	1.90	
	846	9.66	1.36			946	10.22	1.93	
	848	9.66	1.36			948	10.22	1.92	
	850	9.66	1.37			950	10.23	1.93	
	855	9.67	1.37			955	10.25	1.95	
	900	9.68	1.38			1000	10.26	1.96	
	905	9.68	1.38			1005	10.28	1.98	
	910	9.70	1.40			1010	10.28	1.98	
	915	9.71	1.41			1015	10.29	1.99	
	920	9.72	1.42			1020	10.29	1.99	
	930	9.73	1.43			1030	10.30	2.00	
	70					70			
	80					80			
	100					100			

Handwritten notes:
 PPE = 0.30
 Ph = 1.02
 ms = 0.61



H2O Trade Centre
 15 Henning Road
 Coolalinga
 NT 0835
 Phone: (08)89832611
 Fax: (08)89832711

STEPPED RATE PUMPING TEST

PAGE 4 OF 14

JOB#: 1497

CLIENT: ADP

DATE: 4-10-20

REGISTERED NUMBER (RN): 438

LOCATION: HOME, LOS PALOS GPS:

WELL NAME: HOME II


PUMP SETTING (INLET DEPTH): 23 TOC/GL

STATIC WATER LEVEL: TOC/GL

DISCHARGE RATE: LPS

OTHER DETAILS:

STEP 3					STEP 4				
NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS	NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS
0	1030			11 LPS	0	1130	11.49	3.19	15 LPS
1	1031	10.57	2.27		1	1131	16.93	8.63	
2	1032	10.63	2.33		2	1132	18.24	9.94	
3	1033	10.72	2.42		3	1133	19.67	11.37	
4	1034	10.78	2.48		4	1134	19.65	11.35	adjust valve
5	1035	10.85	2.55		5	1135	19.00	10.7	adjust valve
6	1036	10.95	2.65		6	1136	17.00	8.7	
7	1037	11.04	2.74		7	1137	16.87	8.67	
8	1038	11.08	2.78		8	1138	17.84	9.59	
9	1039	11.10	2.80		9	1139	17.84	8.94	
10	1040	11.08	2.78		10	1140	17.13	8.83	
12	1042	11.14	2.84		12	1142	17.17	8.87	
14	1044	11.20	2.90		14	1144	16.93	8.63	
16	1046	11.23	2.93		16	1146	17.03	8.73	
18	1048	11.27	2.97		18	1148	16.89	8.59	
20	1050	11.31	3.01		20	1150	17.10	8.8	
25	1055	11.35	3.05		25	1155	17.29	8.99	
30	1100	11.38	3.08		30	1200	17.15	8.85	
35	1105	11.41	3.11		35	1205	17.10	8.8	
40	1110	11.43	3.13		40	1210	17.20	8.9	
45	1115	11.45	3.15		45	1215	17.20	8.9	
50	1120	11.47	3.17		50	1220	17.22	8.92	
60	1130	11.49	3.19		60	1230	17.10		
70					70				
80					80				
100					100				



H2O Trade Centre
 15 Henning Road
 Coolalinga
 NT 0835
 Phone: (08) 8983 2611
 Fax: (08) 8983 2711

RECOVERY FROM STEPPED RATE TEST

PAGE 5 OF 14

JOB#: 1497

CLIENT: ADP
 DATE: 4-10-20
 REGISTERED NUMBER (RN): 438
 LOCATION: HOME, LOSPALOS GPS:
 WELL NAME: HOME II
 PUMP SETTING (INLET DEPTH): 23 TOC/GL
 STATIC WATER LEVEL: 8.30 TOC/GL
 DISCHARGE RATE: 7, 9, 11, 15 LPS
 OTHER DETAILS:

NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS
0	12.30	17.10		END
1	12.31	10.47	2.17	
2	12.32	9.97	1.67	
3	12.33	9.63	1.33	
4	12.34	9.44	1.14	
5	12.35	9.25	0.96	
6	12.36	9.11	0.81	
7	12.37	8.97	0.67	
8	12.38	8.87	0.57	
9	12.39	8.78	0.48	
10	12.40	8.71	0.41	
12	12.42	8.60	0.30	
14	12.44	8.53	0.23	
16	12.46	8.48	0.18	
18	12.48	8.45	0.15	
20	12.50	8.42	0.12	
25	12.55	8.39	0.09	
30	13.00	8.36	0.06	
35	13.05	8.34	0.04	
40	13.10	8.33	0.03	
45	13.15	8.30	0.02	
50				
60				FINISH TEST.
70				
80				
100				
120				
140				
160				
180				
210				
240				
270				
300				
360				
420				

RN439 - Home III



H2O Trade Centre
 15 Henning Road
 Coolalinga
 NT 0835
 Phone: (08) 8983 2611
 Fax: (08) 8983 2711

PUMP TEST SUMMARY

PAGE 1 OF 14
 JOB#: 1497

CLIENT: **AOP**

REGISTERED # (RN): **439**

LOCATION: **HOME III LOSPALOS** GPS: **08° 30' 14.64" S**

WELL NAME: **HOME PRODUCTION** **126° 57' 35.43" E**

RECORDERS NAME: **NATALINO MENDES**

DATES OF TEST: **8-10-20** TO:

BORE CONSTRUCTION DATA		8-10-20
TOTAL DEPTH: 46M	(MTRS)	DATE DRILLED: 8-10-20
TOTAL DEPTH CASSED: 44	MTRS	SWL WHEN DRILLED: 10.78
CASING SIZE: 200	(MM) ID	REG 8 ATTACHED: (YES) NO
SCREENS/ SLOTS: FROM 17A-28 TO 33-39	MTRS	SCREEN/SLOTS APERTURE: 2 mm
WARNING: MINIMUM INTERNAL BORE DIAMETER IS 200 mm		

TEST EQUIPMENT USED	
PUMP TYPE: SUBMERSIBLE PUMP	PUMP TEST TRAILER USED: Y (N)
BRAND/MODEL: GRUNDPOS	GENERATOR SIZE: 50 (KVA)
MOTOR KW: 11 KW	POLY SIZE & Length:
PUMP OUTLET SIZE: 3"	COLUMN SIZE: 3"
DISCHARGE PIPE SIZE: 3"	COLUMN LENGTHS AND NUMBER USED:
ORIFICE SIZE:	2.2 x 6 + 1.5 + PUMP & MOTOR 2MTR
OTHER DEVICES USED: FLOW METER	
REMARKS:	TOP OF PUMP TO INLET: 28.5
	ACTUAL PUMP INLET DEPTH: 28
	(MTRS TO/CL)

DRAW DOWN MEASURED FROM (TOC/GL) OTHER:	
STEPPED TEST	CONSTANT RATE TEST
DATE OF TEST: 9-10-20	DATES OF TEST: 9-10-20 TO: 10-10-20
SWL AT START: 10.73	SWL AT START: 10.73
STEP ONE: 9 LPS 60 MINS	DISCHARGE RATE: 20 (LPS)
STEP TWO: 13 LPS 60 MINS	PUMPING DURATION: 1440 (MINS)
STEP THREE: 15 LPS 60 MINS	MAX DRAWDOWN: MTRS
STEP FOUR: 20 LPS 60 MINS	RECOVERY MEASURED TO: 10.73 MTRS
STEP FIVE: LPS MINS	AT MINS AFTER SHUTDOWN.
RECOVERY MEASURED TO: MTRS	
FROM SWL AT MINS AFTER SHUTDOWN	
REMARKS:	

OBSERVATION WELLS						
NAME OF OBSERVATION WELLS:						
REGISTERED NUMBERS (RN):						
DISTANCE FROM PUMP WELL:						
DIRECTION FROM PUMPED WELL:						
STATIC WATER LEVEL (GL OR TOC):						
SPS:						
SWL AT END OF TEST:						
REMARKS:						




H2O Trade Centre
 15 Henning Road
 Coolalinga
 NT 0835
 Phone:
 (08) 8983 2611
 Fax:
 (08) 8983 2711

PUMP TEST SUMMARY - COMPOSITE OF BORE

PAGE 2 OF 14

JOB#: 1497

CLIENT: AOP
 REGISTERED # (RN): 439
 LOCATION: HOME, LOSPALOS GPS:
 WELL NAME: HOME PRODUCTION
 RECORDERS NAME: NATALIND MENDES
 DATES OF TEST: 9-10-20 TO: 10-10-20



OTHER BORE DETAILS:





H2O Trade Centre
15 Henning Road
Coolalinga
NT 0835
Phone: (08)89832611
Fax: (08)89832711

STEPPED RATE PUMPING TEST

PAGE 3 OF 13

JOB#: 1497

CLIENT: ADP

DATE: 8-10-20

REGISTERED NUMBER (RN): 439

LOCATION: HOME III Lowflow GPS:

WELL NAME: HOME B^o PRODUCTION

PUMP SETTING (INLET DEPTH): 2600C/GL

STATIC WATER LEVEL: 10.73 100/GL

DISCHARGE RATE: LPS

OTHER DETAILS:

STEP 1					STEP 2				
NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS	NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS
				9 LPS					12 LPS
0		10.73			0	7000	10.83		
1	6001	10.81		ADJUST VALVE	1	7001	10.88	0.15	
2	6002	10.83	0.08	ADJUST VALVE	2	7002	10.88	0.15	
3	6003	10.82	0.09	0.09	3	7003	10.88	0.15	
4	6004	10.82	0.09		4	7004	10.88	0.15	
5	6005	10.82	0.09	PH: 1.3	5	7005	10.88	0.15	
6	6006	10.82	0.09	MS: 0.62	6	7006	10.88	0.15	
7	6007	10.82	0.09		7	7007	10.88	0.15	
8	6008	10.82	0.09		8	7008	10.88	0.15	
9	6009	10.82	0.09		9	7009	10.88	0.15	
10	6010	10.82	0.09		10	7010	10.88	0.15	
12	6012	10.82	0.09		12	7012	10.88	0.15	
14	6014	10.83	0.1		14	7014	10.88	0.15	
16	6016	10.83	0.10		16	7016	10.88	0.15	
18	6018	10.84	0.11		18	7018	10.88	0.15	
20	6020	10.83	0.10		20	7020	10.88	0.15	
25	6025	10.83	0.10		25	7025	10.88	0.15	
30	6030	10.83	0.10		30	7030	10.89	0.16	
35	6035	10.83	0.10		35	7035	10.89	0.16	
40	6040	10.83	0.10		40	7040	10.89	0.16	
45	6045	10.83	0.10		45	7045	10.89	0.16	
50	6050	10.83	0.10		50	7050	10.89	0.16	
60	7000	10.83			60	7000	10.89	0.16	
70					70				
80					80				
100					100				



H2O Trade Centre
 15 Henning Road
 Coolalinga
 NT 0835
 Phone: (08)89832611
 Fax: (08)89832711

STEPPED RATE PUMPING TEST

PAGE 4 OF 14

JOB#: 1497

CLIENT: ADP
 DATE: 8-10-20
 REGISTERED NUMBER (RN): 439
 LOCATION: HOME III LOS PALOS GPS:
 WELL NAME: HOME PRODUCTION
 PUMP SETTING (INLET DEPTH): 20 TOC/GL
 STATIC WATER LEVEL: 10.73 TOC/GL
 DISCHARGE RATE: 9, 12, 15, 20 LPS
 OTHER DETAILS:

STEP 3					STEP 4				
NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS	NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS
				15 LPS					20 LPS
0	8000	10.89			0	9000	10.94		
1	8001	10.95	0.22	Adjust Valve	1	9001	11.02	0.29	
2	8002	10.94	0.21		2	9002	11.03	0.3	
3	8003	10.94	0.21		3	9003	11.03	0.30	
4	8004	10.93	0.2	Adjust Valve	4	9004	11.03	0.30	
5	8005	10.94	0.21		5	9005	11.03	0.30	
6	8006	10.94	0.21		6	9006	11.03	0.30	
7	8007	10.94	0.21	15 LPS	7	9007	11.03	0.30	Raining
8	8008	10.94	0.21	15 LPS	8	9008	11.03	0.30	Raining
9	8009	10.94	0.21		9	9009	11.03	0.30	Raining
10	8010	10.94	0.21	Clear water	10	9010	11.03	0.30	
12	8012	10.94	0.21		12	9012	11.03	0.30	
14	8014	10.94	0.21	Clear water	14	9014	11.03	0.30	Raining
16	8016	10.94	0.21		16	9016	11.03	0.30	
18	8018	10.94	0.21		18	9018	11.03	0.30	
20	8020	10.94	0.21	Clear water	20	9020	11.03	0.30	
25	8025	10.94	0.21		25	9025	11.04	0.31	Raining
30	8030	10.94	0.21		30	9030	11.04	0.31	
35	8035	10.94	0.21		35	9035	11.04	0.31	
40	8040	10.94	0.21		40	9040	11.04	0.31	
45	8045	10.94	0.21		45	9045	11.04	0.31	
50	8050	10.94	0.21		50	9050	11.04	0.31	
60	9000	10.94	0.2		60	1000	11.04	0.31	
70					70				
80					80				
100					100				



H2O Trade Centre
 15 Henning Road
 Coolalinga
 NT 0835
 Phone: (08) 8983 2611
 Fax: (08) 8983 2711


RECOVERY FROM STEPPED RATE TEST

PAGE 5 OF 14

JOB#: 1497

CLIENT: ADP
 DATE: 8-10-20
 REGISTERED NUMBER (RN): 439
 LOCATION: HOME III LOSPALOS GPS:
 WELL NAME: HOME PRODUCTION
 PUMP SETTING (INLET DEPTH): 28.5 TOC/GL
 STATIC WATER LEVEL: 10.78 TOC/GL
 DISCHARGE RATE: 9, 13, 15, 2.0 LPS
 OTHER DETAILS:

NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS
0	10.00	11.04		20 LPS END
1	10.01	10.84	0.11	
2	10.02	10.80	0.07	
3	10.03	10.79	0.06	
4	10.04	10.79	0.06	
5	10.05	10.79	0.06	END OF Recovery
6	10.06			
7	10.07			
8	10.08			
9	10.09			
10	10.10			
12				
14				
16				
18				
20				
25				
30				
35				
40				
45				
50				
60				
70				
80				
100				
120				
140				
160				
180				
210				
240				
270				
300				
360				
420				



H2O Trade Centre
 15 Henning Road
 Coolalinga
 NT 0835
 Phone: (08) 8983 2611
 Fax: (08) 8983 2711

CONSTANT RATE PUMPING TEST

PAGE 6 OF 14

JOB#: 1497

CLIENT: ADP
 DATE: 9-10-2020
 REGISTERED NUMBER (RN): 439
 LOCATION: HOME III LOSPALOS GPS:
 WELL NAME: HOME PRODUCTION
 PUMP SETTING (INLET DEPTH): 28.5 COO/GL
 STATIC WATER LEVEL: 10.78 COO/GL
 DISCHARGE RATE: 20 LPS LPS
 OTHER DETAILS:

NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS
	7:00			20 LPS
0	7000	10.78	10.78	
0.5	7005	10.99	0.21	
1	7001	10.99	0.21	
1.5	70015	10.99	0.21	
2	7002	10.99	0.21	
2.5	70025	10.99	0.21	
3	7003	10.99	0.21	
4	7004	11:00	0.22	
5	7005	11.00	0.22	
6	7006	11.00	0.22	
7	7007	11.00	0.22	
8	7008	11.00	0.22	
9	7009	11.00	0.22	
10	7010	11.01	0.23	
12	7012	11.01	0.23	
14	7014	11.02	0.24	
16	7016	11.02	0.24	
18	7018	11.02	0.24	
20	7020	11.02	0.24	
25	7025	11.03	0.25	
30	7030	11.03	0.25	
35	7035	11.03	0.25	
40	7040	11.03	0.25	
45	7045	11.03	0.25	
50	7050	11.04	0.26	
60	8000	11.04	0.26	
70	8010	11.05	0.27	
80	8020	11.06	0.28	
90	8030	11.05	0.27	
100	8040	11.05	0.27	OBSERVATION BORE NO 2 : 10.72 MTR
120	9000	11.06	0.28	
140	9020	11.06	0.28	
160	9040	11.06	0.28	
180	9060	11.06	0.28	
210	1030	10.06	0.28	
240	1100	11.08	0.30	OBSERVATION BORE NO 2 : 8.73 MTR



H2O Trade Centre
 15 Henning Road
 Coolalinga
 NT 0835
 Phone: (08) 8983 2611
 Fax: (08) 8983 2711

CONSTANT RATE PUMPING TEST

PAGE 7 OF 14

JOB#: 1497

CLIENT: AOP

DATE: 9-10-200

REGISTERED NUMBER (RN): 439

LOCATION: HOME III, LOSPALOS GPS:

WELL NAME: HOME PRODUCTIONS

PUMP SETTING (INLET DEPTH): 28.5 TOOGL

STATIC WATER LEVEL: 10.78 TOOGL

DISCHARGE RATE: 20LPS LPS

OTHER DETAILS:

NO MIN	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS
270	11:30	11.09	0.31	
300	12:00	11.10	0.32	
360	13:00	11.11	0.33	
420	14:00	11.13	0.35	
480	15:00	11.14	0.36	
540	16:00	11.15	0.37	
600	17:00	11.15	0.37	Observation 8.73
660	18:00	11.19	0.41	
720	19:00	11.20	0.42	Giving bore head to do concrete slab + 5 cmtr
780	20:00	11.21	0.43	
840	21:00	11.22	0.44	
900	22:00	11.23	0.45	
1020	24:00	11.24	0.46	
1140	02:00	11.25	0.47	
1260	04:00	11.27	0.49	
1380	06:00	11.29	0.51	
1440	07:00	11.29	0.51	
1500				
1620				
1740				
1860				
1980				
2100				
2220				
2340				
2460				
2580				
2700				
2820				
2940				
3060				
3180				
2300				
2420				
2540				



H2O Trade Centre
 15 Henning Road
 Coolalinga
 NT 0835
 Phone: (08) 8983 2611
 Fax: (08) 8983 2711

RECOVERY FROM CONSTANT RATE TEST-

PAGE 9 OF 14

JOB#: 1497

CLIENT: ADP
 DATE: 10-10-20 239
 REGISTERED NUMBER (RN): A39
 LOCATION: HOME, LOSPALOS GPS:
 WELL NAME: HOME, PRODUCTION
 PUMP SETTING (INLET DEPTH): 28.5 (100)GL
 STATIC WATER LEVEL: 10.78 (700)GL
 DISCHARGE RATE: 20 (LPS)
 OTHER DETAILS:

NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS
0	7000	11.29		
0.5	7005	11.05		END
1	7001	11.05		
1.5	7005	11.04		
2	7002	11.04		
2.5	70025	11.04		
3	7003	11.04		
4	7004	11.03		
5	7005	11.03		
6	7006	11.03		
7	7007	11.03		
8	7008	11.025		
9	7009	11.025		
10	7010	11.025		
12	7012	11.025		
14	7014	11.02		
16	7016	11.02		
18	7018	11.015		
20	7020	11.015		End of Recovery
25	7025	11.01		
30	7030	11.01		
35	7035	11.01		
40	7040	11.00		90% Recovery.
45				
50				
60				Final TEST.
70				
80				
90				
100				
120				
140				
160				
180				
210				
240				

RN441 - Sawarika



H2O PUMP & POWER
 Comoro River Road
 Dili, Timor Leste
 Phone: 670 3324497
 Email: admin@h2o.tl

PUMP TEST SUMMARY

PAGE 1 OF 14

JOB#: 1497

CLIENT: AOP

REGISTERED # (RN): 441

LOCATION: SAWARIKA

GPS: 08°31'40.05" S

WELL NAME: SAWARIKA PRODUCTION 126°59'27.76 E

RECORDERS NAME:

DATES OF TEST: 15-10-20

TO: 15-10-20

BORE CONSTRUCTION DATA			
TOTAL DEPTH:	<u>46</u>	MTRS	DATE DRILLED: <u>14-10-20</u>
TOTAL DEPTH CASSED:	<u>42.5</u>	MTRS	SWL WHEN DRILLED: <u>5.15</u>
CASING SIZE:	<u>6" / 150</u>	MM ID	REG 8 ATTACHED: <u>(YES)</u> NO
SCREENS/ SLOTS: FROM	<u>12.4</u> TO <u>18</u>	MTRS	SCREEN/SLOTS APERTURE: <u>2</u> mm
WARNING: MINIMUM INTERNAL BORE DIAMETER IS <u>150</u> (mm)			
TEST EQUIPMENT USED			
PUMP TYPE:	<u>SUBMERSIBLE PUMP</u>	PUMP TEST TRAILER USED:	Y <u>(N)</u>
BRAND/MODEL:	<u>BRUNNEN</u>	GENERATOR SIZE:	<u>50</u> KVA
MOTOR KW:	<u>11 KW</u>	POLY SIZE & Length:	
PUMP OUTLET SIZE:	<u>3"</u>	COLUMN SIZE:	<u>3"</u>
DISCHARGE PIPE SIZE:	<u>3"</u>	COLUMN LENGTHS AND NUMBER USED:	
ORIFICE SIZE:		<u>4.2 x 6 + pump + motor and</u>	
OTHER DEVICES USED:	<u>Flow meter</u>	<u>2 mt 3" column</u>	
REMARKS:		TOP OF PUMP TO INLET:	<u>29</u>
		ACTUAL PUMP INLET DEPTH:	<u>28.5</u>
			MTRS <u>TOC/GL</u>
DRAW DOWN MEASURED FROM TOC/GL/OTHER:			
STEPPED TEST		CONSTANT RATE TEST <u>(N/A)</u>	
DATE OF TEST:	<u>15-10-20</u>	DATES OF TEST:	TO:
SWL AT START:		SWL AT START:	
STEP ONE:	<u>14</u> <u>LPS</u> <u>60</u> MINS	DISCHARGE RATE:	LPS
STEP TWO:	<u>16</u> <u>LPS</u> <u>60</u> MINS	PUMPING DURATION:	MINS
STEP THREE:	<u>18</u> <u>LPS</u> <u>60</u> MINS	MAX DRAWDOWN:	MTRS
STEP FOUR:	<u>21</u> <u>LPS</u> <u>60</u> MINS	RECOVERY MEASURED TO:	MTRS
STEP FIVE:	<u>LPS</u> <u>MINS</u>	AT	MINS AFTER SHUTDOWN.
RECOVERY MEASURED TO:	MTRS		
FROM SWL AT	MINS AFTER SHUTDOWN		
REMARKS:			
OBSERVATION WELLS <u>(N/A)</u>			
NAME OF OBSERVATION WELLS:			
REGISTERED NUMBERS (RN):			
DISTANCE FROM PUMP WELL:			
DIRECTION FROM PUMPED WELL:			
STATIC WATER LEVEL (GL OR TOC):			
GPS:			
SWL AT END OF TEST:			
REMARKS:			




PUMP TEST SUMMARY - COMPOSITE OF BORE

PAGE 2 OF 14

JOB#: 1497

H2O PUMP & POWER
 Comoro River Road
 Dili, Timor Leste
 Phone: 670 3324497
 Email: admin@h2o.tl

CLIENT: ADP
 REGISTERED # (RN): 441
 LOCATION: SAMARINA GPS:
 WELL NAME: SAMARINA PRODUCTION
 RECORDERS NAME: MARINO Mendes
 DATES OF TEST: 15-10-20 TO: 15-10-20



OTHER BORE DETAILS:



H2O Trade Centre
 15 Henning Road
 Coolalinga
 NT 0835
 Phone: (08)89832611
 Fax: (08)89832711

STEPPED RATE PUMPING TEST

PAGE 3 OF 13

JOB#: 1497

CLIENT: ADP
 DATE: 15-10-20
 REGISTERED NUMBER (RN): 441
 LOCATION: SAWARIKA, LOSALOS GPS:
 WELL NAME: SAWARIKA PRODUCTION I
 PUMP SETTING (INLET DEPTH): 21 TOC/IGL
 STATIC WATER LEVEL: 5.15 TOC/IGL
 DISCHARGE RATE: 14,16,18,21 LPS
 OTHER DETAILS:

STEP 1					STEP 2				
NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS	NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS
0	700	5.15	5.15		0	800	6.03	0.88	
1	701	5.83	0.68	ADJUST VALVE	1	8001	6.24	1.09	
2	702	5.98	0.83	ADJUST VALVE	2	8002	6.245	1.095	
3	703	5.94	0.79		3	8003	6.245	1.095	
4	704	5.95	0.80		4	8004	6.25	1.1	
5	705	5.95	0.80		5	8005	6.25	1.1	
6	706	5.96	0.81		6	8006	6.25	1.1	
7	707	5.96	0.81		7	8007	6.25	1.095	
8	708	5.96	0.81		8	8008	6.25	1.1	
9	709	5.96	0.81		9	8009	6.25	1.1	
10	7010	5.96	0.81		10	8010	6.25	1.1	
12	7012	5.98	0.83		12	8012	6.25	1.1	
14	7014	5.98	0.83		14	8014	6.25	1.1	
16	7016	5.98	0.83		16	8016	6.255	1.105	
18	7018	5.99	0.84		18	8018	6.255	1.105	
20	7020	5.99	0.84		20	8020	6.26	1.11	
25	7025	5.99	0.84	MS 0.57	25	8025	6.26	1.11	
30	7030	6.00	0.85	Ph 0.9	30	8030	6.26	1.11	
35	7035	6.00	0.85		35	8035	6.26	1.11	
40	7040	6.015	0.865		40	8040	6.265	1.115	
45	7045	6.02	0.87		45	8045	6.265	1.115	
50	7050	6.02	0.87		50	8050	6.27	1.12	
60	8000	6.03	0.88		60	9000	6.28	1.13	
70					70				
80					80				
100					100				



H2O Trade Centre
15 Henning Road
Coolalinga
NT 0835
Phone: (08)89832611
Fax: (08)89832711

STEPPED RATE PUMPING TEST

PAGE 4 OF 14

JOB#: 1497

CLIENT: AOP
 DATE: 15-10-20
 REGISTERED NUMBER (RN): 440
 LOCATION: SAWARIKA, LESPALES GPS:
 WELL NAME: SAWARIKA PRODUCTION
 PUMP SETTING (INLET DEPTH): 29 TOE/IGL
 STATIC WATER LEVEL: 515 TOE/IGL
 DISCHARGE RATE: 14, 16, 18, 21 LPS
 OTHER DETAILS:

STEP 3					STEP 4				
NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS	NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS
	9000	6.28	1.13	18 LPS		1000			21 LPS
1	9001	6.46	1.32		0	1001	6.75	1.6	
2	9002	6.47	1.32		1	1002	6.77	1.62	
3	9003	6.47	1.32		2	1003	6.77	1.62	
4	9004	6.47	1.32		3	1004	6.77	1.62	
5	9005	6.47	1.32		4	1005	6.77	1.62	
6	9006	6.47	1.32		5	1006	6.77	1.62	
7	9007	6.47	1.32		6	1007	6.78	1.63	
8	9008	6.47	1.32		7	1008	6.78	1.63	
9	9009	6.47	1.32		8	1009	6.78	1.63	
10	9010	6.47	1.32	9	1010	6.78	1.63		
12	9012	6.48	1.33	12	1012	6.78	1.63		
14	9014	6.48	1.33	14	1014	6.78	1.63		
16	9016	6.49	1.34	16	1016	6.79	1.64		
18	9018	6.49	1.34	18	1018	6.79	1.64		
20	9020	6.49	1.34	20	1020	6.79	1.64		
25	9025	6.5	1.35	25	1025	6.79	1.64		
30	9030	6.5	1.35	30	1030	6.80	1.65		
35	9035	6.5	1.35	35	1035	6.80	1.65		
40	9040	6.5	1.35	40	1040	6.81	1.66		
45	9045	6.5	1.35	45	1045	6.81	1.66		
50	9050	6.5	1.35	50	1050	6.82	1.67		
60	1000	6.5	1.35	60	1100	6.82	1.67		
70				70					
80				80					
100				100					

Ph: 0.88
MC: 0.57



H2O Trade Centre
 15 Henning Road
 Coolalinga
 NT 0835
 Phone: (08) 8983 2611
 Fax: (08) 8983 2711

RECOVERY FROM STEPPED RATE TEST

PAGE 5 OF 14

JOB#: 1497

CLIENT: ADP
 DATE: 13-10-20
 REGISTERED NUMBER (RN): 440
 LOCATION: SAWARIKA, LOSPALOSGPS:
 WELL NAME: SAWARIKA PRODUCTION
 PUMP SETTING (INLET DEPTH): 29 TOC/GL
 STATIC WATER LEVEL: 5.15 TOC/GL
 DISCHARGE RATE: LPS
 OTHER DETAILS:

NOMINAL INTERVAL (MINS)	TIME	WATER LEVEL (MTRS)	DRAW DOWN (MTRS)	REMARKS
0	11.00	6.82		END
1	11.01	5.36		
2	11.02	5.33		
3	11.03	5.32		
4	11.04	5.31		
5	11.05	5.30		
6	11.06	5.30		
7	11.07	5.29		
8	11.08	5.29		
9	11.09	5.29		
10	11.10	5.29		
12	11.12	5.28		
14	11.14	5.27		
16	11.16	5.27		
18	11.18	5.27		
20	11.20	5.26		
25	11.25	5.25		
30	11.30	5.25		
35	11.35	5.25		
40	11.40	5.24		
45	11.45	5.24		
50	11.50	5.23		
60				
70				FINISH TEST.
80				
100				
120				
140				
160				
180				
210				
240				
270				
300				
360				
420				

----- END OF REPORT -----